

APR 22 1994

DCD/DCB  
IE01

Docket Nos. 50-254; 50-265  
License Nos. DPR-29; DPR-30

Commonwealth Edison Company  
ATTN: Mr. E. Kraft  
Site Vice President  
Quad Cities Station  
22712 206th Avenue - North  
Cordova, IL 61242

Dear Mr. Kraft:

This refers to the inspection conducted by Messrs. C. Miller, T. Taylor, K. Walton, P. Prescott, and Ms. D. Chyu of this office from February 8 through March 23, 1994. This inspection included a review of authorized activities for your Quad Cities Nuclear Power Station facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress. The purpose of the inspection was to determine whether activities authorized by the license were conducted safely and in accordance with NRC requirements.

During this inspection, certain of your activities appeared to be in violation of NRC requirements, as specified in the enclosed Notice of Violation (Notice). This violation is a concern because of the failure to address industry communications on equipment problems. In addition, control of contractor personnel appeared to be weak, especially during outage activities. Increased management attention appeared warranted in this area.

You are required to respond to this letter and should follow the instructions specified in the enclosed Notice when preparing your response. In your response, you should document the specific actions taken and any additional actions you plan to prevent recurrence. Specifically, you should address what measures will be taken to ensure that vendor and industry information is promptly and properly addressed; and that instrumentation maintenance procedures adequately reflect this information. After reviewing your response to this Notice, including your proposed corrective actions and the results of future inspections, the NRC will determine whether further NRC enforcement action is necessary to ensure compliance with NRC regulatory requirements.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter, the enclosures, and your response to this letter will be placed in the NRC Public Document Room.

9405020004 940422  
PDR ADOCK 05000254  
Q PDR

IE01

APR 22 1994

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original signed by E. G. Greenman

Edward G. Greenman, Director  
Division of Reactor Projects

Enclosures:

- 1. Notice of Violation
- 2. Inspection Report
  - No. 50-254/94005(DRP);
  - No. 50-265/94005(DRP)

cc w/enclosures:

- L. DelGeorge, Vice President, Nuclear Oversight & Regulatory Services
- G. Campbell, Station Manager
- N. Chrissotimos, Regulatory Assurance Supervisor
- D. Farrar, Nuclear Regulatory Services Manager
- OC/LFDCB
- Resident Inspectors, Quad Cities, Dresden, LaSalle, Clinton
- R. Hubbard
- N. Schloss, Economist, Public Utilities Division
- Licensing Project Manager, NRR
- State Liaison Officer
- Chairman, Illinois Commerce Commission
- T. O. Martin, RIII
- S. Stein, SRS

bcc: PUBLIC - IE01

RIII  
Dmc for  
Roton  
4/21/94

RIII  
*[Signature]*  
Wright  
(Para 7.0)  
4/21/94

RIII  
*[Signature]*  
Hiland  
4/21/94

RIII  
*[Signature]*  
Hausman  
4/21/94

RIII  
*[Signature]*  
Greenman