

NOTICE OF VIOLATION

Commonwealth Edison Company
Quad Cities Station, Units 1 and 2

Docket Nos. 50-254; 50-265
License Nos. DPR-29; DPR-30

During an NRC inspection conducted on February 8 through March 23, 1994, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

The 10 CFR 50, Appendix B, Criteria V, "Instructions, Procedures, and Drawings" requires, in part, that activities affecting quality shall be prescribed by documented instructions or procedures, shall be accomplished in accordance with the instructions or procedures, and that the instructions or procedures shall include appropriate quantitative or qualitative acceptance criteria for determining that important activities have been satisfactorily accomplished.

Contrary to the above, the licensee failed to develop adequate procedures for calibrating feedwater flow transmitters which are used in determining reactor thermal power, and failed to properly calibrate these transmitters following installation between the period of November to December 1993.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Commonwealth Edison is hereby required to submit a written statement of explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington D.C. 20555, with a copy to the U.S. Nuclear Regulatory Commission, Region III, 801 Warrenville Road, Lisle, Illinois 60532-4351, and a copy to the Resident Inspector at the Quad Cities Nuclear Station within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois
this 22nd day of April 1994

9405020008 940422
PDR ADOCK 05000254
G PDR