



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ENTERGY OPERATIONS, INC.

DOCKET NO. 50-382

WATERFORD STEAM ELECTRIC STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 64
License No. NPF-38

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated February 12, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9012140156 901210
PDR ADOCK 05000382
P FDC


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-38 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 64, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate IV-1
Division of Reactor Projects III, IV, and V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 10, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 64

TO FACILITY OPERATING LICENSE NO. NPF-38

DOCKET NO. 50-382

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

REMOVE PAGES

3/4 5-5
3/4 5-6

INSERT PAGES

3/4 5-5
3/4 5-6

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. A visual inspection of the safety injection system sump and verifying that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or corrosion.
 3. Verifying that a minimum total of 97.5 cubic feet of solid trisodium phosphate dodecahydrate (TSP) is contained within the TSP storage baskets.
 4. Verifying that when a representative sample of 4 ± 0.01 grams of TSP from a TSP storage basket is submerged, without agitation, in 4 ± 0.1 liters of 120 ± 10 °F water borated within RWSP boron concentration limits, the pH of the mixed solution is raised to greater than or equal to 7 within 3 hours.
- e. At least once per 18 months, during shutdown, by:
1. Verifying that each automatic valve in the flow path actuates to its correct position on SIAS and RAS test signals.
 2. Verifying that each of the following pumps start automatically upon receipt of a safety injection actuation test signal:
 - a. High pressure safety injection pump.
 - b. Low pressure safety injection pump.
 3. Verifying that on a recirculation actuation test signal, the low pressure safety injection pumps stop, the safety injection system sump isolation valves open.
- f. By verifying that each of the following pumps required to be OPERABLE performs as indicated on recirculation flow when tested pursuant to Specification 4.0.5:
1. High pressure safety injection pump differential pressure greater than or equal to 1429 psid.
 2. Low pressure safety injection pump discharge pressure greater than or equal to 177 psig.

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- g. By verifying the correct position of each electrical and/or mechanical position stop for the following ECCS throttle valves by verifying that each ECCS throttle valve opens to the proper throttled position each time the valve is cycled:

HPSI System
Valve Number

a. SI-225A
b. SI-225B
c. SI-226A
d. SI-226B

e. SI-227A
f. SI-227B
g. SI-228A
h. SI-228B

LPSI System
Valve Number

a. SI-138A
b. SI-138B
c. SI-139A
d. SI-139B

- h. By performing a flow balance test, during shutdown, following completion of modifications to the ECCS subsystems that alter the subsystem flow characteristics and verifying the following flow characteristics:

HPSI System - Single Pump (Cold leg injection mode)

The sum of the injection lines flow rates, excluding the highest flow rate, is greater than or equal to 675 gpm.

HPSI SYSTEM - Single Pump (Hot/cold leg injection mode)

With the system operating in the hot/cold leg injection mode, the hot leg flow must be greater than or equal to 436 gpm and within $\pm 10\%$ of the cold leg flow.

LPSI System - Single Pump

Flow for each pump is greater than or equal to 4810 with the total developed head greater than or equal to 268 feet but less than or equal to 292 feet.