

Office of Nuclear Reactor Regulation ATTN: Mr. D. B. Vassallo, Chief Operating Reactors Branch No. 2 United States Nuclear Regulatory Commission Washington, D.C. 20555

> BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2 DOCKET NOS. 50-325 AND 50-324 LICENSE NOS. DPR-71 AND DPR-62 WITHDRAWAL OF REQUEST FOR LICENSE AMENDMENT RPIS REED SWITCH OPERABILITY

Dear Mr. Vassallo:

By our letter to you dated April 7. 1982 and our letter to Mr. T. A. Ippolito dated September 25, 1981, Carolina Power & Light Company (CP&L) requested revisions to the Technical Specifications (TS) for the Brunswick Steam Electric Plant, Unit Nos. 1 and 2. The requested revisions primarily concerned changing the requirement for the reportability of inoperable reed switches in the Rod Position Indication System (RPIS) to reduce the number of routine Licensee Event Reports (LERs).

Subsequent to discussions with members of the NRC Staff, CP&L is hereby withdrawing its request for TS revisions for reporting inoperable RPIS reed switches. However, our April 7, 1982 letter also submitted proposed TS revisions for reporting all safety/relief valve (S/RV) challenges as discussed in NUREG-0737 Item II.K.3.3. Carolina Power & Light Company believes this item should be addressed in TS. Therefore, revised TS pages are attached to this letter to supersede those submitted on April 7, 1982. These pages reflect monthly reportability of S/RV challenges. Please continue with your review of this issue.

A044

210260405 821022 PDR ADDCK 05000324

Ille Street . P. O. Box 1551 . Raleigh, N. C. 27602

D. B. Vassallo

Since this letter supplements a previous submittal, CP&L has determined that no additional license amendment application fee is required.

If you have any questions concerning this matter, please contact us.

Yours very truly.

in

L. W. Eur Senior Vice President Power Supply

WRM/mf (4554C1T1) Enclosure

cc: Mr. D. O. Myers (NRC-BSEP) Mr. J. P. O'Reilly (NRC-RII) Mr. J. A. Van Vliet (NRC)

L. W. Eury, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.

Franklin Mer Notary (Seal) una

My commission expires: OCT 04 1986

hummen OTARY UBL COUNTY, H.

- 2 -