

APPENDIX A

NOTICE OF VIOLATION

Entergy Operations, Inc.
Waterford Steam Electric Station, Unit 3

Docket: 50-382
License: NPF-38

During an NRC inspection conducted on March 21-30, 1994, one violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.8.1.a requires, in part, that written procedures shall be established, implemented, and maintained covering the applicable procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978.

Regulatory Guide 1.33, Appendix A, states, in part, that maintenance that can affect the performance of safety-related equipment should be performed in accordance with written procedures appropriate to the circumstances.

Contrary to the above, on March 25, 1994, Mechanical Maintenance Procedure MM-003-041, "Five Year Emergency Diesel Generator Inspection," Revision 0, Section 8.9, was not appropriate to the circumstances, in that it did not provide instructions to clean and lubricate the fuel injector pump mounting fasteners in accordance with specifications provided in Cooper Industries Diesel Generator Technical Manual 457001225.

This is a Severity Level IV violation (382/9407-02) (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Entergy Operations, Inc. is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, 611 Ryan Plaza Drive, Suite 400, Arlington, Texas 76011, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a Demand for Information may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas
this *26th* day of *April* 1994

9405020070 940426
PDR ADDOCK 05000382
G PDR