



EDISON DRIVE  
AUGUSTA, MAINE 04336  
(207) 623-3521

October 21, 1982  
MN-82-208

JHG-82-198

United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation  
Division of Licensing  
Mr. Robert A. Clark, Chief  
Operating Reactors Branch No. 3

References: (a) License No. DPR-36 (Docket No. 50-309)  
(b) MYAPCo Letter to USNRC, dated September 2, 1981, FMY-81-133

Subject: Environmental Qualification of Safety Related Electrical Equipment

Dear Sir:

In Reference (b), we committed to installing isolation valves in the letdown line, steam generator blowdown line and auxiliary steam line during the 1982 refueling outage. These isolation valves would actuate on a high area temperature signal, mitigating a high energy line break in the primary auxiliary building or the containment spray pump building. Since certain vendors will be late in delivering their equipment, we will not be able to complete installation during this outage.

1. We will complete installation and testing on-line, if possible, but in any case, prior to end of the next refueling outage.

We trust this information is satisfactory. However, should you have any questions, please do not hesitate to contact us.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

*John H. Garrity*

John H. Garrity, Senior Director,  
Nuclear Engineering & Licensing

8210260420 821021  
PDR ADOCK 05000309  
P PDR

JHG:pjp

cc: Mr. Ronald C. Haynes  
Mr. Paul A. Swetland  
0045L - JHG

*AOAS*