

## LICENSEE EVENT REPORT

CONTROL BLOCK:   1  1  1  1  1  1  1 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 2 ② 0 0 - 0 0 0 0 | - 0 0 ③ 4 1 1 1 1 ④ ⑤  
7 8 9 LICENSEE CODE 14 15 25 26 LICENSE NUMBER 30 57 CAT 56

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 9 1 9 8 2 8 1 0 1 8 8 2 9  
7 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

**EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)**

[0] 2 | At 0500 on 9/19/82, the "A" train component cooling water system was declared  
[0] 3 | inoperable due to the isolation of service water to the 2C CCW heat exchanger. Tech.  
[0] 4 | Spec. 3.7.3 requires the "A" train CCW system to be operable. Tech. Spec. 3.7.3  
[0] 5 | action statement requirements were met. Health/Safety of the public was not  
[0] 6 | affected.

[9/2]

Q E

(17) LER-RO REPORT NUMBER	EVENT YEAR [8 2] 21 22	SEQUENTIAL REPORT NO. [0 3 9] 23 24 26	OCCURRENCE CODE [0 3] 27 28 29	REPORT TYPE [L] 30 31	REVISION NO. [0] 32			
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS [22] 33 34 35 36 37 38 39 40	ATTACHMENT SUBMITTED [N] 41 42 43	NPRD-4 FORM SUB. [N] 44 45 46 47	PRIME COMP. SUPPLIER [X] 48 49 50 51	COMPONENT MANUFACTURER [X 9 9 9 9] 52 53 54 55 56 57

**CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)**

10 | This incident occurred when the manually operated service water outlet valve from the  
11 | 2C component cooling water heat exchanger failed shut. The pin holding the worm  
12 | drive gear dislodged allowing the D/P across the valve disc to close the valve. The  
13 | pin was re-installed and secured and the valve operation tested satisfactorily. "A"  
| train CCW system was returned to service at 1100 on 9/19/82.

train CCW system was returned to service at 1100 on 9/19/82.

7 8 9 FACILITY  
FACILITY S. POWER OTHER STATUS (30) METHOD OF  
DISCOVERY DISCOVERY DESCRIPTION (32) 80

STATS % POWER OTHER STATUS DISCOVERED  
1 5 E (28) 1 0 0 (29) NA A (31) Operation Observation

ACTIVITY CONTENT  
RELEASED OF RELEASE

1	6	Z	(33)	Z	(34)
---	---	---	------	---	------

AMOUNT OF ACTIVITY (35) NA

LOCATION OF RELEASE (36) NA

7 8 9 10 11 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
PERSONNEL EXPOSURES  
NUMBER TYPE DESCRIPTION (39) NA

1 7 9 0 0 0 37 4 38 NA 7 8 11 12 13 PERSONNEL INJURIES 60

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41

7 E 9 11 12  
LOLS OF OR DAMAGE TO FACILITY 43  
TYPE DESCRIPTION

1 9 2 42 DESCRIPTION NA  
7 8 9 10 8210260480 821018  
PDR ADDCK 05000348  
5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
PUBLICITY NBC USE ONLY

ISSUED DESCRIPTION 45 S NA PDR