

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A B V S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

CON'T
01 REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 0 6 1 9 8 2 3 1 0 1 4 8 2 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | During normal operation diesel generator #2 was started for the perform-
03 | ance of OST 1.36.2. The diesel was loaded to full load and run for 1 hour
04 | as per the OST. The diesel engine cooling water inlet and outlet tempera-
05 | tures both exceeded maximum allowable values. Therefore, diesel generat-
06 | or #2 was declared inoperable for corrective maintenance. There were no
07 | safety implications due to the operability of diesel generator #1, and
08 | offsite power.

09 SYSTEM CODE EE (11) CAUSE CODE E (12) CAUSE SUBCODE X (13) COMPONENT CODE ENGINE (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)
17 LER/RC REPORT NUMBER 82 (17) EVENT YEAR 82 (21) SEQUENTIAL REPORT NO. 036 (26) OCCURRENCE CODE 03 (28) REPORT TYPE L (30) REVISION NO. 0 (32)
ACTION TAKEN X (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED N (23) NPRO-4 FORM SUB. N (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER G100 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | The cause of the elevated engine cooling water temperatures was due to
11 | fouling of the cooling water Heat Exchanger tubes. The tubes were
12 | cleaned, and diesel generator #2 was returned to service on
13 | (9/21/82). Also, to prevent recurrence of this incident, the
14 | tubes for diesel generator #1 were cleaned on (9/20/82).

15 FACILITY STATUS E (28) % POWER 090 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION Performing Surveillance Test (32)

16 ACTIVITY CONTENT RELEASED OF RELEASE Z (33) Z (34) AMOUNT OF ACTIVITY N/A (35) LOCATION OF RELEASE N/A (36)

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION N/A (39)

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION N/A (41)

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION N/A (43)

20 PUBLICITY ISSUED N (44) DESCRIPTION N/A (45)

8210260487 821014
PDR ADOCK 05000334
S PDR

NRC USE ONLY

NAME OF PREPARER W. S. Lacey PHONE 412-643-8525

Attachment To LER 82-036/03L
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.