

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 2 ② 0 0 - 0 0 0 0 - 0 0 ③ 4 1 1 1 1 ④ ⑤
2 10 0 LICENSE PLATE NO. 14 26 1 LICENSE PLATE NO. 30 31 CAT 59

CONT

CONT
01 REPORT SOURCE 65 0 5 0 0 0 3 6 4 70 0 9 1 9 8 2 80 1 0 1 8 8 2 90
Z-8 EXCERPT FROM PAGE 18 66 60 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

[0 2] At 1339 on 9/19/82, while performing FNP-2-STP-80.16 (Degraded Grid Voltage/Loss
[0 3] of Voltage Protection Relay Tests), it was determined that the loss of voltage
[0 4] protection channel associated with the B2F sequencer phase 2-3 was inoperable. Tech.
[0 5] Spec. 3.3.2.1, in part, requires this channel to be operable. Tech. Spec 3.3.2.1
[0 6] action statement requirements were met. Health/Safety of the public was not affected.

CODE S-1 HI CODE 151 SUBCODE 151 COMPONENT CODE 151 SUBCODE 151 SUBCODE 151

SYSTEM CODE S | H | (11) CAUSE CODE E | (12) CAUSE SUBCODE A | (13) IR | E | L | A | Y | X | (14) COMP. SUBCODE E | (15) VALVE SUBCODE Z | (16)

7 B 9 10 11 12 13 18 19 20
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

17 EEM NO.
REPORT
NUMBER

EVENT NUMBER

82

21 22

23

24 25 26

27

28 29

30

31

32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRPD-4 FORM SUB. PRIME CCRP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (2)

This event was caused by the failure of the loss of voltage relay (27XF1) to operate

111 | during testing. The relay was cleaned and following satisfactory completion of

1 2 | FNP-2-STP-80.16, the loss of voltage protection channel was returned to service at [redacted]

1 3 | 1540 on 9/19/82.

1 4
7 8 9

FACILITY STATUS 11-10-10-100% POWER OTHER STATUS NA (30) METHOD OF DISCOVERY L-B (31) DISCOVERY DESCRIPTION (32) Surveillance Test

ACTIVITY CONTENT

RELEASED OF RELEASE AMOUNT OF ACTIVITY
1 6 Z (33) Z (34) NA

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)

1 7 0 0 0 (3) Z (3B) NA
7 8 9 11 12 13 PERSONNEL INJURIES

NUMBER 0 0 0 (40) DESCRIPTION (41) NA

1 9 Z (42) NA B210260490 B21018

ISSUED BY **PDR ADDOCK 05000348**
DESCRIPTION **S** PDR
Z 44

NAME OF PREPARED W. G. Hairston, III

PHONE (205) 899-5156