

PROPOSED TECHNICAL SPECIFICATION CHANGES

9012170099 901211
PDR ADOCK 05000368
PDR

ARKANSAS - UNIT 2 3/4 3-40 Amendment No. 7, 13 20, 62

TABLE 3.3-10

POST-ACCIDENT MONITORING INSTRUMENTATION

INSTRUMENT	MINIMUM CHANNELS OPERABLE
1. Containment Pressure (Normal Design Range)	2
2. Containment Pressure (High Range)*	2
3. Pressurizer Pressure	2
4. Pressurizer Water Level	2
5. Steam Generator Pressure	2/steam generator
6. Steam Generator Water Level	2/steam generator
7. Refueling Water Tank Water Level	2
8. Containment Water Level - Wide Range*	2
9. Emergency Feedwater Flow Rate	1/steam generator
10. Reactor Coolant System Subcooling Margin Monitor	1
11. Pressurizer Safety Valve Acoustic Position Indication	1/Valve
12. Pressurizer Safety Valve Tail Pipe Temperature	1/Valve

*If only one channel is inoperable and containment entry is required to restore the inoperable channel, the channel need not be restored until the following refueling outage.