

# ILLINOIS POWER

CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

U-601765  
L30-90(12-13)LP  
8G.120

J. STEPHEN PERRY, *Vice President*  
(217) 935-6226

JSP-0958-90  
December 13, 1990

Docket No. 50-461

Document Control Desk  
Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Clinton Power Station  
Response to Generic Letter 89-10, Supplement 3:  
Consideration of the Results of the NRC -  
Sponsored Tests of Motor-Operated Valves (MOV)

Dear Sir:

On November 9, 1990, Illinois Power Company received Generic Letter 89-10, Supplement 3. Clinton Power Station (CPS) was requested in the Generic Letter to perform a plant-specific safety assessment (item 1 of Supplement 3, Reporting Requirements) to verify that the generic safety assessments performed by the NRC Staff and the Boiling Water Reactor Owners' Group are applicable to Clinton Power Station. The assessment for the Reactor Water Cleanup (RWCU) and Reactor Core Isolation Cooling (RCIC) system isolation valves has been completed. The assessment is available for review, and can be obtained from F. A. Spangenberg at extension 3400. CPS does not have a High Pressure Core Injection (HPCI) system or an isolation condenser.

CPS was also requested to notify the NRC staff of any MOVs with deficiencies of greater safety significance than the MOVs used to provide containment isolation in the steam supply lines of the RCIC and RWCU systems. At CPS, no known MOVs with deficiencies of this type exist.

I hereby affirm that the information in this letter is correct to the best of my knowledge.

Sincerely yours,



J. S. Perry  
Vice President

WTD/ah

cc: NRC Clinton Licensing Project Manager  
NRC Resident Office  
NRC Region III, Regional Administrator  
Illinois Department of Nuclear Safety

9012170178 901213  
PDR ADOCK 05000461  
P PDR

A064  
'10