

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | **M E M Y P I** | 2 | 00-000000000000 | 341111 | 4 | | | 5

LICENSEE CODE 7 8 9 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58 80

CON'T

01 | **L** | 6 | 05000309 | 7 | 050981 | 8 | 0512681 | 9

REPORT SOURCE 60 61 SOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | During plant refueling while performing routine surveillance on FAST level switch

03 | interlocks, technician discovered that one of the three RAS actuation switches failed

04 | to close. All other components of the RAS actuation matrix were tested satisfactorily.

05 | Therefore, the only consequence of the faulty switch was a reduction in the degree of

06 | redundancy. Since the remaining two actuation switches were operable, the minimum

07 | degree of redundancy was maintained and there was no effect on the public health or

08 | safety.

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP SUBCODE	VALVE SUBCODE					
	I	E	B	I	N	S	Z				
	9	11	12	13	18	19	20				

1 7	LER RO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.		
	8	1	0	5	/	0	3	L
	21	22	23	24	25	26	27	28

1 8	ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRDA FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
	C	Z	Z	Z	0	0	0	0	N
	33	34	35	36	37	38	39	40	41

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | The probable cause of switch failure was material incompatibility. Switch was

11 | replaced with an improved model utilizing stainless steel in place of brass.

12 | _____

13 | _____

14 | _____

1 5	FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
	H	0	0	B	Routine Surveillance
	7	10	13	44	45

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
	Z	Z	NA	NA
	7	9	11	44

1 7	PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION
	0	0	Z
	7	10	13

1 8	PERSONNEL INJURIES NUMBER	DESCRIPTION
	0	0
	7	10

1 9	LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION
	Z	
	7	10

2 0	PUBLICITY ISSUED	DESCRIPTION	NRC USE ONLY
	Z		
	7	10	22