Docket No. 50-461

Illinois Power Company ATTN: J. S. Perry Vice President Clinton Power Station Mail Code V-275 P. D. Box 678 Clinton, IL 61727

Gentlemen:

On November 21, 1990, we received Advance Change Notice (ACN) 9/1 to the Clinton Power Station's Emergency Plan. We have reviewed ACN 9/1 and we have determined that it is acceptable and does not degrade the effectiveness of the Emergency Plan.

ACN 9/1 includes several clarifications, information updates, and enhancements to the emergency planning in place for the Clinton Power Station. Minor revisions have been made to the Station Emergency Response Organization (SERO). Clarification has been made regarding the activation of the SERO and the Emergency Support Organization. An improved back-up locat on for the Operations Support Center has been specified. Improvements have been made to the wording of the criteria for classifying an Unusual Event or Alert for abnormal liquid or gaseous radiological releases. Updated information has been provided on the matthds available for communicating with offsite medical facilities.

Should you have any questions, please have your staff contact Mr. T. Ploski of my staff at (708) 790-5634.

Sincerely,

Robert Greger, Chief Reactor Programs Branch

See Attached Distribution

Ploski/cs 12/6/90 Snevi

RIII RIII Lanksbury Weger

ZE IT

9012180034 901206 PDR ADBCK 05000461

Distribution

cc: J. Cook, Manager, Clinton Power Station F. Spangenberg, III, Manager -Licensing and Safety DCD/DCB (RIDS) OC/LFDCB Resident Inspector, RIII J. Hickman, NRR, PM J. McCaffrey, Chief, Public Utilities Division Patricia O'Brien, Governor's Office of Consumer Services S. Zabel, Esquire, Schiff, Hardin, & Waite L. Larson, Project Manager, General Electric Company Chairman, DeWitt County Board Illinois Department of Nuclear Safety Robert Newmann, Office of Public Counsel, State of Illinois Center Perry SRI R. LaFreniere, RIII R. Erickson, EPB, NRR D. Bement, FEMA, RV