

Distribution:
 ✓ Document Control 50-508
 NRC PDR
 L PDR
 NSIC
 PRC System

OCT 8 1982

Docket No.: 50-508

Mr. R. L. Ferguson
 Managing Director
 Washington Public Power Supply System
 P. O. Box 968
 3000 George Washington Way
 Richland, Washington 99352

LB#3 File
 JKerrigan
 LWheeler
 JLee
 DSwanson, OELD
 EJordan, IE
 Taylor, IE

Dear Mr. Ferguson:

Subject: Formal NRC Approval of ASME Code Case N-249-2

Reference: Letter, G03-82-963, G. D. Bouchey to F. J. Miraglia, dated September 21, 1982, subject as above.

The referenced letter requested NRC approval of ASME Code Case N-249-2 for use at the WNP-3 project.

The NRC approves the use of ASME Code Case N-249-2 at the WNP-3 project. The scope of this approval is limited to the use of this Code Case for strap and rivet materials in the ITT-Grinnel Figures 215 Stiff Clamps.

Sincerely,

Original signed by:

Janis D. Kerrigan, Acting Chief
 Licensing Branch No. 3
 Division of Licensing

cc: See next page

8210280416 821008
 PDR ADOCK 05000508

OFFICE	DL:LB#3	JKerrigan					
SURNAME	DWheeler:ph	JKerrigan					
DATE	10/8/82	10/8/82					

Mr. R. L. Ferguson
Managing Director
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99352

cc: Nicholas S. Reynolds, Esq.
DeBevoise & Liberman
1200 Seventeenth St., NW
Washington, DC 20036

Richard Q. Quigley, Esq.
Washington Public Power Supply System
3000 George Washington Way
Richland, Washington 99352

Nicholas D. Lewis, Chairman
Energy Facility Site Evaluation Council
820 East Fifth Avenue
Olympia, Washington 98505

Mr. Kenneth W. Cook
Washington Public Power Supply System
P. O. Box 1223
Elma, Washington 98541

Resident Inspector/WPPSS 3/5
c/o U.S. Nuclear Regulatory Commission
P. O. Box 545
Elma, Washington 98541

Regional Administrator - Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane
Suite 210
Walnut Creek, California 94596

Mr. Thomas W. Bishop
Washington Public Power Supply (WNP-3/5)
P. O. Box 1156
Olympia, Washington 98507