

EMERGENCY PLAN IMPLEMENTING PROCEDURES
INDEX

<u>NUMBER</u>	<u>TITLE</u>	<u>DATE</u>
099-1	Reference Procedures	12-15-81
110-1	Station Director EPIP	SEP 16 1982
120-1	Operations Director EPIP	6-15-82
130-1	Technical Director EPIP	6-15-82
140-1	Maintenance Director EPIP	6-15-82
150-1	Stores Director EPIP	SEP 16 1982
160-1	Administrative Director EPIP	11-10-81
170-1	Security Director EPIP	11-10-81
180-1	Rad/Chem Director EPIP	12-15-81
190-1	Communications Director EPIP	12-15-81
320-1	Activation of the GSEP Station Group	6-22-82
330-1	Classification of GSEP Conditions	8-31-82
330-4	Classification of an Incident involving Hazardous Material	2-18-81
350-1	Quick Estimate of Offsite Dose from an Unplanned Release	5-21-81
360-1	Site Evacuation of Non-essential Personnel	1-18-82
360-2	Assembly Procedure	8-12-81
360-3	Monitoring High Activity Releases During Accident Conditions	12-15-81
360-4	Radioiodine Sampling Under Accident Conditions	12-15-81
360-5	Operation of the Eberline SAM-2	12-15-81
370-1	Rescue and Recovery	12-15-81

8210280427 8210~Zi 12
FOR ADOCK 05000295
F PDR

0039E
0006A

APPROVED *X.L. Hansen*
DATE 9-16-82

STATION DIRECTOR
EPIP 110-1
TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>	<u>DATE</u>	<u>REVISION</u>
	Table of Contents	1	SEP 16 1982	5
A	Purpose	2	SEP 16 1982	2
B	References			
C	Prerequisites			
D	Precautions			
E	Limitations & Actions			
F	Procedure	3	6-15-82	3
G	Checklists			
H	Technical Specification References			
	Table 1 - Action And Notification	4	SEP 16 1982	2
		5	SEP 16 1982	2
	State of Illinois Nuclear Accident Report Form	6	11-10-81	2
		7	4-30-81	1
		8	11-10-81	2
		9	11-10-81	1
	Table 6.3-1	10	6-15-82	0
	Table 6.3-2	11	6-15-82	0
	Table 6.3-3	12	6-15-82	0

This procedure contains 12 pages.

0032E
0006A

1

APPROVED <i>H. P. Hansen</i>
DATE <u>9-16-82</u>

STATION DIRECTOR

A. PURPOSE

The purpose of this procedure is to list the Station Director's responsibilities during a GSEP emergency.

B. REFERENCES

1. EPIP 170-1 Security Director
2. EPIP 180-1 Rad/Chem Director
3. EPIP 320-1 Activation of GSEP Station Group
4. EPIP 330-1 Classification of GSEP Conditions
5. EPIP 330-2 Environs Procedure
6. EPIP 350-1 Quick Estimate of Off-Site Dose
7. EPIP 360-1 Site Evacuation of Non-Essential Personnel
8. EPIP 360-2 Assembly Procedure
9. EPIP 700-1 Emergency Phone List
10. Attachment 1 Spill Prevention Control and Countermeasure Plan (SPCC)
11. Illinois Public Act 79-1442
12. EPIP 440-1 Emergency Communications Systems and Operational Tests

C. PREREQUISITES

None

D. PRECAUTIONS

1. The position of the Station Director will be established as follows: The Station Superintendent or his alternate normally acts as the Station Director. In the absence of the Superintendent or his alternate, the Shift Engineer becomes the acting Station Director until relieved by the Superintendent or his alternate. If the Shift Engineer is incapacitated, then the directorship passes to the Shift Foreman, or in his absence, to the senior NSO until relieved by the Superintendent or his alternate.
2. a) The acting Station Director (Shift Engineer) normally works out of the Shift Engineer's office or the Control Room.
b) The Station Director normally works out of the TSC.

E. LIMITATIONS & ACTIONS

1. The following abbreviations are used in TABLE 1.
 - a) TA = Transportation Accident
 - b) UA = Unusual Event
 - c) A = Alert
 - d) SE = Site Emergency
 - e) GE = General Emergency
 - f) SPCC = Spill Prevention Controls And Countermeasure
 - g) PA = Illinois Public Act 79-1442

TABLE 1
 ACTION AND NOTIFICATION

TIME	TA	UA	A	SE	GE	SPCC	PA
Notify Superintendent	X	X	X	X	X	-	-
Notify Operating Engineer on duty	X	X	X	X	X	-	-
Notify System Power Load Dispatcher	X	X	X	X	X	-	-
Notify The NRC Red Phone or 301-492-8111	X	X	X	X	X	-	-
Notify NAWAS	X	X	X	X	X	-	-
Notify NARS Network	-	-	-	-	X	-	-
Activate GSEP Station Group (See EPIP 320-1)	X	X	X	X	X	-	-
Notify Rad Protection (241) to determine habitability of the station (See EPIP 180-1)	-	-	X	X	X	-	-
Activate TSC and OSC	-	-	X	X	X	-	-
Activate EOF (Call Westinghouse)	-	-	*	X	X	-	-
Sound Emergency Siren (2 minute blast)	-	*	*	X	X	-	-
Assemble/Account for personnel (See EPIP 360-2)	-	*	*	X	X	-	-
Consult with Rad/Chem Director to determine the need for a site evacuation (See EPIP 360-1)	-	*	*	X	X	-	-
Make a quick estimate of off-site dose and recommend protective action (See EPIP 350-1)	-	-	X1	X1	X1	-	-
Dispatch personnel for radiological evaluation of the accident	X1	-	-	-	-	-	-
Dispatch personnel for environs monitoring (See EPIP 330-2)	-	-	-	X1	X1	-	-
Inform watch commander of emergency and maintain plant security (See EPIP 170-1)	X	X	X	X	X	-	-
Notify local support groups as necessary:							
a) Illinois State Police	*	*	*	*	*	-	-
b) Lake County Sheriff	*	*	*	*	*	-	-

TABLE 1

ACTION AND NOTIFICATION

TIME	TA	UA	A	SE	GE	SPCC	PA
c) Zion Police Dept	*	*	*	*	*	-	-
d) Ambulance - Zion Rescue Dept Safe-Way	*	*	*	*	*	-	-
e) Victory Memorial Hospital	*	*	*	*	*	-	-
f) Lake County ESDA	*	*	*	*	*	-	-
g) Waukegan ESDA	*	*	*	*	*	-	-
Notify local support groups as necessary: (Cont)							
h) Zion ESDA	*	*	*	*	*	-	X
i) Springfield, IL ESDA (NARS-dial)	*	*	*	*	*	-	-
j) Wisc Div of Emergency Gov't	*	*	*	*	X	-	-
k) US Coast Guard	*	*	*	*	*	X	X
l) Div Mgr-Nuclear	*	*	*	*	*	X	X
m) Director Water Quality	*	*	*	*	*	X	X
n) See EPIP 700-1 for additional information	*	*	*	*	*	-	-
Keep a record of GSEP related events	X	X	X	X	X	X	X

KEY

- (-) = Not Required
- (X) = Required Action
- (*) = At the Discretion of the Station Director
- (l) = If Applicable