

MISSISSIPPI POWER & LIGHT COMPANY Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 23, 1982

JAMES P. McGAUGHY, JR. ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Region II 101 Marietta St., N.W., Suite 3100 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station. Unit 1 Docket No. 50-416 License No. NPF-13 File 0260/L-835.0

> Improper Operator Log Keeping and Plant Awareness Reference: LER 82-074/03 L-0

450

. .

AECM-82/502

Initial fuel load requires 2 ECCS systems be operational. On September 23, 1982, it was discovered that only one system was actually operational. This situation was not reported in a timely manner due to improper log keeping. Attached is LER 82-074/03 L-0.

JPM: sap Attachment

cc: Mr. N. L. Stampley (w/a)

Mr. R. B. McGehee (w/o)

Mr. T. B. Conner (w/o)

Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a) Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Document Control Desk (w/a) U. S. Nuclear Regulatory Commission Washington, D. C. 20555

8210290050 821023 PDR ADDCK 05000416