



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

December 10, 1990


Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

ATTN: Document Control Desk

Gentlemen:

Enclosed for your information is the monthly performance report covering LaSalle County Nuclear Power Station for November, 1990.

Very truly yours,


for G. J. Diederich
Station Manager
LaSalle County Station

GJD/MJC/djf

Enclosure

xc: A. B. Davis, NRC, Region III
NRC Resident Inspector LaSalle
Ill. Dept. of Nuclear Safety
R. Pulsifer, NRR Project Manager
D. P. Galle, CECO
D. L. Farrar, CECO
INPO Records Center
D. R. Eggett, NED
J. E. Kuskey, GE Resident
T. J. Kovach, Manager of Nuclear Licensing
W. F. Naughton, Nuclear Fuel Services Manager
C. F. Dillon, Senior Financial Coordinator, LaSalle
T. R. Novotney, INPO Coordinator, LaSalle Station
T. A. Hammerich, Regulatory Assurance Supervisor
J. W. Gieseke, Technical Staff Supervisor
Station File

9012180214 901130
PDR ADOCK 05000373
R PDR

ZCADTS/5

180017

IE24

LASALLE NUCLEAR POWER STATION

UNIT 1

MONTHLY PERFORMANCE REPORT

NOVEMBER 1990

COMMONWEALTH EDISON COMPANY

NRC DOCKET NO. 050-373

LICENSE NO. NPF-11

TABLE OF CONTENTS
(UNIT 1)

I. INTRODUCTION

II. REPORT

- A. SUMMARY OF OPERATING EXPERIENCE
- B. PLANT OR PROCEDURE CHANGES, TESTS, EXPERIMENTS, AND SAFETY RELATED MAINTENANCE (50.59)
 - 1. Amendments to Facility License or Technical Specifications
 - 2. Changes to procedures which are described in the Safety Analysis Report
 - 3. Changes to facility which are described in the Safety Analysis Report.
 - 4. Tests and Experiments not covered in the Safety Analysis Report
- C. MAJOR CORRECTIVE MAINTENANCE TO SAFETY-RELATED EQUIPMENT
- D. COMPLETED SAFETY-RELATED MODIFICATIONS
- E. LICENSEE EVENT REPORTS
- F. DATA TABULATIONS
 - 1. Operating Data Report
 - 2. Average Daily Unit Power Level
 - 3. Unit Shutdowns and Power Reductions
- G. UNIQUE REPORTING REQUIREMENTS
 - 1. Main Steam Relief Valve Operations
 - 2. ECCS System Outages
 - 3. Off-Site Dose Calculation Manual Changes
 - 4. Major Changes to Radioactive Waste Treatment System
 - 5. Indications of Failed Fuel Elements

I. INTRODUCTION (Unit 1)

The LaSalle County Nuclear Power Station is a two-unit facility owned by Commonwealth Edison Company and located near Marseilles, Illinois. Each unit is a Boiling Water Reactor with a designed net electrical output of 1078 Megawatts. Waste heat is rejected to a man-made cooling pond using the Illinois River for make-up and blowdown. The architect-engineer was Sargent and Lundy and the primary construction contractor was Commonwealth Edison Company.

Unit One was issued operating license number NPF-11 on April 17, 1982. Initial criticality was achieved on June 21, 1982 and commercial power operation was commenced on January 1, 1984.

This report was compiled by Michael J. Cialkowski, telephone number (815)357-6761, extension 2427.

II. MONTHLY REPORT

A. SUMMARY OF OPERATING EXPERIENCE (Unit 1)

Day	Time	Event
1	0000	Reactor critical, generator on-line at 1120 MWE
4	2330	Reduced power to 1080 MWE for system load.
5	1000	Increased power to 1120 MWE.
	2230	Reduced power to 1080 MWE for CRD exercising.
6	0600	Increased power to 1120 MWE.
13	0100	Reduced power to 850 MWE for monthly surveillances.
	1000	Increased power to 1120 MWE.
14	0130	Reduced power to 740 MWE for scram time testing, rod set and strong back removal.
	1300	Increased power to 1120 MWE.
19	0130	Reduced power to 1050 MWE for condensate pump transfer.
	0800	Increased power to 1120 MWE.
20	0200	Reduced power to 850 MWE for system load and for CRD exercising.
	1000	Increased power to 1120 MWE.
	2400	Reduced power to 850 MWE for system load.
21	1100	Increased power to 1120 MWE.
22	0200	Reduced power to 850 MWE for system load.
23	2000	Increased power to 1120 MWE.
26	2300	Reduced power to 1000 MWE for system load.
27	1000	Increased power to 1120 MWE.
28	0300	Reduced power to 900 MWE for system load.
	1300	Increased power to 1120 MWE.
29	1100	Reduced power to 800 MWE due to Division 1 battery charger problems.
	2100	Increased power to 1000 MWE.
30	1700	Increased power to 1120 MWE.
	2400	Reactor critical, generator on-line at 960 MWE reducing power to 750 MWE for CRD problem.

B. PLANT OR PROCEDURE CHANGES, TESTS, OR EXPERIMENTS (50.59) (Unit 1)

1. Amendments to the Facility License or Technical Specification.
(None)
 2. Changes to procedures which are described in the Safety Analysis Report.
 - a) LaSalle Operating Procedure LOP-WF-30, "Transfer of Floor Drain Process System Tank Water to Equipment Drain and Waste Collector (WE) Tank (1WE03T)" was used to transfer evaporator head tank water to the liquid radwaste sample tank to make use of the 30,000 gallon volume of 1WE03T to hold water, while WE filter gasket repairs were underway. The safety function of radwaste is to limit radioactive concentrations released to the environment. Prior to going to the head tank, the water would have been processed through an evaporator. After getting to WE, it will be sampled and routed accordingly. The Safety Evaluation concluded that radwaste is not the basis for any Technical Specification margin of safety and the radioactive effluent dose limits of Technical Specification 3/4.11.2.3 still remain valid.
 - b) LaSalle Special Procedure LLP-90-075, "Auxiliary Building HVAC (VA) Purge", was performed to allow the purge of the Auxiliary Building office areas without endangering the required differential pressure criteria of the control room envelope. This change allowed cool outside air into the office spaces while the HVAC compressor is being repaired. The Safety Evaluation prepared for this test stated that the VA system is non-safety and its failure doesn't affect any safety systems. VA normally uses outside air for makeup.
 3. Changes to facility which are described in the Safety Analysis Report.
 - a) LaSalle Temporary System Change (TSC) 1-766-90 was performed to defeat Drywell Drain Sump fill up rate alarm, due to having a faulty transmitter on its flow element, which was causing a nuisance alarm. The unidentified leakage totalizer will remain operable for sump monitoring and identified leakage technical specifications will not be affected. The safety evaluation concluded that the alarm circuit is non-safety and does not affect the consequences of an accident.
 4. Tests and Experiments not described in the Safety Analysis Report.
(None)
- C. MAJOR CORRECTIVE MAINTENANCE TO SAFETY-RELATED EQUIPMENT (including SOR differential pressure switch failure reports).
(See Table 1)
- D. COMPLETED SAFETY-RELATED MODIFICATIONS.
(None)

C TABLE 1 (Unit 1)

MAJOR CORRECTIVE MAINTENANCE TO
SAFETY-RELATED EQUIPMENT

WORK REQUEST NUMBER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS AND EFFECTS ON SAFE PLANT OPERATION	CORRECTIVE ACTION
L03574	1VY04C	74 Relay	None	Replaced 74 relay
L03582	1A Main Steam Line Radiation Monitor	Control Module	None	Replaced control module
L03601	APRM "F"	Power Supply	Improper voltage to APRM	Replaced power supply
L03662	Division 1 Post LOCA Oxygen Monitor	Regulator, cell	Erratic oxygen samples	Replaced regulator, cell, amplifier board
L03924	Control Rod Number 5C 47	Pilot solenoid valves	None	Replaced pilot solenoid valves

(No SOR failures this month)

E. LICENSEE EVENT REPORTS (Unit 1)

<u>LER Number</u>	<u>Date</u>	<u>Description</u>
-------------------	-------------	--------------------

(NONE)

F. DATA TABULATIONS (Unit 1)

1. Operating Data Report (See Table 3)
2. Average Daily Unit Power Level (See Table 4)
3. Unit Shutdowns and Significant Power Reductions (See Table 5)

TABLE 5

F.3 UNIT SHUTDOWNS AND POWER REDUCTIONS > 20%
(Unit 1)

YEARLY SEQUENTIAL DATE NUMBER	(YYMMDD)	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER	CORRECTIVE ACTIONS/COMMENTS (LER/DVR # if applicable)
(None)						

SUMMARY OF OPERATION:

The Unit remained on line at high power throughout the month. Several minor power reductions were required due to low grid demand, routine surveillances, Division 1 Battery Charger and CRD problems.

G. UNIQUE REPORTING REQUIREMENTS (Unit 1)

1. Safety/Relief valve operations

<u>DATE</u>	<u>VALVES</u> <u>ACTUATED</u>	<u>NO.</u> <u>OF</u> <u>ACTIVATION</u>	<u>TYPE</u> <u>OF</u> <u>PLANT</u> <u>CONDITION</u>	<u>DESCRIPTION</u> <u>OF</u> <u>EVENT</u>
-------------	----------------------------------	--	--	---

(None)

2. BCCS System Outages
(See Table 6)

3. Changes to the Off-Site Dose Calculation Manual
(None)

4. Major changes to Radioactive Waste Treatment Systems.
(None)

5. Indications of Failed Fuel Elements.
(None)

G.2 ECCS System Outages

Note: The year and unit data has been removed from the outage number.

<u>OUTAGE NO.</u>	<u>EQUIPMENT</u>	<u>PURPOSE</u>
(U-0)		
377	ODG01K	Lubrication
(U-1)		
601	1E12-C300C 1E12-C300D	Lubricate pump coupling
603	1E12-F093	Administrative
606	1E12-F026A	Perform Surveillance LES-EQ-112
608	1DG035	Perform Surveillance LES-EQ-112
609	1E12-F026A	Valve inspection
614	1E21-C001	Change oil
616	1DG035	Valve inspection
617	1E21-C001	Megger Motor
618	1E21-C001	Perform LES-GM-129
623	1DG035	Valve inspection
625	1E12-F026A	Valve inspection
632	1E12-C300B	Perform LES-GM-105
642	1E51-C004 1E51-C005	Perform LES-DC-104
643	1E51-C003	Lubricate coupling
644	1E51-F360	Remove turbine governor
860	1E22-D300	Strainer inspection

LASALLE NUCLEAR POWER STATION

UNIT 2

MONTHLY PERFORMANCE REPORT

NOVEMBER 1990

COMMONWEALTH EDISON COMPANY

NRC DOCKET NO. 050-374

LICENSE NO. NPF-18

TABLE OF CONTENTS
(Unit 2)

I. INTRODUCTION

II. REPORT

- A. SUMMARY OF OPERATING EXPERIENCE
- B. PLANT OR PROCEDURE CHANGES, TESTS, EXPERIMENTS, AND SAFETY RELATED MAINTENANCE (50.59)
 - 1. Amendments to Facility License or Technical Specifications
 - 2. Changes to procedures which are described in the Safety Analysis Report.
 - 3. Changes to facility which are described in the Safety Analysis Report.
 - 4. Tests and Experiments not covered in the Safety Analysis Report.
- C. MAJOR CORRECTIVE MAINTENANCE TO SAFETY-RELATED EQUIPMENT
- D. COMPLETED SAFETY-RELATED MODIFICATIONS
- E. LICENSEE EVENT REPORTS
- F. DATA TABULATIONS
 - 1. Operating Data Report
 - 2. Average Daily Unit Power Level
 - 3. Unit Shutdowns and Power Reductions
- G. UNIQUE REPORTING REQUIREMENTS
 - 1. Safety/Relief Valve Operations
 - 2. ECCS System Outages
 - 3. Off-Site Dose Calculation Manual Changes
 - 4. Major Changes to Radioactive Waste Treatment System
 - 5. Indications of Failed Fuel Elements

I. INTRODUCTION (Unit 2)

The LaSalle County Nuclear Power Station is a two-unit facility owned by Commonwealth Edison Company and located near Marseilles, Illinois. Each unit is a Boiling Water Reactor with a designed net electrical output of 1078 Megawatts. Waste heat is rejected to a man-made cooling pond using the Illinois River for make-up and blowdown. The architect-engineer was Sargent and Lundy and the primary construction contractor was Commonwealth Edison Company.

Unit Two was issued operating license number NPF-18 on December 16, 1983. Initial criticality was achieved on March 10, 1984 and commercial power operation was commenced on June 19, 1984.

This report was compiled by Michael J. Cialkowski, telephone number (815)357-6761 extension 2427.

II. MONTHLY REPORT

A. SUMMARY OF OPERATING EXPERIENCE (Unit 2)

Day	Time	Event
1	0000	Reactor critical, generator on-line at 1130 MWE
4	0100	Reduced power to 850 MWE for heater bay work
	1600	Increased power to 1130 MWE
13	0200	Reduced power to 1070 MWE for condensate booster pump alignment
	0800	Increased power to 1130 MWE.
17	0100	Reduced load to 820 MWE for feedwater pump work and rod set.
	0330	Increased power to 980 MWE (holding power level due to feedwater pump problems)
18	1600	Increased power to 1130 MWE
21	0030	Reduced power to 1050 MWE for CRD exercising
	1300	Increased power to 1130 MWE
28	0130	Reduced power to 950 MWE for monthly surveillances
	1100	Increased power to 1130 MWE
30	2400	Reactor critical, generator on-line at 1130 MWE

- B. PLANT OR PROCEDURE CHANGES, TESTS OR EXPERIMENTS (50.59) (Unit 2)
1. Amendments to the Facility License or Technical Specification.
(None)
 2. Changes to procedures which are described in the Safety Analysis Report.

(None.)
 3. Changes to facility which are described in the Safety Analysis Report.
(None)
 4. Tests and experiments not described in the Safety Analysis Report.
(None)
- C. MAJOR CORRECTIVE MAINTENANCE TO SAFETY RELATED EQUIPMENT (including SOR differential pressure switch failure reports).
(See Table 1)
- D. COMPLETED SAFETY RELATED MODIFICATIONS.
(None)
- E. LICENSEE EVENT REPORTS (Unit 2)
(None)
- F. DATA TABULATIONS (Unit 2)
1. Operating Data Report.
(See Table 3)
 2. Average Daily Unit Power Level.
(See Table 4)
 3. Unit Shutdowns and Significant Power Reductions.
(See Table 5)

C TABLE 1 (Unit 2)

MAJOR CORRECTIVE MAINTENANCE TO
SAFETY-RELATED EQUIPMENT

WORK REQUEST NUMBER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS AND EFFECTS ON SAFE PLANT OPERATION	CORRECTIVE ACTION
L00694	CRD HCU Accumulator	Pressure switch	Inaccurate accumulator pressure readings	Replaced pressure switch
L03897	Div. 1 125V Battery Charger	Firing board	Power reduction per Tech Spec	Replace firing board
L91250	RCIC Baro Vacuum Pump	Pump motor space heater	Motor oil improper temperature	Replaced space heater

(See attached SOR failure report)

SOR dp Switch Failure Data Sheet

Equipment Piece Number: 2E12-N010BA Model Number: 103-AS-B202-NX-JJTTX6

Serial Number: 85-6-3587R

Application: Residual Heat Removal Minimum Flow Switch

Date and Time of Discovery: 10/25/90 1430 hours

Reactor Mode: Run Power Level: 100%

Calibration Tolerance: 23.6-22.4"WC

Nominal Setpoint: 23.0"WC

Action Limits: <24.7 or >21.3"WC

Reject Limits: <17.7 or >28.3"WC

Technical Specification

Limit: 5.90"WC

As Found Setpoint: "WC

Date and Time of Return to Service: 10/26/90 0450 hours

Model Number of Replacement Switch: 103AS-B202-NX-JJTTX6

Serial Number of Replacement Switch: 89-2-3874

DVR Number: 01-2-90-072

Cause: During routine calibration, pressure differential switch 2E12-N010BA setpoint was found to be erratic and not repeatable. During inspection of the switch, slight corrosion was found on the bearing and shaft. The cause of the failure was determined to be due to corrosion induced shaft binding.

Corrective Action: The switch was replaced, calibrated and returned to service. The failed switch was disassembled and inspected.

SOR dp Switch Failure Data Sheet

Equipment Piece Number: 2E31-NQ10B Model Number: 102-AS-E305-NX-JJTTX6
Serial Number: 85-1-2446

Application: Main Steam Line High Flow MSIV Isolation

Date and Time of Discovery: 11/20/90 1030 hours

Reactor Mode: Run Power Level: 100%

Calibration Tolerance: 102-104 PSID

Nominal Setpoint: 111 PSID

Action Limits: <98.2 or >107.8 PSID

Reject Limits: <94.8 or >111.2 PSID

Technical Specification
Limit: 116 PSID

As Found Setpoint: 120 PSID

Date and Time of Return to Service: 11/27/90 2050 hours

Model Number of Replacement Switch: 102-AS-E305-NX-JJTTX6

Serial Number of Replacement Switch: 86-10-562

DVR Number: 01-2-90-073

Cause: Instrument setpoint drift.

Corrective Action: The switch was replaced, calibrated and returned to service. The failed switch was disassembled and inspected. Internal inspection of the switch was performed with no abnormalities found.

SOR dp Switch Failure Data Sheet

Equipment Piece Number: 2E31-N011B Model Number: 102-AS-403-NX-JJTTX6

Serial Number: 85-1-2450

Application: Main Steam Line High Flow MSIV isolation

Date and Time of Discovery: 11/28/90 1100 hours

Reactor Mode: Run Power Level: 100%

Calibration Tolerance: 102-104 PSID

Nominal Setpoint: 111 PSID

Action Limits: <98.2 or >107.8 PSID

Reject Limits: <94.8 or >111.2 PSID

Technical Specification

Limit: 116 PSID

As Found Setpoint: 101 - 107 PSID

Date and Time of Return to Service: 11/30/90 1739 hours

Model Number of Replacement Switch: 102-AS-403-NX-JJTTX6

Serial Number of Replacement Switch: 86-10-563

DVR Number: 01-2-90-074

Cause: The switch was found to not maintain a constant setpoint. After disassembly and inspection, slight corrosion of the bearings and a scratch on the crossshaft was noted. The failure was due to corrosion induced shaft binding.

Corrective Action: The switch was replaced, calibrated and returned to service. The failed switch was disassembled and inspected.

TABLE 3
 3.1 OPERATING DATA REPORT

BUCKET NO. 050-374
 UNIT LASALLE TWO
 DATE DECEMBER 10 1990
 COMPLETED BY M.J. CIALKOWSKI
 TELEPHONE (815)-257-6761

OPERATING STATUS

1. REPORTING PERIOD: NOVEMBER 1990 GROSS HOURS IN REPORTING PERIOD: 720
 2. CURRENTLY AUTHORIZED POWER LEVEL (MW) 3,323 MAX DEMAND CAPACITY (MWe-Net) 1,036
 DESIGN ELECTRICAL RATING (MWe-Net) 1,070
 3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net) (NONE)
 4. REASONS FOR RESTRICTION (IF ANY)

REPORTING PERIOD DATA

	THIS MONTH	YEAR-TO-DATE	CUMULATIVE
5. REACTOR CRITICAL TIME (HOURS)	720.0	5,695.1	35,042.2
6. REACTOR RESERVE SHUTDOWN TIME (HOURS)	0.0	0.0	1,718.9
7. GENERATOR ON-LINE TIME (HOURS)	720.0	5,556.6	35,239.7
8. UNIT RESERVE SHUTDOWN TIME (HOURS)	0.0	0.0	0.0
9. THERMAL ENERGY GENERATED (MMWH)	2,361,312	17,350,967.2	103,679,015
10. ELECTRICAL ENERGY GENERATED (MWe-Gross)	866,000	5,837,672	34,280,598
11. ELECTRICAL ENERGY GENERATED (MWe-Net)	781,067	5,610,245	32,545,550
12. REACTOR SERVICE FACTOR (%)	100.0	71.0	66.8
13. REACTOR AVAILABILITY FACTOR (%)	100.0	71.0	70.0
14. UNIT SERVICE FACTOR (%)	100.0	69.3	65.7
15. UNIT AVAILABILITY FACTOR (%)	100.0	69.3	65.7
16. UNIT CAPACITY FACTOR (USING RDC) (%)	104.7	67.6	59.1
17. UNIT CAPACITY FACTOR (USING DESIGN MWe) (%)	100.0	64.9	56.8
18. UNIT FORCED OUTAGE FACTOR (%)	0.0	5.8	14.8

19. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH)
 (N/A)

20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP
 (N/A)

TABLE 4
F.2. AVERAGE DAILY UNIT POWER LEVEL (MW-NET)

DOCKET NO. 050-274
UNIT LASALLE TWO
DATE DECEMBER 10, 1990
COMPLETED BY M.J. CIALIMINI
TELEPHONE (815)-257-6761

REPORT PERIOD		NOVEMBER, 1990	
DAY	POWER	DAY	POWER
1	1,094	17	982
2	1,096	18	1,061
3	1,009	19	1,095
4	1,009	20	1,094
5	1,093	21	1,073
6	1,095	22	1,098
7	1,070	23	1,091
8	1,099	24	1,102
9	1,099	25	1,101
10	1,090	26	1,099
11	1,099	27	1,099
12	1,095	28	1,060
13	1,087	29	1,095
14	1,096	30	1,100
15	1,090	31	
16	1,083		

TABLE 5

F.3 UNIT SHUTDOWNS AND POWER REDUCTIONS >20%
(UNIT 2)

YEARLY SEQUENTIAL DATE NUMBER	(YMMDD)	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER	CORRECTIVE ACTIONS/COMMENTS (LER/DVR # if applicable)
-------------------------------------	---------	-----------------------------------	---------------------	--------	--	--

{None}

SUMMARY OF OPERATION:

The unit remained on line at high power throughout the month. Several minor power reductions were required due to low grid demand, routine surveillances, heater bay and feedwater pump work.

G. UNIQUE REPORTING REQUIREMENTS (Unit 2)

	Safety/Relief	Valve	Operations	
DATE	VALVES ACTUATED	NO & TYPE ACTUATIONS	PLANT CONDITION	DESCRIPTION OF EVENT
(None)				

2. ECCS System Outages
(See Table 6)

3. Changes to the Off-Site Dose Calculation Manual.
(None)

4. Major changes to Radioactive Waste Treatment Systems.
(None)

5. Indications of Failed Fuel Elements.
(None)

(Unit 2)
Table 6

G.2 ECCS System Outages

Note: The year and unit data has been removed from the outage number.

OUTAGE NO.	EQUIPMENT	PURPOSE
1764	2E51-F316	Repack valve
1767	2E12-C300A	Repair oil leak
1781	2E22-C302A	Replaced motor
1782	2E12-C00;B	Change oil
1787	2DG006	Repack valve
1792	2E22-D300	Inspection
1794	2E22-D300	Replace gasket