

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | S | G | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
01 | L | 6 | 0 | 5 | 0 | 0 | 0 | 4 | 1 | 6 | 7 | 0 | 9 | 2 | 5 | 8 | 2 | 8 | 1 | 0 | 2 | 5 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | During Non-Nuclear Heatup with the plant in Operational Condition 3 (Reactor at 217
03 | degrees F and 300 psig), Routine Surveillance 06-OP-1D17-M-0007 revealed Channels C&D
04 | of the Control Room Vent Radiation Monitors outside the tolerances specified in
05 | T.S.3.3.7.1-1.6. This event is being reported in accordance with T.S.6.9.1.13.b.
06 | The event resulted in no release of radioactivity, no damage to the facility, and
07 | no effect upon public health or safety.

09 | B | B | 11 | E | 12 | X | 13 | I | N | S | T | R | U | 14 | E | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | 22 | 0 | 8 | 2 | 24 | 26 | / | 27 | 0 | 3 | 28 | 29 | L | 30 | / | 31 | 0 | 32
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
E | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 40 | N | 23 | N | 24 | N | 25 | G | 0 | 8 | 0 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | The monitors were found to be out of calibration for the HiHi trip setpoint. Channels
11 | C&D were recalibrated and found to be satisfactory when the above Surveillance
12 | Procedure was repeated on September 25, 1982. (The redundant channels A & B were
13 | operable). No further action was required. This is a final report.

15 | B | 28 | 0 | 0 | 0 | 29 | NA | 30 | B | 31 | Surveillance Testing | 32
7 8 9 10 12 13 44 45 46 80
16 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 80
17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 11 12 13 80
18 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 11 12 80
19 | Z | 42 | NA | 43
7 8 9 10 80
20 | N | 44 | NA | 45 | 8210290081 821025 | PDR ADOCK 05000416 | PDR | NRC USE ONLY
7 8 9 10 68 69 80

Original signed by W. H. Chenault
NAME OF PREPARER _____ PHONE: _____