



Consumers
Power
Company

James W Cook
Vice President - Projects, Engineering
and Construction

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0453

October 15, 1982

Mr J G Keppler, Regional Administrator
US Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND NUCLEAR COGENERATION PLANT -
INSPECTION REPORTS NOS 50-329/82-06, 82-07 AND 50-330/82-06, 82-07
FILE: 0.4.2 SERIAL: 19071

- References: 1) JWCook letter to JGKeppler, Serial 19052, dated
September 30, 1982, Re Inspection Report Nos 82-05
& 82-06
- 2) JWCook letter to JGKeppler, Serial 19057, dated
September 30, 1982, Re Inspection Report No 82-07

Reference 1 committed to providing you the schedule for accomplishing
reinspection of cable routing. There are approximately 6,000 Class 1E
cables installed prior to March 15, 1982, which remain to be reinspected.
We plan to complete the reinspection of cable routing by the end of April,
1983, utilizing six teams working three teams per shift. These teams will
also conduct a sample overinspection for cables installed after March 15, 1982.

Reference 2 contains an error in the body of the letter in that in paragraph
2, the date in the first line should be January 1, 1981.

OCT 20 1982

Consumers Power Company

By James W. Cook

Sworn and subscribed to before me on this 15th day of October, 1982.

Patricia A. Puffer
Notary Public, Bay County, Mich

My commission expires 3-4-86

JWC/WRB/ljr

CC RWarnick, NRC Region III
WDSafer, NRC Region III
RNGardner, NRC Region III
RJCook, NRC Resident Inspector, Midland Site
RBLandsman, NRC Region III
BLBurgess, NRC Region III