

Medical Center
September 25, 1990

555 Willard Avenue
Newington CT 06111



Veterans
Administration

In Reply Refer To:

Mr. Steve Courtemanche
Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406

Dear Mr. Courtemanche:

During your inspection of the Newington VAMC on January 31, 1990 Routine Inspection No. 030-01283/90-001, our department was cited for using Xenon gas in a room not under negative pressure (Section 7). The Newington VAMC agreed to have the room properly ventilated to comply with N.R.C. regulations. This project was completed on September 18, 1990.

This letter is to inform you of our compliance with the N.R.C. recommendations.

Sincerely,

A handwritten signature in cursive script that reads "Larry T. Swing".

Larry T. Swing, Supervisor
Nuclear Medicine Service

9012190027 901210
REG1 LIC30
06-11222-01 PDR

"America is #1—Thanks to our Veterans"