

May 2, 1994



VIRGINIA POWER

Mr. Gregory L. Clayton
Virginia Department of Environmental Quality
300 Central Road, Suite B
Fredericksburg, Virginia 22401

Dear Mr. Clayton:

On August 30, 1993 Virginia Power applied for a permit to install an emergency standby diesel-powered generator at the North Anna Nuclear Power Station (registration number 40726). The permit was issued on October 20, 1993. Subsequently, Jim Cassada of Virginia Power and Terry Darden of DEQ had several telephone conversations during which they discussed certain emission limits in the permit which differ from those requested in our application. Mr. Darden was very helpful and cooperative, and expressed a willingness to reconsider the emission limits if Virginia Power could provide justification for the use of test data provided by the manufacturer (Caterpillar) rather than generic emission factors, and justification for the safety factors Caterpillar added to the emission data to establish guarantee values. Attached is a Caterpillar memorandum which addresses those issues.

The differences between the emission limits requested in the application (which are the values guaranteed by Caterpillar) and those contained in the permit are as follows:

- The short-term emission limit for NO_x (114.4 lb/hr) is lower than that guaranteed by Caterpillar (157.2 lb/hr).
- The short-term and annual emission limits for TOC (3.3 lb/hr and 1.2 TPY at 700 hr/yr operation) are lower than those guaranteed (6.7 lb/hr and 1.68 TPY at 500 hr/yr operation, or 2.35 TPY at 700 hr/yr operation).
- The SO₂ emission limits in the permit appear to be exactly half the values requested in the application. We believe the values in the application are correct, based on the heat input capacity and fuel sulfur content numbers given in the permit.


In addition, the short-term emission limit for PM₁₀ (1.8 lb/hr) is less than that originally guaranteed by Caterpillar (1.9 lb/hr) based on a 50% factor added to the nominal test data to account for variability in the engines and the tests. However, Caterpillar has subsequently re-examined the factor and determined that a factor of 40% is adequate. Therefore, we are not requesting that the emission limit for PM₁₀ be revised.

9405110095 940502
PDR ADOCK 05000338
PDR

COO 1/1

We believe the attached Caterpillar document will answer your questions about the basis of Caterpillar's emission rate data. If additional technical information is required, please contact Jim Cassada at (804) 273-3010. Thank you for your assistance.

Very truly yours,



A. W. Hadder
Manager
Air Quality

cc: U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Re: North Anna Power Station
Units 1 and 2
Docket Nos. 50-338 and 50-339
License Nos. NPF-4 and NPF-7

NRC Senior Resident Inspector
North Anna Power Station

Facility

Date February 10, 1994

Plant/
Office Large Engine Center

Department 3600 Project Services

Attention D E Davis

Plant Or Office	Department	Attention
Destroy	File Until (Date)	

SUBJECT: CATERPILLAR 3612 EMISSIONS DATA

The emission values provided are primarily based on laboratory measurements on similar 3600 engines. The lab measurements were made on development engines located at the Caterpillar Technical Center in Mossville, Illinois. These engines are equipped with production hardware in the areas of importance for emissions (injector nozzles, turbochargers, heads, valves, cams, etc.). The data from lab engines are supplemented with data from the field.

The 3600 is a modular engine. It uses separate cylinder heads and unit injectors so the combustion chamber is identical for 6, 8, 12 and 16 cylinder configurations. The 6 and 12 cylinder engines share turbochargers (one on the 6 and two on the 12) as do the 8 and 16 cylinder engines. The turbochargers used on the 6 and 12 are smaller than the 8 and 16 but the turbochargers are matched so that the intake manifold pressure is similar. The flow per cylinder and the air-fuel ratio are therefore similar.

TEST METHODS FOR GASEOUS EMISSIONS

NO_x - a chemiluminescent analyzer with nitrogen dioxide converter is used which is consistent with EPA Method 7E

Hydrocarbons (gaseous organic compounds) - a flame ionization analyzer is used which is consistent with EPA Method 25A

CO - A non-dispersive infrared analyzer (NDIR) is used which is consistent with EPA Method 10

Exhaust flow - inlet air flow and fuel flow are measured. Exhaust flow is the sum of the air and fuel flows.

Quality control is consistent with EPA requirements for on-highway truck engines. Additional quality control includes a carbon balance of fuel inlet carbon vs. the measured exhaust carbon (CO, HC, CO₂) to check the measuring systems.

TEST METHOD FOR PARTICULATES

Caterpillar has developed a special measuring system for particulate emissions called the Steady State Particulate System (SSPS). The Steady State Particulate System was

designed to measure diesel particulate in a manner compatible with EPA Method 5 without back-half wash. Diesel particulate are very small (about 0.3 micron) and do not exhibit significant inertia effects so isokinetic sampling is not necessary (EPA method for truck diesel engines do not use isokinetic sampling). SSPS samples similar to method 5 in that the exhaust sample is pulled through a filter held at 120 deg C and the filter is weighed before and after sampling. SSPS was found to correlate with Method 5 in lab tests (field experience will be covered later)

DATA USED FOR EMISSION VALUES PROVIDED

The emission values provided for the 3612 are based on tests on a 3606 conducted March 21, 1990 at the Caterpillar Technical Center. These tests are covered in an internal Caterpillar report, 3606 High Speed Emissions Correlation with 3608 by DA Spurgeon. The 3612 is essentially two 6 cylinder engines sharing a crankshaft so the data is applicable to both engines. The test data are given on Sheets A and B. Caterpillar has computerized test cells which store the data electronically. The data on Sheets A and B are modified slightly for injection timing (21 to 21.5 degrees) based on data taken from other engines. Plotted data are shown on Sheet C. Emissions units are usually reduced to grams/brake-horsepower hour (g/bhp-hr) since this has been the historic unit chosen by EPA for regulating engines and allows comparing engines of various power (brake power is the power from the output shaft of the engine)

The published emission data sheet is given on Sheet D. The emission values for this sheet are chosen conservatively.

COMPARISON OF LAB RESULTS TO FIELD DATA

Caterpillar is not normally provided with emission test data from the field unless there is some problem. The following is the field data we have on the 3600

Almega Corp. of Bensenville, Illinois measured nitrogen oxide emissions on a 3608 generator set engine located at the Caterpillar plant in Pontiac, Illinois on Oct. 9, 1987 using EPA Method 7 (grab sample colorimetric method). The 3 runs were 46.4, 38.8, and 51.2 lb/hr for an average of 45.5 lb/hr (7.38 g/bhp-hr)(see Sheet E). Caterpillar had run the same set-up at the Technical center on April 6, 1987 giving 51.2 lb/hr (8.26 g/bhp-hr) (see Sheet F-printer problems did not allow printing of full sheet).

Environmental Technologies International of Honolulu, Hawaii tested eight 3616 engines on the island of Guam for particulates (Method 5) and nitrogen oxides (Method 7E). The measured values are given on Sheet G. The NOx ranged from 6.34 to 7.37 for an average of 7.02 g/bhp-hr compared to a nominal value of 7.20 g/bhp-hr provided from lab testing. The particulates included a very high emission measurement for Old GMH Unit 2 which was reduced to a value consistent with the others on a repeat test. It is likely the high values was due to accumulated soot or rust blown out the stack during this initial running. Soot can accumulate in stacks during light load running and are then blown out when operated at full load. The average excluding the high value is 0.217 g/bhp-hr compared to a nominal of 0.32 g/bhp-hr based on lab measurements with the Caterpillar Steady State Sampling System.

Measurements on a 3616 at Algona, Iowa on August 4, 1993 gave higher than expected particulate emissions. An emission rate of 0.367 g/bhp-hr was measured using Method 5 (front half) compared to a nominal lab value of 0.12 g/bhp-hr. Repeat measurements were made on October 15, 1993 by Almega Corp. which gave a value of 0.078 g/bhp-hr. The

early high values are believed to be due to scale and/or accumulated soot blowing out the stack. During engine warm-up, large particles (about 1 μ m) accumulated on surfaces near the stack. Diesels do not produce particles of this size.

Caterpillar measured particulates at the Algona site with the Steady State Particulate System in parallel with the Method 5 measurements. The SSPs gave 0.075 g/bhp-hr vs 0.078 for Method 5.

These tests confirm that the emission values provided from the laboratory engines are valid for actual engines in operation.

VARIABILITY

Emission measurements are inherently variable. This variability must be accounted for when providing "not-to-exceed" values for emission permits.

Our standard tolerances are:

NO _x	15%
CO	30%
HC	30%
Particulates	40%

These tolerances are less than what were sent on August 4, 1993 (20% NO_x, 35% HC & CO, and 50% particulates). The higher tolerances had been revised down in early 1993 but there was a miscommunication internally.

The tolerances are based on Caterpillar experience on truck engines that must meet not-to-exceed emission standards, field measurements, and literature information.

Flow Tolerance

Exhaust flow measurement error directly effects the emission rate. Measuring the exhaust flow with EPA Method 2 is prone to errors. For instance, at the high stack velocity common with diesels (30 m/s), the flow measurement is very sensitive to Type S pitot probe orientation. A 10 degree error can give about 10% velocity error. The probable tolerance for exhaust flow is estimated at 3-5% at best.

NO_x Tolerance

The data from the 3616 engines at Guam give a coefficient of variation of 5.2% of the mean NO_x value. The coefficient of variation (COV) is the standard deviation divided by the mean value. The Guam data was taken with a chemiluminescent analyzer (EPA Method 7E). This COV is consistent with truck engine emission variability (chemiluminescent analyzers are used).

NO_x measurements at the Caterpillar Pontiac plant with the grab sample/phenoldisulfonic acid/colorimetric procedure (EPA method 7) give a coefficient of variation of 59% based on the three measurements of 46.4, 38.8, and 51.2 lb/hr. Method 7 uses an average of the 3 samples so the COV would be reduced, but only to about 30%. Diesel engines produce very stable NO_x concentrations at steady load, the variation must be attributed primarily to the measuring system.

The emission values with tolerances are intended to be "not-to-be exceeded". For a normal distribution, 97.7% of the samples would be less than the average + 2 standard

deviations. Based on the use of EPA Method 7E (chemiluminescent) with its lower variability and the flow error probability, a tolerance of 15% was selected for NOx. This would be low for EPA Method 7 (grab sample).

Particulate Tolerance

The literature reports very high variations with Method 5. Licata and Egdall in The Precision of Source Emission Measurement Methods report coefficients of variations of up to 40% for particulate concentrations about 10 times what are found with diesels (see Sheet H). The Method 5 procedure has many potential sources of error or contamination and is very dependent on the skill of the operators.

The particulate measurements at Guam give a 106% coefficient of variation if the asterisked point is included (see Sheet G). It is obvious that this is not a normal distribution if this point is included. We believe the high value is due to accumulated material in the stack. Excluding this point reduces the COV to 7.3%.

Truck engine tests give coefficient of variations of 5-14%.


Considering the high tolerances reported by some and including tolerance for exhaust flow, a tolerance of 40% was selected.

Hydrocarbon Tolerance

No field data are available on hydrocarbon emissions on the 3600. The coefficient of variation observed in truck engine lab tests is 8-12%. A tolerance value of 30% was selected based on the truck engine data (taken in well controlled conditions) and considering flow error and lack of field experience.

Carbon Monoxide

No field data are available on CO emissions on the 3600. The coefficient of variation in truck lab tests is about 6%. A tolerance value of 30% was chosen due to lack of field data and due to the low basic CO emissions of the diesel engine.



J R Gladden
Sr Project Engineer
3600 Product

PART LOAD EXHAUST EMISSIONS AT 900 RPM (EPA SUB PART D)

FILE: DF02015 DATE: 21-MAR-90 CBS: SPURGEON
 RACK CAL: FAMILY (EPA):
 TURBINE DIA: FLOW TIME: HSC/NOZ AREA:
 ENGINE MODEL: 3606-DITA NO: 007X3
 BORE: 200.0 MM STROKE 300.0 MM CYLS: 6
 TEST CON AIR TO ENGINE OR TURBO COMPR - TEMP: 24. DEG C
 PRESS: 96.0 KPA ABS AT EACH DATA POINT
 FUEL-TYPE: 1E262 TEMP: 46. DEG C
 BARD: 99.0 KPA AFTERCOOLING: SCAC-50C
 INJ TIME DEG BTC: 21.0 DEG ADV: 0.00
 TURBO MODEL: VTC234A - SEE REMARKS
 NO: 1 LOCATION: REAR
 REMARKS TURBO: VC11/HF10/HA04-MC00/EF10/EA03
 7C3396 HIGH SPEED HOL CAM
 2350 EMISSIONS DATA (REF DF02014 PART LOAD PERF)

CELL: 502 FILE NO: 00000-000 DYMO COM.
 CODE (EPA):
 101.7 DANIELS AIR FLOW PIPE DIA:
 COMB CHAMB PISTON CRATER:
 CR: 13.00 NOMINAL PC ORIF:
 FUEL BYST TYPE: LUCAS-UI PUMP DIA: 21.0 MM
 CHECK TYPE GROUP NO:
 FUEL NOZZ PART NO: LUCAS TYPE: O.I.
 ORIFICES- NO: 10 DIA: .463MM ANGLE: 145 DEG
 FUEL LINES ID AND LENGTH-EXTERNAL: X
 INTERNAL: X
 EXH MAN TYPE: SPLIT PART NO:
 PUBDATA GEN APPL:
 AUTO SP APPL:

DATA POINT	1	2	3	4	5	7	
BEAM	M-R	3512.0	7630.4	10366.7	14101.9	10300.6	22030.9
AVE RPM	RPM	900	900	900	900	900	900
MEP	KPA	390.3	797.1	1190.0	1590.0	2074.0	2500.0
POWER	KW	331.00	662.42	995.57	1320.63	1724.10	2077.53
FUEL RATE	CM3/MIN	1426.50	2469.50	3491.70	4501.02	5732.45	6920.52
BSFC (GROSS BASIS)	CM3/KW-HR	250.395	223.605	210.440	203.262	199.405	199.860
TURBO SPEED (L)	KRPM	10.6	15.5	20.1	23.9	27.6	30.5
AIR FLOW (L/L-PR)	KG/HR	3311	4649	6170	7077	10111	12217
SNOKE		0.031	0.041	0.022	0.015	0.011	0.011
RACK POSITION OBSERVED	MM	-9.300	-3.617	1.676	6.600	12.669	17.926
GIL PRESSURE	KPA	492.63	407.26	404.70	402.77	400.61	477.29
FUEL PRESSURE	KPA	702.42	609.03	675.77	663.21	643.77	620.65
INLET AIR (L/L-PR)	DEG C	22.1	22.5	23.2	23.0	24.2	24.0
AIR TEMP FROM COMPR(L/L-PR)	DEG C	43.7	63.9	93.0	120.2	163.2	197.9
WATER TEMP TO AFTCOOLER	DEG C	52.2	53.9	50.2	51.0	49.7	47.1
WATER TEMP FROM ENGINE	DEG C	05.0	04.0	05.6	07.5	05.9	07.4
OIL TO BEARINGS	DEG C	01.0	01.6	01.6	02.0	02.4	02.9
EXH TEMP TO TURBO (LF)	DEG C	391.3	496.4	547.3	572.1	507.2	600.9
EXH TEMP TO TURBO (LR)	DEG C	379.6	490.0	541.0	560.9	506.4	607.3
EXHAUST STACK TEMP	DEG C	332	400	430	443	436	435
FUEL TEMPERATURE	DEG C	40.4	40.3	40.3	40.3	40.1	40.3
INLET AIR RESTRICTION (L)	KPA	-3.60	-3.67	-3.63	-3.65	-3.61	-3.59
EXHAUST STACK PRESSURE	KPA	-0.19	-0.12	-0.07	0.01	0.21	0.54
AIR PRES FROM COMPR (L)	KPA	11.05	40.92	02.62	133.56	200.32	264.45
EXH PRES TO TURBO (LF)	KPA	12.49	20.12	44.69	72.66	114.10	157.75
EXH PRES TO TURBO (LR)	KPA	13.56	26.56	49.25	79.60	124.33	179.67
PEAK CYLINDER PRESSURE	KPA	6500	0750	11000	13500	16000	10250
CO2 (DRY)	PERCENT	5.20	6.90	7.40	7.30	7.50	7.50
CO (DRY)	PERCENT	0.014	0.017	0.014	0.013	0.011	0.014
NOX (DRY)	PPM	1637	2152	2091	2061	1913	1772
HC (NET)	PPM	275	315	335	270	220	190
DEW POINT TEMPERATURE	DEG C	-1.4	-1.3	-1.2	-1.3	-1.3	-1.2
DEW POINT PRESSURE	KPA	0.5	0.5	0.5	0.5	0.5	0.5
BAROMETER	KPA	99.04	99.01	99.00	99.79	99.75	99.73
CYL 6 PEAK PRESS-KPA		6750.0	9000.0	11250.0	13750.0	16250.0	10500.0
IGN TIMING - DEG		7.000	0.000	10.000	11.000	11.000	13.000
PUMP 1 DYN INJ TIM - DEG		20.000	20.000	20.000	20.000	20.000	20.000
CYLINDER PRESSURE		6500.0	0750.0	11000.0	13500.0	16000.0	10250.0
IGN DELAY - DEG		13.000	12.000	10.000	9.000	9.000	7.000
PUMP INJ DUR - DEG		11.000	15.000	19.000	23.000	20.000	33.000
PUMP1 PEAK INJ P - KPA		75.000	90.000	105.000	123.000	120.000	140.000
COMPRESSION PRESS - KPA		3250.0	4250.0	5250.0	6750.0	0500.0	10000.0

CURRENT SECTOR IS 1.1 OF 1.1 CURRENT DIRECTION IS 11

3600 LAC TESTS

1/1

SHEET A

----- OUTPUT -----
Power 66p

1782

2312 64p

1335

88X

444

DATA POINT	1	2	3	4	5	7
AVE RPM	900	900	900	900	900	900
BMEP	398.3	797.1	1198.0	1598.0	2074.0	2500.0
POWER	331.00	662.42	993.57	1324.10	1739.33	2077.53
FUEL RATE	331.62	665.61	1005.04	1352.31	1759.45	2127.45
SMOKE (CORR TO 75 GRAINS)	1426.50	2459.36	3491.78	4581.02	5732.45	6920.52
PARTIC (75 GR - 82 EQM)	250.595	223.695	210.440	203.262	199.405	199.060
EXHAUST	3507	4644	6163	7869	10100	12204
SMOKE (CORR TO 75 GRAINS)	3593	4792	6373	8139	10444	12619
AIR/FUEL RATIO	0.039	0.051	0.028	0.020	0.016	0.015
FUEL TO AIR RATIO	40.97	31.34	29.42	29.14	29.37	29.39
EPA FUEL/AIR RATIO	0.02441	0.03191	0.03359	0.03432	0.03405	0.03402
X DIFF F/A	0.0245	0.0322	0.0344	0.0340	0.0340	0.0340
VOLUMETRIC EFFICIENCY	0.14	0.31	0.96	1.12	1.70	1.06
PARTIC (75 GR - 82 EQM)	05.72	113.54	150.71	192.45	247.12	298.65
RACK P08 FROM C/L	103.7	169.2	153.2	163.3	186.7	221.4
IMLET MANIFOLD AIR PRES	-9.500	3.617	1.676	6.600	12.669	17.926
IMLET AIR TEMP	99.04	99.01	99.00	99.79	99.73	99.73
WET TO DRY CONVERSION	22.1	22.3	23.2	23.0	24.2	24.0
KNOX CORRECTION FACTOR	0.954	0.940	0.936	0.936	0.936	0.936
PEAK CYLINDER PRESSURE	0.904	0.900	0.900	0.907	0.906	0.905
BAROMETER	6500	0750	11000	13500	16000	18250
HUMIDITY	99.94	99.01	99.00	99.79	99.73	99.73
CO2	24	24	24	24	24	24
CO	5.20	6.90	7.40	7.50	7.50	7.50
MOX AS MO	140	170	140	130	110	140
MC	1637	2132	2091	2061	1913	1772
CO	200	335	350	209	235	203
CO2	463	734	790	943	1017	1563
MOX AS MO	4504.4	7004.7	11041.7	14249.4	10165.6	21931.0
MC	5001	9937	12762	16013	10937	21199
BAROMETER	470.7	714.4	1006.0	1033.0	1073.0	1119.7
CORRECTED TO 75 GRAINS HUMIDITY	5245	9039	11506	14525	17175	19104
MOX AS MO	10.11	15.60	13.30	12.10	11.39	10.55
FED. REC VOL. 42 NO. 174, SEPT. 8, 1977	1.04	0.827	0.598	0.529	0.440	0.561
----- OUTPUT -----	1.06	0.805	0.714	0.580	0.464	0.402

g/h, h, NO. correct
g/h, h, CO
g/h, h, MC

3600 LBS
70575


2/2

DATA POINT	1	2	3	4	5	7
AVE RPM	900	900	900	900	900	900
BMEP	398.3	797.1	1198.0	1598.0	2074.0	2500.0
SMOKE	0.031	0.041	0.022	0.015	0.011	0.011
SMOKE (CORR TO 75 GRAINS)	0.039	0.051	0.028	0.020	0.016	0.015
PARTIC (75 GR - 82 EQM)	103.7	169.2	153.2	163.3	186.7	221.4
EXHAUST	1727.4	2304.0	3064.0	3913.3	5021.7	6067.5
KNOX CORRECTION FACTOR	0.904	0.900	0.900	0.907	0.906	0.905
VENTILATION CO2	34131	39350	04610	109453	140320	169001
VENTILATION CO	4595	7337	0804	9400	10303	15940
VENTILATION MO2	214905	371406	470094	601420	716994	082434
VENTILATION MO2 - 75	194209	337225	434066	545401	649501	726105
BAROMETER	99.04	99.01	99.00	99.79	99.73	99.73

NOTE: EXHAUST, VENTILATION CO2, CO, MO2, AND MO2 - 75 HAVE BEEN CURRENT SECTOR IS 2. 1 OF 3. 1 - CURRENT DIRECTION IS


900 RPM

HYDROCARBON EMISSIONS
CORRELATION BETWEEN 3606 AND 3608




900 RPM

NITROGEN OXIDE EMISSION LEVELS (as NO2)
CORRELATION BETWEEN 3606 AND 3608




900 RPM

MEASURED PARTICULATE MATTER - MODIFIED MTD 5
DOES NOT INCLUDE "BROX HALF WASH" PARTICULATES



900 RPM

CARBON MONOXIDE EMISSIONS
CORRELATION BETWEEN 3606 AND 3608



CATERPILLAR

3600 EMISSIONS

12 CYLINDERS

STANDARD TIMING

21.5 DEGREES

MOL CAM

FUEL SULFUR

0.2 %

DISTILLATE

TURBOCHARGER: VTC254

ENGINE SPEED rpm	900	900	900	900	900	900	900
ENGINE POWER bkW	4180	3800	3460	3140	2356	1570	786
ENGINE POWER bhp	5605	5096	4640	4211	3159	2105	1054
BMEP kPa	2514	2286	2081	1889	1417	944	473

BRAKE SPECIFIC EMISSIONS g/bhp-hr

NOx (as NO ₂)	10.6	11.2	11.5	12.1	13.1	17.9	18.7
Hydrocarbons	0.40	0.43	0.47	0.50	0.64	0.81	1.05
Carbon Monoxide	0.56	0.48	0.42	0.47	0.55	0.73	1.05
Sulfur Dioxide	0.60	0.60	0.60	0.60	0.62	0.65	0.74
Particulates	0.10	0.10	0.10	0.10	0.18	0.28	0.42

BRAKE SPECIFIC EMISSIONS g/bkW-hr

NOx (as NO ₂)	14.2	15.0	15.4	16.2	17.6	24.0	25.1
Hydrocarbons	0.54	0.58	0.63	0.67	0.86	1.09	1.41
Carbon Monoxide	0.75	0.64	0.56	0.63	0.74	0.98	1.41
Sulfur Dioxide	0.80	0.80	0.80	0.80	0.83	0.87	1.00
Particulates	0.13	0.13	0.13	0.13	0.24	0.38	0.56

EMISSION RATE g/hr

NOx (as NO ₂)	59418	57074	53359	50951	41389	37687	19711
Hydrocarbons	2242	2191	2181	2105	2022	1705	1107
Carbon Monoxide	3139	2446	1949	1979	1738	1537	1107
Sulfur Dioxide	3341	3037	2765	2509	1949	1361	785
Particulates	561	510	464	421	569	590	443

Sulfur dioxide emissions are proportional to fuel sulfur. Values are nominal and do not include tolerances for engine to engine or instrumentation variation.

The ALMEGA CORPORATION

SUMMARY OF EMISSION TEST DATA

TABLE:	1		
PLANT:	Caterpillar Inc., Pontiac, Illinois		
SOURCE:	Stationary Diesel Engine 3608		
OPERATOR:	M. R. Jackson		
REPETITION #:	1	2	3
TEST DATE:	10/9/87	10/9/87	10/9/87
TEST TIME:	4:00-5:00AM	5:00-6:00AM	6:00-7:00AM

STACK GAS

Temperature, average °F	728.5	753.0	754.5
Velocity average fps	117.8	117.8	115.1
Volume flow x scfh db x 10 ⁶	0.399	0.387	0.384
acfm	16,005	15,998	15,635
% CO ₂	6.0	6.0	5.5
O ₂	13.5	13.5	13.5
Moisture %	6.5	7.0	6.1

NITROGEN OXIDE

Concentration x 10 ⁻⁶ lb/scf db	116.2	100.0	133.6
ppm	974	837	1,119
Emissions lbs/hr	46.4	38.8	51.2

AUDIT SAMPLE

NO _x concentration ppm	
calibration gas	350
audit samples	346

METHOD 7A

TEST MUST BE RUN AT 900 RPM 100% RPM PART 1)
 DATE: 07-09-74
 TIME DIA: 297.74
 PUMP DIA: 23.0
 GROUP MOI: 7C3854

NOI: 8MC245
 STROKE: 500 MM
 TUMBO COMP: - TEMP: 24.4240
 PRESS: 96 ASD AT EACH DATA POINT
 TEMPI: 39.0057
 AFTERCOOLING: SEP CIM
 DEC: 16.5 DEG
 DEC ADJ: NONE

LOCATIONS: 100, 200, 300, 400, 500, 600, 700, 800, 900, 1000
 VALVE: 100, 200, 300, 400, 500, 600, 700, 800, 900, 1000

PARAMETER	100	200	300	400	500	600	700	800	900	1000
REC'D RPM	395.9	402.0	1201.0	1603.2	1890.2	2077.3	2265.9	2454.5	2643.1	2831.7
EM (CORR. FUM J1349)	443.50	889.56	1335.12	1780.68	2226.24	2671.80	3117.36	3562.92	4008.48	4454.04
L RATE	446.04	892.08	1338.12	1783.68	2229.24	2674.80	3120.36	3565.92	4011.48	4457.04
C (MASS BASIS)	1083.10	2166.20	3249.30	4332.40	5415.50	6498.60	7581.70	8664.80	9747.90	10831.00
C (MASS) (J1349 W5)	254.7	219.3	205.6	199.8	198.0	196.2	194.4	192.6	190.8	189.0
P (CORR. (TOTAL))	4154.0	5989.0	8308.0	11030.0	13026.0	15022.0	17018.0	19014.0	21010.0	23006.0
AUTY MASS	8267.0	6184.0	4101.0	2018.0	935.0	350.0	135.0	52.0	20.0	7.0
RE (CORR. TH 75 GRAINS)	36.77	30.73	30.33	31.12	31.32	31.52	31.72	31.92	32.12	32.32
FUEL WATER	-0.2154	-0.3255	-0.4356	-0.5457	-0.6558	-0.7659	-0.8760	-0.9861	-1.0962	-1.2063
TO AIR WATER	7.26	7.24	7.47	7.38	7.61	7.61	7.61	7.61	7.61	7.61
FUELL/AIR RATIO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
REC'D PUMPER	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
REC'D WPC	93.10	102.54	105.92	107.12	107.62	107.62	107.62	107.62	107.62	107.62
METRIC EFFICIENCY	251.0	277.1	281.7	286.6	291.5	296.4	301.3	306.2	311.1	316.0
YIC (75 GR. - 82 LUN.)	-10.443	-4.497	0.00	5.560	11.623	17.686	23.749	29.812	35.875	41.938
R PUS FROM C/L	106.15	130.45	166.29	202.14	238.00	273.85	309.70	345.55	381.40	417.25
ET MANIFOLD AIR PRES	24.2	24.2	24.3	24.4	24.5	24.6	24.7	24.8	24.9	25.0
ET AIR TEMP	952	943	943	942	942	942	942	942	942	942
TO DRY CONVERSION	900	905	904	903	903	903	903	903	903	903
CORRECTION FACTOR	5600	7800	9900	12200	13900	15600	17300	19000	20700	22400
R CYLINDER PRESSURE	99.70	99.70	99.70	99.64	99.62	99.62	99.62	99.62	99.62	99.62
UNLEIGH	25	24	24	24	24	24	24	24	24	24
IDITY	5.41	6.53	6.61	6.40	6.38	6.38	6.38	6.38	6.38	6.38
AB NO	178	152	109	145	120	113	113	113	113	113
AS NO	645	1237	1329	1215	1192	1192	1192	1192	1192	1192
	243	165	192	176	159	146	146	146	146	146
	747	510	512	519	526	533	540	547	554	561
	5947.51028	5144.9	5169.6	5193.6	5217.6	5241.6	5265.6	5289.6	5313.6	5337.6
	3796	7969	11897	15795	19693	23591	27489	31387	35285	39183
	588.3	550.2	793.6	973.1	1028.6	1055.9	1073.5	1091.1	1108.7	1126.3
	3417.	7209.	10759.	13157.	15147.	16111.	16235.			

REC'D TO 75 GRAINS HUMIDITY GR/MM
 REC'D TO 75 GRAINS HUMIDITY GR/MM
 REC'D TO 75 GRAINS HUMIDITY GR/MM

LAB DATA RUN
 AT SAME CONDITIONS
 AS POSITIVE PLANS
 3608 TESTED BY
 ALMEGA, CORP.

2812 64P → 2.26 8/64p.A.
 1514 13 6 46 = 51.2 15/4-

EMISSION MEASUREMENTS ON 3616 ENGINES AT GUAM

Engine	Date	NOx g/bhp-hr	PARTICULATES g/bhp-hr
Old GMH Unit 1	5/20/93	7.11	0.210
"	5/26/93	6.99	0.231
Old GMH Unit 2	5/15/93	6.59	1.23 *
"	5/19/93	7.30	0.238
Talofofo Unit 1	5/21/93	6.34	0.226
Talofofo Unit 2	6/23/93	6.78	0.221
GPA Unit 1	6/14/93	7.21	0.193
"	7/14/93	7.30	--
GPA Unit 2	6/13/93	7.37	0.218
"	7/14/93	7.12	--
Tumon Unit 1	6/24/93	7.22	0.209
"	7/15/93	6.85	--
Tumon Unit 2	6/25/93	7.06	0.219
	Average:	7.02	0.329 0.217 excluding *

* Rust, mill scale, and/or accumulated soot in muffler probably gave high value.

BETWEEN TEAM VARIATIONS FOR PARTICULATE EMISSIONS

- ▲ ASTM - INSTACK FILTER
- EPA - 5 WITH 3 SINGLE TRAINS
- EPA - 5 WITH 4 PAIRED TRAINS




FIG. NO. 1