

NUCLEAR REGULATORY COMMISSION

T-1143

ORIGINAL

In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
 SUBCOMMITTEE ON CLINCH RIVER BREEDER REACTOR

DATE: October 27, 1982 PAGES: 1 - 233
AT: Washington, D. C.

TROY
ADD LPDR
NSIC
NTIS
CF

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8210290184 821027
PDR ACRS
T-1143 PDR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
SUBCOMMITTEE ON CLINCH RIVER BREEDER REACTOR

- - -

Nuclear Regulatory Commission
1717 H Street, N.W.
Washington, D.C.
Wednesday, October 27, 1982

The meeting of the Subcommittee on Clinch River Breeder Reactor of the Advisory Committee on Reactor Safeguards was convened at 8:30 a.m.

PRESENT FOR THE ACRS:

- Max W. CARBON, Chairman
- Robert AXTMANN, Member
- J. Carson MARK, Member
- Jeremiah J. RAY, Member

DESIGNATED FEDERAL EMPLOYEE:

P. BOEHNERT

ACRS CONSULTANTS:

- W. KASTENBERG
- W. Lipinski
- Z. ZUDANS

1 ALSO PRESENT:

2 T. KING
3 G. CLARE
4 P. DICKSON
5 D. BECKER
6 R. STARK
7 B. MORRIS
8 P. CHECK

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

P R O C E E D I N G S

1
2 MR. CARBON: The meeting will now come to
3 order.

4 This is a meeting of the Advisory Committee on
5 Reactor Safeguards Subcommittee on Clinch River Breeder
6 Reactor, CRBR.

7 My name is Carbon, the subcommittee chairman.
8 The other ACRS members present today are Robert Axtmann,
9 Carson Mark, and Jeremiah Ray on my left. We also have
10 in attendance ACRS consultants William Kastenber and
11 Zenon Zudans.

12 The purpose of the meeting today is to discuss
13 CRBR plant design criteria, safeguards, and security for
14 CRBR and design basis accidents and their associated
15 prevention-mitigation systems.

16 The meeting is being conducted in accordance
17 with the provisions of the Federal Advisory Committee
18 Act and the Government in the Sunshine Act. Paul
19 Boehnert is the Designated Federal Employee for the
20 meeting. The rules for participation in the meeting
21 have been announced as part of the notice previously
22 published in the Federal Register on Wednesday, October
23 6th, 1982.

24 A transcript of the meeting is being kept, and
25 will be made available, as stated in the Federal

1 Register notice. It is requested that each person first
2 identify himself or herself and use the microphone so
3 that he or she can be readily heard.

4 We have received no written statements from
5 members of the public, and we have received no requests
6 for time to make oral statements from members of the
7 public.

8 Before we start, I would turn to the
9 subcommittee and ask if anyone has any comments to make
10 or questions to raise. I would point out that our first
11 topic is plant design criteria. We are meeting today on
12 this topic, I believe, specifically at the request of
13 the staff. It is a continuation of earlier
14 discussions. You have noted and will note that I think
15 it is four criteria that have been added to the previous
16 list. We have been discussing those. We will be
17 discussing in particular some questions which Dave
18 Okrent raised the last time, and discussing whatever
19 else we or the staff wish.

20 It is expected that the design criteria topic
21 will be on the full committee meeting next week. I
22 won't say anything, I guess, on the design basis
23 accident rationale or plant safety and security at this
24 time, but we will get into those as quite separate
25 topics later in the day.

1 Does anyone have any comments?

2 MR. MARK: I have a question, which perhaps
3 can be answered by King, Mr. King, since he is
4 presenting the criteria. How does he propose to do
5 that? Is he going to go through the whole 60, calling
6 attention to them? I have a few textual questions which
7 I could raise separately, but if he is going through the
8 criteria one at a time, I hope he doesn't, but he might
9 say, Criteria 1, are there any questions, Criteria 2.

10 MR. CARBON: Why don't you just answer when
11 you start?

12 MR. KING: I do not intend to go through my
13 criteria one by one. I intend to address the major
14 changes in the PSAR and the site suitability report. I
15 provided yesterday a copy of the final draft of the SER
16 section which does go through the criteria one by one
17 and explains all the changes from Appendix A to 10 CFR
18 50.

19 MR. MARK: Perhaps after you have gone through
20 what you have planned, then I could have an opportunity
21 to ask about this criteria or that one.

22 MR. KING: Yes. That is one of the reasons I
23 provided the SER sections. Any questions that come up
24 on criteria, you will at least have the words in front
25 of you.

1 MR. CARBON: Are there any other questions or
2 comments?

3 MR. RAY: I had a similar concern. I wondered
4 how you were going to treat Dr. Okrent's comments.

5 MR. KING: I will have vu-graphs that address
6 each of Dr. Okrent's comments.

7 MR. RAY: Thank you.

8 MR. CARBON: Let's them proceed with the
9 meeting. I guess I call on Mr. Stark.

10 MR. STARK: Good morning.

11 Today the staff will make three
12 presentations. Two of the presentations that will occur
13 later, the one on accidents and sabotage, will be status
14 reports, and they will be quite similar to the status
15 report we made yesterday to the subcommittee on thermal
16 hydraulics. However, as Dr. Carbon stated, the first
17 presentation is a discussion on what we believe are
18 mature and final design criteria.

19 As Dr. Carbon indicated, the design criteria
20 were the subject of a March ACRS working group meeting.
21 We believe we have incorporated the comments from that
22 March meeting, as well as Dr. Okrent's July letter, and
23 Tom King, who will be following right now, will discuss
24 the design criteria and how they have been changed by
25 the March ACRS meeting, and how we factored in Dr.

1 Okrent's comments.

2 So, with that, I will turn it over to Tom
3 King.

4 MR. KING: My name is Tom King. I am with the
5 NRC staff in the Clinch River Program Office.

6 Today I will be talking about principal design
7 criteria for Clinch River.

8 Over the past several months, we have spent
9 considerable time going through the criteria, the
10 criteria that were developed in 1976, and that currently
11 show up in the PSAR and the site suitability report. We
12 think we have a complete set. We are here today to
13 present this set and to solicit any comment or feedback
14 you have on the comment.

15 I plan to summarize what we have done in terms
16 of the approach we have taken in looking at the
17 criteria, the major changes we have made, and to address
18 Dr. Okrent's comments and the ACRS comments from the
19 March 30th and 31st meeting.

20 (Slide.)

21 MR. KING: The purpose of the principal design
22 criteria is spelled out in 10 CFR 50. Basically, it
23 says they establish the necessary design, fabrication,
24 construction, testing, and performance requirements for
25 structures, systems, and components important to safety,

1 that is, structures, systems, and components that
2 provide reasonable assurance that the facility can be
3 operated without undue risk to the health and safety of
4 the public.

5 Appendix A to 10 CFR 50 provides 55 general
6 design criteria which are written for light/water
7 reactors, but it is acknowledged in the preface to
8 Appendix A that they are to be used as guidelines for
9 developing principal design criteria for other types of
10 reactors.

11 (Slide.)

12 MR. KING: The way we accomplished or tried to
13 accomplish what we feel the intent of the criteria is,
14 we feel that as far as Clinch River is concerned, the
15 intent of that criteria is to express the broad
16 requirements which must be met to ensure that the safety
17 of CRBR is comparable to LWR's and that core disruptive
18 accidents are of sufficiently low likelihood that they
19 can be excluded from the plant design basis.

20 In going through the criteria and looking at
21 the changes we felt should be made, this was the basic
22 premise we started from. We had three basic rules that
23 followed from this. They were, in going through the
24 criteria, we tried to, for those structures, systems,
25 and components which are comparable to structures,

1 systems, and components in LWR's, we made it equivalent
2 to or more conservative than the corresponding
3 requirements for LWR's.

4 For the unique aspects associated with Clinch
5 River, we developed unique criteria, and in developing
6 those, we tried to reflect an equivalent or more
7 conservative safety approach than generally applied to
8 LWR's, and we tried to look at those factors which we
9 felt were necessary, design factors that were necessary
10 to reduce the likelihood of core disruptive accidents
11 such that they could be excluded from the CRBR design
12 basis, and we have added or made changes to criteria
13 that we feel address that point.

14 (Slide.)

15 MR. KING: Some other, more specific ground
16 rules that we feel should be applied in going through
17 the criteria, we used the framework of Appendix A of 10
18 CFR 50 as much as possible. In going through there,
19 where there was no substantial difference between CRBR
20 and LWR structures, systems, or components, we adopted
21 the words from Appendix A in their entirety.

22 Where we felt the intent of the criteria in
23 Appendix A applied to CRBR but we had to make some
24 changes either due to terminology differences or CRBR
25 systems that were a little different, we again tried to

1 maintain the wording as much as possible from the
2 Appendix A, and just made those changes necessary to fit
3 the CRBR terminology. Where there were unique
4 characteristics of the CRBR systems, we developed unique
5 criteria.

6 We also went back and looked at the principal
7 design criteria of SEFOR and FFTF, and we looked at the
8 ANS 54.1 standard, which is currently in draft form and
9 is being developed to address principal design criteria
10 or design criteria for LWR's. We used those documents,
11 and also in a general sense considered previous LMFBR
12 experience, in terms of areas that you could look at
13 that may prompt you to add another criteria.

14 MR. RAY: Mr. King, excuse me. On this list
15 there is no indication that you considered foreign
16 experience. Did you?

17 MR. KING: To the extent that we had it, yes.

18 MR. RAY: That phraseology arouses my
19 curiosity. Is it limited availability to you? I mean,
20 are they treating these things as secrets?

21 MR. KING: We have some general reports on
22 experience, like for instance with Phoenix reactor, and
23 some of the Japanese reactors. To the extent that
24 information is presented in those, yes, we have
25 considered it.

1 MR. RAY: You have not aggressively gone after
2 it? Is that what you meant?

3 MR. KING: I have not gone to try and find out
4 what their principal design criteria are, or tried to
5 get information specifically, specifically the types of
6 information that would address principal design
7 criteria.

8 MR. RAY: That is an interesting omission.

9 MR. AXTMANN: I am sorry. I don't know what
10 SEFOR is.

11 MR. KING: SEFOR is a reactor that was built
12 in Arkansas by General Electric. It stands for
13 Southwest Experimental Fast Oxide Reactor. I believe it
14 was a 20 megawatt oxide fuel --

15 MR. AXTMANN: Did it operate?

16 MR. KING: Yes, it operated.

17 MR. AXTMANN: And died?

18 MR. KING: I'm not sure why it was shut down.
19 Maybe Dick Becker could answer that a little better. He
20 was at the project.

21 MR. BECKER: I am Dick Becker, NRC staff, CRBR
22 Program Office.

23 The SEFOR reactor was a reactor that was
24 designed and built specifically to measure the doppler
25 coefficient in LMFBRs. It went through the experimental

1 program, and then it was shut down at the end of their
2 planned experimental program, and decommissioned.

3 MR. AXTMANN: In what era?

4 MR. BECKER: It shut down in 1972.

5 MR. MARK: When it was decommissioned, what
6 did they do about it? Did they just pile dirt on top of
7 it, or take the concrete away, or what?

8 MR. BECKER: No, it was decommissioned to
9 "possession only" status. They closed and sealed the
10 containment, removed the sodium and the fuel. They cut
11 any penetrations into the containment, sealed them, and
12 sealed the reactor cavity with a plate across the
13 cavity. It has intrusion alarms and water sensors, but
14 it is essentially in a status called "possession only."

15 MR. MARK: Thank you.

16 MR. AXTMANN: What power levels or flux levels
17 did they use?

18 MR. BECKER: Its design was 20 megawatts
19 thermal power. It had a large fuel element that gave
20 you the same temperature conditions that you would
21 expect in an operating commercial LMFBR.

22 MR. AXTMANN: Temperature, but not necessarily
23 flux?

24 MR. BECKER: That's right; slow power but high
25 temperature.

1 MR. CARBON: Go on, Mr. King.

2 MR. KING: The last item is one we touched on
3 before. We added criteria which changed existing
4 criteria that we felt we needed to such that we wanted
5 to reduce the likelihood of core disruptive accidents
6 sufficiently that they can be excluded from the design
7 basis.

8 MR. CARBON: Would you give an example of the
9 last half of Number 5 there, criterion addressing those
10 features?

11 MR. KING: As an example, we added a criteria
12 on fuel rod failure propagation, Criterion 59, I believe
13 the number is. That was added because failure
14 propagation was one of the ways in which you could get
15 into a core disruptive accident, an accident involving
16 the whole core. We added a criteria requesting that
17 either systems to detect propagation or features to
18 prevent propagation be added to the design.

19 MR. CARBON: Fine. You will be discussing
20 that one later?

21 MR. KING: That particular one will come up
22 later.

23 MR. CARBON: Fine. Go ahead.

24 MR. KING: In looking at the criteria, we had
25 to ask ourselves, how do we know they are complete?

1 (Slide.)

2 MR. KING: What we did was, we tried to
3 categorize the criteria into basic functions in which
4 they perform. This is the list of functions we came up
5 with. We went through and attempted to make sure we had
6 adequate criteria where there was one or multiple
7 criteria that addressed each one of these functions, and
8 satisfied ourselves that we had all of these areas
9 covered in terms of CRBR systems important to safety.

10 I did not bring a matrix that lays out 60
11 criteria against each one of these, but that could be
12 done, and we can do that.

13 MR. CARBON: I was writing when you said
14 that. On what basis did you say you satisfied yourself
15 it was complete?

16 MR. KING: We made this list to try to
17 describe the basic safety functions which we wanted the
18 criteria to address. We went through and matched up the
19 criteria to the appropriate safety function, and looked
20 at the systems, structures, and components. We looked
21 at those features that we felt were necessary to prevent
22 core disruptive accidents, and made sort of a
23 qualitative judgment that the criteria we have address
24 all of these functions, and we did not find any holes.
25 Let me put it that way.

1 MR. ZUDANS: On this list, as it stands, you
2 have an item, sufficient decay heat removal. I noticed
3 in the criterion you never really mention natural
4 circulation as a requirement. Did I miss that?

5 MR. KING: No. What we mention is decay heat
6 removal. The important function, we feel, is decay heat
7 removal.

8 MR. ZUDANS: Of course it is, but that's just
9 one mechanism.

10 MR. KING: Natural circulation is just one of
11 the ways in which you can remove decay heat.

12 MR. ZUDANS: Is it because you like to stay at
13 the high level of resolution and not go into specifics?

14 MR. KING: Yes, that's a major consideration
15 in these criteria.

16 MR. ZUDANS: I didn't quite like it the first
17 time, and I don't like it now, that that is not
18 explicitly mentioned.

19 MR. KING: You feel we should have a specific
20 criteria addressing natural circulation?

21 MR. ZUDANS: That is my primitive way of
22 thinking. You mention two loops and three loops, so you
23 are very specific, but on this aspect you are not.

24 MR. LIPINSKI: I have a general comment. It
25 seems like if you did not have a Clinch River design

1 before you, and you were given the task of writing
2 criteria, that you could still have written these
3 criteria. But having been given Clinch River, you are
4 specifically writing these criteria to fit Clinch
5 River. As we go through them, I will have comments on
6 various specific criteria, but somehow, it seems like
7 about the only concession you might have had to make is
8 whether it whether it was a loop or a puff type LMFBR;
9 but you should have been able to write a general set of
10 criteria without regard to the design, and leave it up
11 to the designer to meet those criteria, not the other
12 way around, that he writes the criteria to meet the
13 design.

14 MR. KING: We didn't try to fit the criteria
15 to the existing Clinch River design.

16 MR. LIPINSKI: I will comment on that, where
17 you have specific words deleted and they imply something
18 about the design, because you deleted certain words.

19 MR. KING: All right. We will get to those.

20 MR. CARBON: I do have a comment. I don't
21 want to push it more here, but I'm sure the question
22 will come up at the full committee meeting on how you
23 are sure that your list is complete. Frankly, this
24 presentation, your words, Tom, do not sound all that
25 strong to me, and I would anticipate that in the full

1 committee meeting, it might be well to have a little bit
2 stronger argument or statement.

3 Go ahead.

4 MR. AXTMANN: Excuse me. I don't see any item
5 relating to radiological safety of the operators. Is
6 that something that was also left out in 10 CFR 50 for
7 LWR's?

8 MR. KING: No, radiological protection of the
9 operators is addressed in 10 CFR 20 and 10 CFR 100.

10 MR. AXTMANN: And it is not --

11 MR. KING: We did not try to duplicate what
12 was covered in those portions.

13 MR. AXTMANN: This talks only to design. I
14 don't think 10 CFR 20 and 100 do talk to design.

15 MR. KING: No, they talk to the limits that
16 you have to meet. That is true.

17 MR. AXTMANN: I see. You don't see any
18 conflict there, when you are talking about general
19 criteria relating to safety? These are addressing the
20 safety to the public, but you don't see a conflict about
21 not specifically dealing with that?

22 MR. KING: No, I don't see any conflict.

23 MR. RAY: On this point, there are several
24 places, as I remember it in reading this, where
25 consideration of the operator is evident. Control room

1 habitability is one of the areas. Aren't there other
2 criteria?

3 MR. STARK: Criteria 17 on control room
4 adequate radiation protection exists in the criteria
5 right now.

6 MR. RAY: Is that the only one?

7 MR. STARK: I was just turning pages.

8 MR. KING: I think that's the only one that
9 specifically mentions a dose rate.

10 MR. AXTMANN: I see an inconsistency there.

11 MR. RAY: I agree.

12 MR. MARK: I agree as well. It is a design
13 matter, quite apart from the rad or rem limits, when you
14 think about the design of making inspection and
15 maintenance as radiation-free as possible. Just setting
16 a limit does not do that for you. The way you lay out
17 the pipes and so forth may very well affect that.

18 (Slide.)

19 MR. KING: This is just a vu-graph to give you
20 an idea of the number of criteria that changed in the
21 version that's in the PSAR and the site suitability
22 report from the 1976 version. They started with 55
23 criteria in Appendix A to 10 CFR 50, omitted nine, added
24 ten unique ones, for a total of 56, and of the 46 they
25 used from Appendix A, 23 were modified in some way to

1 apply to CRBR, and 23 were adopted without change.

2 In the version that we are proposing, starting
3 with the 55 criteria in Appendix A, we have omitted
4 seven. We have 12 unique ones for Clinch River, for a
5 total of 60, and of the 48 that were used from Appendix
6 A, we have modified 27 in some way to apply to Clinch
7 River.

8 MR. CARBON: I do not understand the
9 distinction between the two major groups. They both
10 start out, of the 55 criteria, it says, in one case nine
11 are omitted, and another are seven.

12 MR. KING: This is the version currently in
13 the PSAR and the site suitability report, the one that
14 was developed back in 1976. We have taken that version
15 and we have made some changes to it, and these are the
16 numbers that now apply to the version that we are
17 proposing.

18 MR. CARBON: So in the new version you have
19 only omitted seven instead of nine?

20 MR. KING: That's correct.

21 (Slide.)

22 MR. KING: What I wanted to do was run through
23 briefly the criteria, the ones that are identical to
24 Appendix A, just to show you which ones those are and go
25 into the ones where we've made some changes, and then

1 the unique ones, and the ones we omitted.

2 There were a total of 21 we made no change
3 to. The numbers in parentheses are their corresponding
4 numbers, and it is from Appendix A to 10 CFR 50.
5 Quality standards and records we didn't change. Fire
6 protection, sharing of systems, structures, and
7 components, reactor inherent protection, suppression of
8 reactor power oscillations, containment design,
9 inspection, and testing of electrical power systems,
10 protection of system reliability and testability,
11 separation of protection and control systems, quality of
12 reactor coolant boundary, capability for containment
13 leakage rate testing, provisions for containment testing
14 and inspection, piping systems penetrating containment,
15 primary containment isolation, inspection of primary
16 containment isolation, inspection of containment
17 atmosphere cleanup system.

18 Testing of containment atmospheric cleanup
19 system, control of releases of radioactive materials,
20 prevention of criticality in fuel storage and handling,
21 monitoring, fuel and waste storage, protection against
22 anticipated operational occurrences.

23 (Slide.)

24 MR. RAY: Perhaps I missed it because I wasn't
25 listening hard enough, but on plant security, is this

1 different from 10 CFR 50, Appendix A criteria?

2 MR. KING: Plant security?

3 MR. RAY: For this plant.

4 MR. KING: There is no Appendix A criteria
5 that deals with plant security.

6 MR. RAY: Is there any criterion that deals
7 with plant security? Will we hear that later?

8 MR. KING: There is no general design criteria
9 or principal design criteria that deals with plant
10 security. There is Part 73 to 10 CFR 50 that deals with
11 plant security.

12 MR. RAY: I see.

13 MR. KING: We did not put a criteria in
14 because we felt that that section in the Code of Federal
15 Regulations dealt with that subject.

16 MR. RAY: What you are saying is, that is
17 automatically controlled?

18 MR. KING: That is automatically controlled.

19 MR. RAY: Because it is a regulation that
20 applies to this plant?

21 MR. KING: That's correct.

22 MR. RAY: Thank you.

23 (Slide.)

24 MR. KING: Okay. There are 27 criteria that
25 we made some change to. This is the criteria for

1 Appendix A. There are four that I put an asterisk next
2 to that indicate major change. All the others are
3 changes really that deal with terminology and making
4 sure that we have the right words that describe the CRBR
5 systems.

6 I plan to talk later specifically about the
7 ones with the asterisks, the ones that are major
8 changes. I did not intend to talk specifically about
9 the ones that we felt were minor editorial or technology
10 type changes.

11 (Slide.)

12 MR. KING: This is the second half of that
13 list. The ones that had minor changes.

14 (Slide.)

15 MR. KING: These are the criteria that are
16 unique to Clinch River. The last two are new from the
17 version that was developed back in 1976. The remainder,
18 although they are unique, they were developed back in
19 1976. I don't believe we have made any changes to the
20 ones that were developed back in the previous review.

21 MR. AXTMANN: I have another general
22 question. This is the first CRBR subcommittee meeting I
23 have attended, so perhaps I am the only one in
24 ignorance. Why is this called the CRBR criteria rather
25 than fast reactor criteria?

1 MR. KING: We are writing these criteria
2 specifically for CRBR. We are not trying to address the
3 general LMFBR's. That is one of the ground rules.
4 Maybe I didn't mention it earlier, but that was one of
5 the ground rules we were going on. We are only
6 addressing CRBR.

7 MR. CARBON: Would you straighten me out on
8 something? I have some correspondence here that says
9 there are four new items, Criteria 57 to 60, but Number
10 58 shows up in your first slide, your first list,
11 anyway, as one that is identical to an earlier one.

12 MR. KING: Fifty-seven and 58 were added in
13 this current version.

14 MR. CARBON: Why is 58 in the first chart that
15 says CRBR criteria identical to 10 CFR 50 Appendix A?

16 MR. KING: Fifty-seven and 58 are included in
17 10 CFR 50. They are ones that were excluded in the
18 original version, but we now believe they should be
19 added into the original criteria. We have taken 58
20 verbatim and made no changes to it, and included it in
21 the CRBR criteria. That is why it shows up in the list
22 of no changes. That is, no changes from Appendix A.

23 MR. CARBON: Okay, so when you have added four
24 new items, that means compared to 1976?

25 MR. KING: That's correct.

1 MR. CARBON: Not compared to the LWR criteria.

2 MR. KING: That's correct. There will be some
3 vu-graphs coming up that address the major changes from
4 the 1976 version. Those four are on that list.
5 Fifty-eight is one of them.

6 These are the criteria from Appendix A that we
7 did not include.

8 (Slide.)

9 MR. KING: Reactor coolant makeup, Clinch
10 River design, and the criteria have features that
11 prevent the loss of reactor coolant, things like guard
12 vessels and elevated piping. Therefore, we didn't see
13 the need for a reactor coolant makeup system on Clinch
14 River, and we did not include that criteria in Appendix
15 A.

16 Emergency core cooling, inspection and testing
17 of emergency core cooling, we did not include those
18 because Clinch River has a captive cooling inventory.
19 They have criteria that require this. Therefore, we did
20 not see the need for an emergency core cooling system.

21 In addition, for decay heat removal, we have
22 added some additional requirements over and above what
23 you find in the LWR criteria to ensure decay heat
24 removal. Containment heat removal, there were no design
25 basis events that required a containment heat removal

1 system. Therefore, we did not include a criteria for
2 the inspection and testing of that system.

3 MR. LIPINSKI: Do LMFBR's require pressure
4 system in containment?

5 MR. CARBON: Yes.

6 MR. LIPINSKI: Then why wouldn't Clinch River
7 have to do something equivalent?

8 MR. CARBON: The leakage testing.

9 MR. KING: We have left the criterion for
10 leakage testing. This is for containment.

11 MR. LIPINSKI: Aren't there some sodium fires
12 postulated within containment? Not the big one, but
13 aren't there minor fires?

14 MR. KING: Yes.

15 MR. LIPINSKI: They heat the containment, so
16 how do you remove that heat after it's heated?

17 MR. KING: Conduction out through the walls of
18 containment.

19 MR. LIPINSKI: How long do you wait?

20 MR. KING: You can wait indefinitely. Those
21 fires do not raise the peak temperature above the design
22 temperature or pressure.

23 MR. LIPINSKI: But if I have anything that
24 heats the containment, am I not concerned about the heat
25 removal from the containment?

1 MR. KING: If it heats at such that it exceeds
2 its design temperature, yes.

3 MR. LIPINSKI: Well, even if I get to the
4 limit, isn't it still important to be able to cool that
5 containment down?

6 MR. KING: It's important to keep the
7 containment below its design temperature and pressure.
8 If you need a cooling system to do that, then that
9 cooling system should be part of the design. If you
10 don't need a cooling system to do that, then there is no
11 sense of requiring that in the design. That is the
12 thought process we went through.

13 MR. LIPINSKI: If I were to do a PRA and look
14 at the time sequence of events from the time the
15 containment was heated until it could cool by natural
16 convection and not have access to the containment, am I
17 vulnerable as a result of that?

18 MR. KING: No, there is no reason to get into
19 containment for decay heat removal or getting into safe
20 shutdown.

21 MR. LIPINSKI: All of the equipment inside is
22 qualified to those specific conditions for an indefinite
23 time period at high temperature?

24 MR. KING: For the time period demanded by the
25 event. I wouldn't say it is indefinite. You look at

1 what the duration of the event is, and qualify it for
2 that period of time with some conservatism. Again, all
3 the controls for decay heat removal and safe shutdown
4 are in the control room. There is no monitoring that
5 has to be done.

6 MR. KASTENBERG: Before you remove that, I
7 have a question. There may be some events beyond the
8 design basis which require decay heat removal, and there
9 may be a system or systems to cope with that. What
10 system would you use?

11 MR. KING: We are developing an appendix to
12 our SER that will address design criteria for those
13 systems that are used to mitigate events beyond the
14 design basis. Maybe I didn't make it clear in the
15 beginning. The principal design criteria address those
16 systems, structures, and components that deal with
17 design basis events only. We are dealing with design
18 basis events in a separate --

19 MR. CARBON: Could you move your microphone
20 up, or do you have one?

21 MR. KING: Is that better?

22 MR. ZUDANS: Is there any --

23 MR. KASTENBERG: You say there will be a
24 meeting in November?

25 MR. STARK: The meeting in November is on core

1 disruptive accidents. I guess that will be a piece of
2 it. What Tom is saying is, we have an appendix to the
3 SER that will cover beyond design basis accidents, and
4 it will be free-standing, and it will include our
5 assessment or criteria, and our evaluation of beyond the
6 design basis accidents and systems, so I think that --
7 I'm not exactly sure. We don't have the agenda worked
8 out for the November session, but as I recall, that was
9 going to describe or discuss the status of our review on
10 hypothetical core disruptive accidents, and I don't know
11 to what extent it will include the assessment of
12 containment heat removal systems.

13 I think it is just energetics right now, but I
14 guess we could amend the agenda.

15 MR. KASTENBERG: At some time we ought to hear
16 about criteria specifically, if there are systems to
17 mitigate beyond the design basis.

18 MR. ZUDANS: Tom, could you as you go later on
19 indicate where the design basis is defined in the
20 criteria? These design criteria are only to deal with
21 design basis events. The events themselves, at least, I
22 can't clearly read in these criteria.

23 MR. KING: Design basis events are not defined
24 in the criteria. They are defined in the PSAR.

25 MR. ZUDANS: There is some kind of a gap, at

1 least in my understanding. Unless I have a set of
2 design basis events defined, I don't see what I am
3 applying these criteria to. In other words, I have to
4 go to a document that is not part of this set. There is
5 a gap in the logic that I don't understand.

6 MR. STARK: The second presentation today will
7 be discussing design basis accidents.

8 MR. ZUDANS: Is there reference in this
9 criteria to that set?

10 MR. KING: The criteria themselves do not
11 reference that set. The introduction to the criteria --

12 MR. ZUDANS: In other words, this is like a
13 loose animal. I can walk it all over the block. It is
14 not advertised as anything specific. I think that link
15 has to be somehow fixed, because it would be quite
16 different if you change your design basis.

17 MR. KING: I agree. I think maybe that's a
18 good point. If you added a new event to the design
19 basis, it could affect the criteria. I agree with
20 that.

21 MR. ZUDANS: Sure. It has to be a very
22 specifically defined thing in this set and the other
23 set.

24 MR. KING: That is a good point.

25 MR. CARBON: Can I go back to your question or

1 comment, Bill? I wasn't really listening to your
2 question. There are no additional criteria beyond
3 these. I'm not sure I caught the intent of your
4 question.

5 MR. KASTENBERG: The intent is basically
6 this. If they are going to have systems, whether they
7 be containment systems or other, that would deal with
8 events beyond the design basis, some criteria would have
9 to be established for those systems. I got the feeling
10 that the process of evolving those criteria is taking
11 place now, and at some point we would want to hear what
12 criteria they come up with.

13 MR. CARBON: Bob, back on about their second
14 or third slide, Number 5 says, the criteria address
15 structures, systems, and components associated only with
16 a design basis event, and those features which reduce
17 the likelihood of CDA's, and I don't think there are any
18 criteria for the DBA.

19 MR. STARK: As I indicated earlier, we are
20 going to have an appendix to the SER dedicated to beyond
21 the design basis accidents. In that particular
22 appendix, we will look at the criteria, the acceptance
23 criteria, and also our evaluation, so I think what we
24 are saying here is that what we are looking at today is
25 design basis accidents and the criteria associated with

1 the design basis accident, and what Dr. Kastenberg is
2 saying is true. For those systems that only exist for
3 beyond the design basis accident, they will have a
4 criteria associated with those, and those will be the
5 subject of the appendix to the SER.

6 MR. CARBON: Criteria for beyond the DBA?

7 MR. STARK: That's correct. We will have to
8 use something for our acceptance review and evaluation,
9 and Dr. Kastenberg is correct. We will have those as a
10 part of our particular appendix in that review.

11 MR. CARBON: Then you are proposing next week
12 at the full committee meeting we will only be discussing
13 part of the criteria.

14 MR. STARK: We will be discussing the criteria
15 associated with design basis accidents. That's
16 correct. Just in the same fashion as the general design
17 criteria only address design basis accidents for
18 light/water reactors. There is nothing inconsistent
19 there.

20 MR. CARBON: Except if I understand what you
21 are saying, you will end up with principal design
22 criteria for CRBR that address beyond the DBA, and you
23 don't have those on the LWR.

24 MR. STARK: That is because we have made an
25 attempt here to evaluation a beyond the design basis

1 spectrum, and we have to develop some sort of measure or
2 yardstick to do our evaluation to.

3 MR. CARBON: All I am trying to do is get
4 consistency clear in my mind. Still on LWR's, we have
5 no criteria for ATWS, I guess.

6 MR. MORRIS: This is Bill Morris, NRC staff.

7 You might recall that at an earlier meeting we
8 presented to you some of the general design criteria
9 that we were developing for events beyond the design
10 basis. We don't call those principal design criteria.
11 Those are special ad hoc criteria developed specifically
12 to use in our evaluation of CDA's. Those are on the
13 record. They were incorporated in the transcript of a
14 previous meeting, and you may recall those.

15 MR. CARBON: But those are not principal
16 design criteria.

17 MR. MORRIS: No, the principal design criteria
18 for CRBR as for an LWR are those criteria that are
19 employed to assure that you will not develop a severe
20 accident such as a core disruptive accident. That is
21 what they are there for. However, recognizing that such
22 accidents may occur, the staff has decided that it
23 should, and this follows the lead of the applicant, that
24 we should have some provisions for accidents beyond the
25 design basis.

1 So, we break things down into those two
2 categories. The criteria that are for the beyond design
3 basis events should not be confused with principal
4 design criteria. We are following, as Rich said, new
5 criteria for beyond the design basis.

6 May I make one clarification of something that
7 was brought up before? What you have here in the
8 principal design criteria is an attempt to recognize the
9 general kind of events that could occur. It is not
10 necessary, we contend, to know the details of the
11 assumptions made in examining design basis accidents in
12 Chapter 15 in order to have a complete set of general
13 design criteria.

14 What we are talking about here are the general
15 type of events, the external events such as earthquakes,
16 but the general design criteria for LWR's do not specify
17 what the earthquake is. Fires are postulated, but we
18 don't specify where the fire is going to be or what its
19 intensity is. So, that's the distinction with regard to
20 Mr. Zudans' question. What we're doing here, and what
21 will be done in Chapter 15 of the SER --

22 MR. ZUDANS: I understand your point, but of
23 course then it could be appropriate to remove references
24 to design basis events. You can describe the same
25 objectives on a higher scale, which I would really like

1 to see. You are giving criteria that relate to the
2 product, and not your assumed behavior of the product.
3 You say you want a certain level of risk to the public
4 not to be exceeded, and you present criteria without
5 reference to design basis events.

6 I think your reference has in mind a very
7 specific set, and that is what bothers me.

8 MR. MORRIS: I think that may be the
9 distinction. We are talking about the principal design
10 criteria, so we must be talking about generalized
11 postulated events.

12 MR. ZUDANS: Correct; but you make
13 reference --

14 MR. MORRIS: We will be talking about specific
15 criteria in the SER and the PSAR, which will be much
16 more detailed.

17 MR. ZUDANS: But isn't it true that these
18 criteria refer to the design basis events that are
19 listed? They are written specifically to satisfy the
20 results of design basis events that are listed in
21 Chapter 15.

22 MR. MORRIS: These criteria recognize that
23 there are going to be specific design basis events that
24 must be mitigated, but they don't specify what those
25 events are in detail.

1 MR. ZUDANS: But what is behind it is a
2 knowledge of that set. Also behind that is, the fact
3 that one of those items in that chapter changes the
4 whole general criteria. And I think that is too low a
5 level of criteria. It should be higher up.

6 MR. MORRIS: I would contend that the kind of
7 events that are recognized here in the principal design
8 criteria are, for example, reactivity events, sodium
9 fires, ordinary fires, external events such as tornadoes
10 and seismic events. Those general kinds of events are
11 recognized here, but as I say, when you change the level
12 of intensity of the design basis earthquake, it doesn't
13 mean you have to go back and change a principal design
14 criteria. That means you change the specific criteria
15 for the components in the plant.

16 MR. ZUDANS: Let's take a specific example.
17 Supposing right now there is no primary coolant pipe
18 break that is postulated as a design basis event in the
19 LMFBR, but there is such in an LWR. The LWR criteria
20 takes care of that guillotine type break, don't they?

21 MR. MORRIS: Yes, and I agree with you that we
22 have recognized in general here that we do not have to
23 deal with a LOCA event as we do for a light/water
24 reactor.

25 MR. ZUDANS: Why don't you? Suppose three

1 weeks from now you change your mind for whatever reason.

2 MR. MORRIS: If that were the case, we would
3 have to re-examine these criteria.

4 MR. ZUDANS: Well, that proves to me that the
5 criteria are at too low a level, too precise, too much
6 resolution. They have to be elevated to a level where
7 the choice of events does not affect the criteria.

8 MR. MORRIS: However, I must point out that one
9 of the criteria -- I cannot recall the number right
10 now -- does address the possibility of broken pipes and
11 leaks. It just doesn't do it in the same way as done
12 for the LWR criteria. I would argue that the LWR
13 criteria are possibly at too low a level in the sense
14 that they recognize the existence of certain pieces of
15 equipment, and they speak to equipment in addressing
16 LOCA. In the criteria we are developing here, I think
17 they say that you must consider the possibility of leaks
18 in pipes and fires, so in that sense I think we are
19 fairly general.

20 Although I don't want that remark to be taken
21 as something, that there is something inadequate about
22 the LWR criteria, you will note that some of those that
23 are missing from our set now do correspond to specific
24 pieces of equipment to mitigate LOCA.

25 MR. LIPINSKI: I would like to comment on

1 that, because that applies to my earlier statement. The
2 way you wrote the criteria, you had knowledge of the
3 plant design, and your explanation goes on to say this,
4 and as a result, you wrote the criteria with respect to
5 a LOCA, acknowledging the design rather than writing the
6 criteria in such a way that the design was forced to put
7 in guard vessels and guard pipes.

8 MR. MORRIS: I would think what we have is a
9 general understanding of the fact that the LMFBR systems
10 will be operating at lower pressures.

11 MR. LIPINSKI: That is not the issue.

12 MR. MORRIS: That is taken into account in not
13 stressing the need for mitigating a large blowdown due
14 to a pipe break.

15 MR. LIPINSKI: I am not talking about that. I
16 am talking about pumping the system dry and letting the
17 sodium flow out. The design has acknowledged that that
18 has happened, and there are features to prevent it, but
19 the criteria should have dictated that these features be
20 included, and then the design meets them. The way you
21 wrote the criteria, you assume that equipment is
22 available.

23 MR. KING: I think the criteria do not use the
24 words fire in the vessel or piping.

25 MR. LIPINSKI: I would rather look at the

1 words later.

2 MR. CHECK: This is Paul Check of the staff.

3 This is an interesting discussion. I think
4 you two are saying something that is similar.
5 Variations on a theme. If I understand you, it sounds
6 like you are saying that we have acknowledged perhaps a
7 little too much in the design, and the criteria are set
8 at too low a level. As a matter of fact, that is
9 acknowledging design also, but I have to say what Bill
10 Morris has said and what Tom King has said. We have not
11 embarked on this in an attempt to establish a new basis
12 for doing this part of our business of licensing.

13 What we have tried to do is search for a basis
14 for licensing this reactor, and we are doing it with all
15 the tools and experience we have in building light/water
16 reactors. I think what we are trying to construct here
17 are design criteria which are close analogs, at least
18 the set is a close analog to what the set for
19 light/water reactors is.

20 I think the criticisms that you make of it can
21 also be leveled at those for light/water reactors.
22 After all, those criteria were developed from experience
23 with light/water reactors. They didn't come down from a
24 cloud. They were a distillation of a lot of experience
25 and knowledge about what light/water reactors are, and

1 we are doing something about that now. We certainly
2 admit to that. We are being influenced as we converge
3 by the design itself.

4 What we are trying, and we hope we will not
5 lose, is the attainment of this objective. That is, to
6 establish clearly a basis for licensing a plant. The
7 basis in law for licensing this plant. Not establishing
8 a new point of departure for licensing LMFBR's.

9 MR. LIPINSKI: I will go back to the subject
10 of LOCA's. Compared to LWR's, you do not have the high
11 pressure, but you still have the capability of taking
12 the system inventory and pumping it all over the
13 containment floor. There should be a very specific
14 criteria that says you will contain the liquid from a
15 rupture in the criterion. Then you come back and you
16 say, we have equipment for the guard vessels and guard
17 pipes.

18 MR. CARBON: I think there is something that
19 came out from the staff in an earlier discussion that
20 was more of a statement that this is an iterative
21 process.

22 MR. CHECK: That is certainly true.

23 MR. CARBON: You look at the unit itself, and
24 the design, and you go back and address the design
25 itself. I think you can go about it any way you wish.

1 MR. CHECK: And we also go into -- there is
2 the point that maybe here we have a point where
3 reasonable men can disagree. What you are saying, Walt,
4 makes some sense in light/water reactors. If they all
5 of a sudden decided that meteor strikes are going to be
6 considered, then there would be a criterion to cover
7 them. There is some knowledge. I am trying to avoid
8 pejorative terms, but the establishment of the set is
9 influenced by the knowledge of what reactors are and
10 what design events are.

11 MR. LIPINSKI: Let me take --

12 MR. CARBON: I think maybe we had better move
13 on.

14 MR. LIPINSKI: I've got another example.

15 (Slide.)

16 MR. KING: What I want to talk about next are
17 the major changes from the 1976 version. There are
18 eight of these I am going to talk about.

19 The first one is the principal design criteria
20 number 8, reactor design. We have added a requirement
21 to that criteria that requires the design to provide
22 means to prevent fuel management errors. We use the
23 words from ANS 50.1, which has that same requirement and
24 that same specification, that same criteria.

25 The rationale was that fuel management errors

1 are not a design basis event at Clinch River as they are
2 in LWR's. Therefore, we felt if they are not going to
3 be included as a design basis event, then features
4 should be required to prevent them. That is why we have
5 added that additional statement.

6 MR. LIPINSKI: I am puzzled by that, because
7 why are they not part of the design basis event? They
8 are certainly probable. They are not completely
9 impossible. I have no disagreement with what you have
10 said here, but I am surprised that it says, since such
11 errors are not included in the CRBR design basis event
12 spectrum. I wasn't aware that they weren't. The
13 question is, why weren't they?

14 MR. KING: They weren't because there are
15 things to prevent them, discriminator posts and --

16 MR. LIPINSKI: Yes. Well, the probabilities
17 are very small, but some of these devices can fail.
18 They are not totally infallible, and the question is,
19 what happens if. Is it a disaster, or is it something
20 minor? Here again, you are taking an assumption that
21 the design has included these features to prevent it as
22 opposed to requiring this in the criteria and then
23 making sure that the design comes up with features to
24 live up to the criteria.

25 MR. KING: We are requiring those things in

1 the criteria, and we are looking at them to see if they
2 are adequate. You are saying maybe we had it backwards
3 because the features were there before we stuck the
4 words in the criteria.

5 MR. LIPINSKI: That's correct. You looked at
6 the features and didn't have it in the criteria, and now
7 you've modified the criteria to be sure the features are
8 included.

9 MR. KING: This is a case where we have looked
10 at design basis events and decided we needed to write
11 some additional words in the criteria to be compatible
12 with the design basis events.

13 MR. ZUDANS: I would like to add one comment.
14 Whatever you said is correct, and I also think what I
15 said is correct. There is too strong an emphasis on
16 principal design criteria being subservient to design
17 basis events. Read number 24 that you have there. I
18 can't help but feel uncomfortable that there is a
19 God-sent set of design basis events to which this set of
20 criteria is subservient. I don't like that reference
21 and I think that's what's wrong with it, not that the
22 criteria are wrong.

23 MR. CHECK: Well, you certainly know, Mr.
24 Zudans, that it is every bit as difficult to establish a
25 set of design basis events as it is to establish --

1 MR. ZUDANS: That seems to be the primary
2 thing. This is subservient to that. That is what is
3 wrong, in my opinion. Maybe the wording is wrong, not
4 the content.

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. CHECK: They are linked.

2 MR. ZUDANS: They are not linked.

3 MR. CHECK: They are linked.

4 MR. ZUDANS: They are not linked. They are
5 totally dependent, according to this. Read number 24.

6 MR. CHECK: I have never thought --

7 MR. ZUDANS: Well, read number 24.

8 MR. CHECK: Oh, I understand the dependence,
9 yes. One is dependent on the other.

10 MR. ZUDANS: Not so. The one is primary and
11 the criteria is secondary. All you do is make sure this
12 design copes with design basis events. That means there
13 is a God-sent set made by humans that these criteria now
14 are out of the set, and I think it should be the other
15 way around, not that they would change in content.

16 Design basis events are determined by design.
17 The design either can have a limit or may not have. It
18 is a design. Okay? The principal design criteria
19 should only reflect what the design must have, not to
20 endanger the public health and safety. That is all you
21 are concerned with.

22 A natural phenomena is very easy because those
23 events will exist. You can define seismic events and
24 extreme phenomena. That is fine. That has nothing to
25 do with the design. There is a set that the design is

1 capable of experiencing, and that set is very
2 design-specific, and the way the design criteria are
3 written now, they seem to be subservient to that set.

4 MR. CHECK: That is history. The reactors
5 were here first, and the design events followed. That
6 goes back further than I do, so I am not sure. But the
7 codification of design events certainly began before
8 design criteria.

9 MR. CARBON: Zenons, if I understand
10 correctly, for example you are saying in number 24 you
11 would delete the last comment and provide reactivity
12 control systems, period.

13 MR. ZUDANS: That is correct.

14 MR. CARBON: Let's leave that for your
15 consideration at present.

16 MR. ZUDANS: But there are many places where
17 that shows up.

18 MR. LIPINSKI: I have no trouble with this
19 criteria requiring the two independent reactivity
20 control systems, but in looking at the rest of the
21 criteria I cannot figure out what activates there.

22 I can have a PPS system that comes out with a
23 common signal that activates two independent reactivity
24 control systems, but I cannot interpret your criteria as
25 saying anything upstream of this is duplicated.

1 MR. KING: Maybe the words need to be cleared
2 up, but certainly the intent of that is to have entirely
3 independent systems.

4 MR. LIPINSKI: I know what your intent was. I
5 read this, but I cannot come out with that
6 interpretation.

7 MR. CARBON: Does number 24 say that?

8 MR. LIPINSKI: That is the mechanism. If I go
9 back and look at the criteria for electronics, I cannot
10 get --

11 MR. CARBON: The system does not have any
12 criteria for electronics?

13 MR. LIPINSKI: As I say, I have no trouble
14 with 24, but when I go back and look at the other
15 criteria I cannot match it up for getting duplication.

16 MR. CARBON: Yes, because you are saying
17 systems does not include electronics, by your
18 definition?

19 MR. LIPINSKI: There are other criteria that
20 do cover this, but when I read them I cannot get the
21 words that say I have to have that duplicated to match
22 up with number 24.

23 MR. KING: I am not sure which criteria you
24 are talking about --

25 MR. LIPINSKI: Number 19.

1 MR. KING: -- it is referring to.

2 MR. LIPINSKI: Reactivity control? I do not
3 think that is your definition because criteria 19 is
4 protection. Eighteen is protection system functions.
5 Nineteen is protection system reliability and
6 testability. Twenty is protection system independence.
7 And somewhere in one of those three I would have to come
8 out with the idea that I have two systems that are
9 interacting with number 24, and I do not.

10 MR. CARBON: I guess I do not have the feeling
11 that your last statement is necessarily true. I can
12 interpret 24 to be standing on its own.

13 MR. LIPINSKI: You do not have reactivity
14 control defined in the front, do you?

15 MR. KING: No, we do not.

16 MR. LIPINSKI: It is a question of what the
17 definition of reactivity control is. Can you not
18 include the electronics or include the sensor all the
19 way? We have other systems that deal with electronic
20 inputs.

21 MR. CARBON: I can include electronics in the
22 control system, if I use the word "system" by a broad
23 definition.

24 MR. LIPINSKI: I think you will find in LWR
25 terminology that reactivity control are the reactivity

1 devices.

2 MR. CARBON: Quite so. But how about the word
3 "systems"?

4 MR. LIPINSKI: It is the same. I would say
5 there is an ambiguity in the specification.

6 MR. KING: We can take a look at our words to
7 clear that up. I do not have a problem with that.

8 Let us talk a little bit more about 24. As I
9 said, the intent was to require two totally independent,
10 redundant reactivity control systems -- that is, from
11 sensor to absorber rod. This requirement was added for
12 a couple of reasons.

13 One, in the previous review back in the '76
14 time frame, one of the conclusions was that we should
15 have two totally independent, diverse, redundant
16 reactivity control systems. That was primarily thought
17 of in LMFBRs that if you had an accident that caused
18 sodium boiling or voiding in the core you would not have
19 the systems that you had in LWRs. It was then felt that
20 having a system that will scram the plant reliably was
21 very important.

22 Again, we do not have boron injection
23 capability -- that kind of thing. Therefore, we had to
24 rely on the fast shutdown systems that had to be
25 equivalent to an LWR to reduce the likelihood that we

1 will have an event where the plant does not scram, that
2 the CRBR should have two independent shutdown systems.
3 That is why we reworded the requirement to state that.

4 We also added a statement in there on shutdown
5 margin which specifies not only the plant has to shut
6 down, but it specifies that it has to be enough to
7 terminate the event.

8 These are really the only systems that add
9 negative reactivity and we wanted to be specific on the
10 reactivity insertion requirements for these systems, so
11 we added that as an additional requirement.

12 MR. MARK: On this general point, there are in
13 the CRBR design, as it happens, two systems which I
14 guess when you have gone over them will meet the
15 criterion.

16 MR. KING: As of a couple of weeks ago, there
17 were not.

18 MR. MARK: Well, you are going to examine them
19 with this criterion in mind.

20 MR. KING: That is correct.

21 MR. MARK: I think as it happens one of
22 those -- I believe it is one, and I am not sure whether
23 it was both -- one of those will act without any motive
24 power while it is acting -- any electrical motors or
25 anything. That is, if you have a complete loss of

1 power, one of the scram systems still works.

2 MR. KING: Both scram systems will work on a
3 loss of power.

4 MR. MARK: I can imagine a scram system which
5 requires a motor to push the rods around. I guess BWRs
6 have such things. It would not be wrong in the criteria
7 to say that at least one of them must work in the event
8 of a total loss of offsite power.

9 MR. KING: I think there is a criterion -- I
10 cannot remember the number -- that talks about that
11 situation, basically a fail-safe-type criterion that
12 says on loss of power or some other phenomena that the
13 system has to go to a safe configuration.

14 MR. MARK: I see. If that is the case, I
15 missed it.

16 MR. CARBON: You will give consideration to
17 Dr. Zudans' comment about deleting all or part of the
18 last clause?

19 MR. ZUDANS: Mr. Chairman, I would like to add
20 something to that comment. At least in my preliminary
21 thinking it would be completely acceptable to define
22 design basis events in terms of its probability of
23 occurrence. You could say somewhere in the beginning of
24 the criteria that the design basis should include all
25 design basis events that have a probability of X per

1 reactor year.

2 MR. CARBON: Having made that offer,
3 suggestion, whatever, let us then go on.

4 MR. KING: Criterion 25 is really -- follows
5 directly from 24. Twenty-five addresses the control
6 systems as they anticipate operational occurrences.
7 Twenty-five addresses them as they postulate accidents.

8 MR. CARBON: Excuse me. Twenty-five is
9 identical to 24, except for the last six words. What is
10 the difference? Twenty-five would appear to be
11 incorporated in 24.

12 MR. KING: We tried to follow the -- Their 25
13 does not require an independent capability of the
14 systems to shut down the plant. Their 25 requires a
15 combined capability. The change we made to 25 was to
16 use basically the same words that we added in 24 -- that
17 we required an independent capability.

18 MR. CARBON: Maybe you and the other people
19 understand that, but I just plain do not understand why
20 you have 25, why it is not incorporated in 24.

21 MR. KING: You could combine 25 and 24, there
22 is no question. We did not attempt to do that because
23 we were not trying to redo the format of the lightwater
24 criteria. We were trying to stick to the format as
25 close as possible. They had a 24 and 25.

1 MR. MARK: Just because they mucked that up,
2 there is no reason you have to follow that here.

3 MR. KING: Certainly we can go back and try to
4 improve on what they have done. We did not try to do
5 that. We felt that if the words they had got the
6 message across, we used that, and if the format got the
7 message across, we used that format.

8 Thirty-five, reactor residual heat extraction
9 system. That is really the decay heat removal system.
10 What we did is change the criteria to require
11 independence and diversity in the design. Redundancy
12 was already included in the words. We put a statement
13 in to require that the coolant used in the reactor -- we
14 required that at least two flow paths remain available
15 for decay heat removal following a single failure.

16 MR. LIPINSKI: Do you think your criteria
17 requires a separate RHR system for the main heat
18 transport system?

19 MR. ZUDANS: No, it does not.

20 MR. KING: We require diversity.

21 MR. LIPINSKI: I can give you diversity, but I
22 can still use the main pipes. You have not defined your
23 diversity as to whether I have to have a separate pipe
24 from the reactor vessel different from the heat
25 transport pipe.

1 MR. KING: No. When we implement the design
2 we will decide whether the degree of diversity is
3 sufficient or not. We did not try to define that in the
4 criteria, that is true.

5 MR. LIPINSKI: That is what is bothering me.
6 I think the criteria should be more specific and refer
7 to the main heat transport system and a separate diverse
8 system that is different.

9 MR. KING: We thought about that. In fact, we
10 had some words at one time generated to do that. But it
11 seemed to us the important feature was flow paths. We
12 wanted multiple flow paths to remove decay heat.
13 Whether they were part of the normal HTS system or part
14 of another system did not seem to be the important
15 point.

16 MR. LIPINSKI: Well, this is the problem with
17 LWRs right now because the criteria were not that
18 specific to say that there should have been a separate
19 full pressure residual heat removal system separate from
20 the main heat transport system, and you have an
21 opportunity now to be very specific in your criteria and
22 not repeat that LWR mistake.

23 Now do you think your criteria prevents
24 once-through systems?

25 MR. KING: Systems that remove heat?

1 MR. LIPINSKI: Do not recirculate, where I
2 just draw water from a tank and shove it out as steam.

3 MR. KING: I think the criteria would permit
4 that, yes.

5 MR. LIPINSKI: Okay. Now you are also
6 allowing power operation of the system, assuming onsite
7 power is available and offsite power is not available,
8 and you have no requirement that the system operate
9 without power.

10 MR. KING: We do not have a requirement in the
11 principal design criteria that the plant must withstand
12 a station blackout.

13 MR. LIPINSKI: Is there a specific reason that
14 it should not?

15 MR. KING: We are going to require that the
16 plant be analyzed for station blackout, but we do not
17 consider that as a design basis event. That is why it
18 does not show up in the design criteria. It will show
19 up in the safety analysis of the plant. The plant will
20 be analyzed for that event.

21 MR. LIPINSKI: Now you are perceiving LWRs,
22 the direction of LWRs is to analyze the LWR plants for
23 their capability to withstand station blackout.

24 MR. KING: The CRBR will be analyzed for their
25 capability to withstand station blackout.

1 MR. LIPINSKI: Except the LWR criteria are
2 written, and this is happening after the fact. You are
3 writing your criteria; namely your criteria can require
4 blackout capability and then you will do your analysis
5 to see if you have met the criteria.

6 MR. KING: If you consider station blackout as
7 a design basis event, something that is probable that
8 will happen, I agree with you that should be in the
9 criteria.

10 MR. LIPINSKI: It is not a question of whether
11 it is probable that it will happen. Even if it is very
12 probable, the consequences cannot be tolerated, and that
13 is another consideration.

14 MR. KING: I think that is why we are looking
15 at it. We are just arguing whether it should be called
16 or thrown in the spectrum of design basis events or
17 thrown in the spectrum of beyond design basis events.
18 Either way, we are going to look at it.

19 We are going to require that the plant be able
20 to survive it. We have not included it in the design
21 basis event spectrum.

22 MR. ZUDANS: I would like to comment on this
23 one too. We commented on this one before because where
24 you changed it it still appears to me to contradict your
25 footnote where you say that this requirement is not

1 intended to preclude two-loop operation because the
2 requirement says the system safety function can be
3 accomplished, assuming a single failure with at least
4 two flow paths remaining available for residual heat
5 removal.

6 Are you including in your own mind the DHRS
7 system as a second loop?

8 MR. KING: We are including it as a flow
9 path.

10 MR. ZUDANS: So that means that if one of the
11 three loops is shut down you have two loops and a single
12 failure will still leave you with two flow paths.
13 However, in accordance with this criterion, I guess I am
14 repeating what Walt just said, you either have offsite
15 or onsite power available.

16 MR. KING: Correct.

17 MR. ZUDANS: Don't you think this is a place
18 where you should have natural circulation when neither
19 offsite nor onsite power is available? That is a design
20 basis event. Your criteria fail to address this
21 particular design basis event.

22 MR. KING: The criteria requires that you
23 assume you have lost all offsite power or all onsite
24 power.

25 MR. ZUDANS: But not both.

1 MR. KING: Right. And LWR criteria does not
2 require that.

3 MR. ZUDANS: That has nothing to do with it.
4 Forget LWRs. You have a design that takes care of that
5 situation and here you restrict your criterion to either
6 one or the other source of power being available. Why
7 not have a third criteria that says neither of them are
8 available and what do you do then?

9 MR. KING: When we consider all of the loss of
10 power, we do not consider that to be in the design basis
11 category. That is why you do not see words on station
12 blackout in the criteria. It is not that we are
13 ignoring those. Those events are going to be analyzed.

14 MR. ZUDANS: I think the project is smarter
15 than that. They provide for that particular situation
16 and they can take care of it, and as you know from
17 yesterday's discussion that was probably the most
18 profoundly discussed aspect.

19 That seemed to be the only item that at least
20 I am interested in. I know the rest will work, and here
21 you do not address one of the key design basis events.

22 MR. CARBON: Having brought out these words,
23 let us refer this to you for further consideration. Go
24 on.

25 (Slide.)

1 MR. KING: This is a continuation of the major
2 changes. We have added four additional criterion from
3 the 1976 version. The first one is reactivity limits.
4 It is essentially the same as criterion 28 in Appendix A
5 to 10 CFR 50.

6 There were terminology changes to fit CRBR
7 terminology, and I am not sure why that was not included
8 in the original set, but I think it requires that, for
9 instance, when you evaluate the plant for accidents that
10 the design not allow more reactivity to be inserted in
11 an accident than your shutdown system.

12 MR. CARBON: Excuse me. I presume you are
13 saying that you have no records as to why it was not in
14 the 1976 version and that your judgment is that it
15 should be in there and you put it in there. Is that
16 right?

17 MR. KING: That is correct. It is the same
18 story on 58. That is identical to design criteria 29.
19 It requires a highly reliable shutdown system. Again,
20 we do not see any reason for not included that on CRBR
21 and we are not sure why it was not included on the old
22 version.

23 Fifty-nine and 60 are new. Fifty-nine deals
24 with fuel rod failure propagation. There are no
25 corresponding limits or criteria in Appendix A that are

1 similar to 59 and 60. In 59 we have added fuel failure
2 propagation as one of the ways which could lead to a
3 whole core disruptive accident. We felt that requiring
4 features to prevent that or to detect it such that you
5 could terminate the event was appropriate for Clinch
6 River since this was one of the initiators for a core
7 disruptive accident.

8 MR. CARBON: We have talked about the fact
9 that this is an iterative process. Give an example of
10 what you have in mind as a design feature to meet 59.

11 MR. KING: Delayed neutron monitors. What is
12 their response time, their sensitivity? Should they be
13 part of the plant shutdown system or not? That is the
14 kind of feature that we could look at that would meet
15 59.

16 Also design of the fuel. What is the
17 experience in terms of failure? Has there been
18 propagation? Do we have a good data base that says
19 there will not be propagation? If we do, maybe we do
20 not need to be -- delayed neutron monitors require that
21 there be safety grade equipment. It is this kind of
22 thought process that we are going to go through.

23 Right now we are putting this criteria up. We
24 are going to meet something, but we are not sure what
25 that something is yet.

1 Sixty is flow blockage. Several things have
2 prompted this. One is the Fermi 1 experience where they
3 did have flow blockage and they did not have features to
4 mitigate the effects of loose parts. We do not have
5 much experience on LMFBRs with this, about what could be
6 expected, what size they could be, and flow blockage was
7 not included as a design feature.

8 Given those considerations, we felt it was
9 appropriate for that requirements to be added to prevent
10 flow blockage, whether it is for loose parts or loss
11 from hydraulic hold-down on assemblies or whatever
12 considerations you could have that would lead to flow
13 blockage, which would require features to prevent that.

14 MR. LIPINSKI: Before you take that off, I
15 would like to go back to 57, reactivity limits. You
16 include consideration of events such as rod ejection,
17 yet in an earlier criteria you deleted the words "rod
18 ejection". I am puzzled.

19 Here you specifically refer to it and in the
20 other criteria you said you wanted to delete the words.
21 You said it was not possible.

22 MR. KING: I remember deleting the words "rod
23 ejection" on another criteria because we felt that was
24 an LWR terminology.

25 MR. LIPINSKI: And yet in this criteria here,

1 57, you put them in.

2 MR. KING: Well, I don't think we put them in;
3 I think it was a matter of maybe we forgot to take it
4 out. Fifty-seven is straight from Appendix A, 10 CFR
5 50. We did change a couple of words like, I think, "rod
6 ejection" we changed to "rod runout," this kind of
7 thing.

8 MR. LIPINSKI: Well, on this 57 you do have
9 "rod ejection" and "rod runout."

10 MR. KING: Yes, we do have "rod ejection" in
11 that one.

12 MR. LIPINSKI: But on the other one you said
13 you wanted to delete it.

14 MR. KING: I think that is an inconsistency.
15 We should take "rod ejection" out of this one.

16 MR. LIPINSKI: Yes, criteria 23 where you
17 deleted rod ejection. You could go to the typo where
18 you have "not ejection of dropout." I think you want
19 "rod ejection or dropout."

20 MR. KING: I think you are right. In 57 we
21 changed "rod dropout" to "rod runout". We did not take
22 out rod ejection and we should have. Again, the only
23 reason is we did not want to use LWR terminology that
24 might be confusing.

25 MR. CARBON: Mr. King, how far along are you

1 in your presentation? It is scheduled for 2-1/2 hours
2 and we have gone 1-1/2. Are you maybe 60 percent
3 through, or 30 or 90?

4 MR. KING: I would say 60 to 70 percent
5 through.

6 MR. CARBON: So we are roughly on schedule.

7 MR. KING: The only remaining vugraphs I
8 wanted to show deal with comments that were raised by
9 this Committee in the March 30-31 meeting and the
10 comments we received from Dave Okrent in the July 1
11 letter.

12 MR. CARBON: Well, let's take a break at this
13 time, then.

14 (A brief recess was taken.)

15 MR. CARBON: Let's move ahead.

16 MR. KING: I think we wanted to follow up on
17 Bill Morris wants to make a statement following up from
18 this morning's discussion.

19 MR. MORRIS: Bill Morris, NRC Staff.

20 I wanted to point out something about the
21 general design criteria, Appendix A. We should
22 recognize that there is an admission in the Code of
23 Federal Regulations that additional criteria may be
24 added in the future. That is admitted for lightwater
25 reactors and I think we must admit to the possibility

1 for the LMFBR.

2 One particular example is that that has been
3 discussed here recently. That is the possibility of
4 requiring some design, general design, criterion related
5 to station blackout. The station blackout problem is an
6 unresolved safety issue for lightwater reactor. It is
7 being considered intensively.

8 If it should occur that a new general design
9 criterion should be added to these in Appendix A because
10 of that study, we would believe that it would be
11 reasonable to consider the addition of an additional
12 criterion to the principal design criterion for Clinch
13 River. We do not want to presume what the result of
14 that unresolved safety issue will be.

15 We prefer to wait. We do have some level of
16 confidence, however, that if it were to be the case that
17 for lightwater reactors it was necessary to mitigate
18 station blackout that it would be possible for this
19 design to mitigate station blackout in a comparable
20 way. We would prefer to just wait and hold off on
21 adding any such criterion that would include a criterion
22 for natural circulation.

23 So our general policy here has been that where
24 one could find some possible way to perhaps improve the
25 general design criterion, if that is going to come for

1 lightwater reactors, if it were to be applicable to
2 Clinch River, then we would address that in the
3 appropriate way at the appropriate time.

4 We do not want to go and begin to forge ahead
5 in the lightwater reactor industry here in those areas
6 in which the concern could be equally applied to an
7 LMFBR as to a lightwater reactor. We have tried to
8 consider the special and unique features of LMFBRs that
9 should be included.

10 So some of your concerns, there seems to be a
11 generic question of why don't we fix this because we
12 know it is going to be a problem. Our answer to that is
13 we do not believe we should get out ahead of the
14 lightwater reactor industry in this regard, with regard
15 to licensing. So that, I think, is a generic answer to
16 a generic concern that you have, and I would like you to
17 keep that in mind as we go through this and you come up
18 with those concerns.

19 They do not always needs to be fixed at this
20 time for this criteria.

21 MR. LIPINSKI: Given your criteria of DBA and
22 beyond DBA, I presume you are thinking of a number like
23 ⁻⁷ 10 per year.

24 MR. MORRIS: Maybe I have not gotten your
25 question, but no, we do not have a threshold probability

1 to distinguish between design basis and beyond the
2 design basis. We do not believe the techniques for
3 coming up with those kinds of numbers are sufficiently
4 mature.

5 MR. LIPINSKI: For station blackout you have
6 seismic frequencies that are being discussed today, even
7 those beyond the safe shutdown earthquake. The more
8 frequent minor ones that will remove your incoming power
9 lines and subject the plant to a long state of offsite
10 loss of power puts you into the requirement that you are
11 going to require diesels to have onsite power.

12 If I look at diesel probabilities of .01 per
13 diesel, if this design is coming up with ten diesels to
14 guarantee that I am going to have onsite power to
15 guarantee that I do not have station blackout, then the
16 design may be acceptable. But if it is using the
17 approach of having the minimum number of diesels, I
18 think you are going to have a problem.

19 MR. MORRIS: I would point out that we do not
20 presume to try to resolve this tough issue here. This
21 is an issue that would extend to lightwater reactors as
22 well as to Clinch River. We agree it is an important
23 question and should be resolved.

24 We believe that if the time should come at
25 which that generic resolution for lightwater reactors

1 would be to add additional diesels or add more diverse
2 kinds of motive power that that could be incorporated
3 for Clinch River as well as it could be for lightwater
4 reactors. Therefore, we prefer to stop short of trying
5 to resolve that tough issue here.

6 MR. LIPINSKI: Don't misunderstand. I am not
7 advocating ten diesels. I would rather see a
8 specification that says it can operate without power --
9 not operate, but removes heat without power RHR.

10 MR. CARBON: Fine. Let us move on, then.

11 (Slide.)

12 MR. KING: I wanted to talk about the comments
13 raised in the March 30-31 ACRS meeting. What I have
14 done is I have gone through the transcript. I was not
15 at the meeting and I picked out what I considered to be
16 the major comments and tried to put a response down for
17 each one. We have considered them all.

18 We have incorporated some. We have not
19 incorporated some.

20 MR. LIPINSKI: Could I back you up one? I was
21 not prepared for you to throw this one up because I did
22 not finish with your last vugraph.

23 MR. KING: You want to go back to the last
24 vugraph?

25 MR. LIPINSKI: Criterion 58. I had some

1 slides in the handout that showed the specific words for
2 each criterion. This is the one that deals with the
3 extreme high probability of accomplishing your safety
4 functions. My only comment is if I go back to criterion
5 19 for the protection system, and criterion 24 for the
6 reactivity control systems, you have words in there with
7 respect to reliability.

8 It is just a question of whether you want to
9 use words like "extremely high" in those specific
10 sections. This effectively is a redundant criteria to
11 what is already there. This is possibly a little
12 stronger, but you already have words in those other
13 criteria.

14 MR. KING: I agree. There are words in those
15 other criteria. Again, we are just following or using
16 the same format that the LWR criteria used. They
17 applied reliability words.

18 MR. LIPINSKI: Fifty-eight is a criteria you
19 added.

20 MR. KING: I added it in because it had not
21 been included in the 1975 version of the Clinch River
22 criterion. It has been in Appendix A.

23 MR. LIPINSKI: I am sorry. I thought these
24 were not in Appendix A but they were created by you.

25 MR. KING: The four new ones, the first two

1 come from Appendix A, but they were not included in the
2 Clinch River set originally. We feel they should be.
3 The last two were ones that are not in Appendix A and
4 are new, that we developed.

5 MR. LIPINSKI: Okay. That was in the first
6 two.

7 MR. KING: Yes. That is identical to 29 in
8 Appendix A.

9 MR. LIPINSKI: Okay.

10 MR. CARBON: Move on.

11 MR. KING: Okay. One of the questions from
12 the March meeting was why don't principal design
13 criteria define design basis accidents.

14 The principal design criteria, as we view
15 them, define requirements on systems, components and
16 structures. Design basis accidents are used to test the
17 capability of the plant systems, components and
18 structures. We put a little discussion in our draft SER
19 section on DBAs.

20 DBAs are defined and discussed in Chapter 15
21 of the PSAR and will be discussed in Chapter 15 of our
22 SER. Again, we talked about this this morning. There
23 is some linkage between the two and you cannot bury your
24 head in the sand and ignore one and do an adequate job
25 on the other, but we did not feel that PDCs were a place

1 where you should define design criteria. They should
2 really deal with design requirements on plant systems.

3 The second question was why don't design
4 criteria address CDAs and energetics. Again, the
5 principal design criteria we feel should just address
6 those systems, components and structures necessary for
7 mitigating design basis accidents. We will address
8 energetics and the criteria for systems that mitigate
9 accidents beyond the design basis in a separate appendix
10 to the SER.

11 (Slide.)

12 MR. KING: The next question was why don't the
13 criteria specify a margin of safety for the plant for
14 the safe shutdown earthquake, seismic events beyond the
15 safe shutdown earthquake, and we consider beyond the
16 design basis. We are going to look at what margin the
17 plant has for accommodating earthquakes beyond the
18 design basis.

19 I think if you read the criteria that deals
20 with natural phenomenon it does say that you will look
21 at the historical data in selecting your site
22 suitability safe shutdown earthquake, and you will also
23 look at the amount of data, and that implies you should
24 look at what the uncertainties are in that data such
25 that you allow adequate margin when you select the safe

1 shutdown earthquake.

2 So we did not feel that putting a specific
3 requirement in the design criteria to go beyond the safe
4 shutdown earthquake was appropriate. We felt the words
5 in the criteria generally imply that you should have
6 conservative margin and that beyond the design basis
7 earthquake will be looked at as part of the beyond
8 design basis events.

9 The fourth question was why don't the criteria
10 specify natural circulation as a requirement. We went
11 through this this morning. We felt that decay heat
12 removal was the real requirement and the number of paths
13 that you should have. Whether that is by forced
14 circulation or natural circulation I think is part of
15 the implementation process.

16 If station blackout is added as a design basis
17 event, it will probably end up that the plant will have
18 to have natural circulation. We are looking at station
19 blackout as an event beyond the design basis and from
20 that standpoint the plant will be designed for natural
21 circulation.

22 The fifth question was why don't the criteria
23 address sabotage. We felt sabotage was addressed in
24 another part of the Code of Federal Regulations and need
25 not be duplicated here.

1 MR. MARK: There has been a lot of discussion
2 for quite a few years of considering design to reduce
3 the ease of conducting sabotage. Now that would
4 certainly be consistent with the idea that the principal
5 design criteria give thought to sabotage in the
6 criterion for design.

7 MR. KING: Part 73 requires that that be given
8 in the design as well. It talks about having protected
9 areas.

10 MR. MARK: It probably covers the points as
11 well as it could. It would not be a mistake, however,
12 to have in a majestic document such as the principal
13 design criteria some recognition of the fact that
14 sabotage should be thought about. This is the 60
15 commandments. You could do without 58 and put sabotage
16 in.

17 MR. KING: I do not think putting sabotage in
18 is bad. I just think it is a duplication.

19 MR. MARK: This, however, is a stand-alone
20 thing. It is impossible for anybody to read all of the
21 175 parts of CFR 100 and to correlate them. So the fact
22 that it is in somewhere else is not in the least
23 surprising.

24 That is just an observation.

25 MR. ZUDANS: There is nothing wrong in

1 providing a cross reference to this maze of different
2 paragraphs and different numbers. There could be a
3 reference made that this is treated there.

4 MR. KING: That could be done.

5 MR. ZUDANS: You do make references in other
6 aspects. This would not be the only one, would it?

7 MR. KING: I do not think we reference any
8 other parts.

9 MR. ZUDANS: I thought you referenced to some
10 other appendix. I do not remember.

11 MR. KING: There is a QA criteria. There is
12 also an appendix to 10 CFR 50.

13 MR. ZUDANS: But you reference it in these
14 criteria, don't you?

15 MR. KING: We do not reference that appendix
16 or that CFR in the Appendix itself, although a lot of
17 detailed QA requirements are put in that appendix.

18 Okay. Another question was why don't the PDCs
19 address containment retention time. I think they do in
20 a general sense if they say the containment has to
21 remain intact with its leak rate for as long as the
22 accident conditions require. They do not put a time
23 in -- 24 hours or whatever -- but we feel that the point
24 is covered adequately.

25 We look at the event and make sure the

1 containment is there and does its job for the duration
2 of that event. It will be a different time for a
3 different event.

4 Now why don't the PDCs address station
5 blackout. We went through that already.

6 Number 8, add definition of postulate
7 accidents and fuel damage limits, and we did that.

8 MR. LIPINSKI: I am curious on the postulated
9 accident because throughout the criteria you add the
10 word "postulated". Aren't the criteria to cover
11 accidents that are not postulated? Specifically, you
12 could have bounding type accidents that have been
13 postulated, but I could have some other accidents that
14 are not postulated but they are bounded and will occur,
15 possibly, and the system will be able to mitigate them.

16 MR. KING: The postulated accidents are
17 intended to be the design basis events that envelope all
18 the other differences or categories of events that could
19 occur within that envelope.

20 MR. LIPINSKI: But that is not your
21 definition.

22 MR. KING: Let me see what my definition is.
23 They are intended to be design basis events.

24 MR. LIPINSKI: It just says they are selected
25 to establish design basis. Implied is that they bound

1 the entire spectrum.

2 MR. KING: Maybe I should add some words there
3 that talk about the bounding, that these events bound
4 the spectrum of events in that category. I agree with
5 that.

6 (Slide.)

7 MR. KING: Okay. Those were the major points
8 that I got from the March meeting. The next point --

9 MR. CARBON: I would like to ask a question of
10 Mr. Morris. Bill, isn't the answer to these eight
11 questions really that you are trying to keep these just
12 as close to LWR criteria as possible and not break any
13 new ground, and you are simply trying to stay close to
14 existing ones? Isn't that the real answer?

15 MR. MORRIS: That is correct. As I said at
16 the beginning of this session after the break, we do not
17 want to try to go out and presume what may be resolved
18 for lightwater reactors in the future. There should not
19 be certain design criteria that mention sabotage here
20 because we think that should be done in a generic form.
21 That is an answer that goes to this as well.

22 MR. CARBON: I am not sure I agree with your
23 approach to it, but that is what you are doing.

24 MR. MORRIS: That is our approach. We have
25 attempted to introduce those criteria that are unique to

1 an LMFBR to make sure that those are included, but we do
2 not want to introduce new criteria that could just as
3 well be introduced for an LWR.

4 MR. CARBON: I guess this comes from your aim
5 to try to have the same safety for both -- whatever that
6 means.

7 MR. MORRIS: We believe that you will this
8 approach will achieve that goal. Those additional
9 criteria that one may like to see included someday, we
10 must wait until they are included generically before
11 including them in the CRBR criteria. We have no intent
12 to have additional criteria added to the GDCs right
13 now.

14 MR. ZUDANS: You do have two definitions in
15 the beginning. One is the anticipated operating
16 occurrences and the other is the postulated accidents
17 that should encompass what is perceived as the design
18 basis events.

19 The biggest negotiating point is agreeing on
20 these design basis events. They are the key to the
21 design because the ease or difficulty of implementing
22 the criteria that you have here depends on a kind of a
23 set or a subset that you select as the design basis
24 event. So it still remains unclear to me whether this
25 is the proper procedure.

1 There are many criteria that do not require
2 it. They are self-editing, like containment leak
3 tightness. You say very simply that it shall be
4 available as long as it is needed. Of course, in the
5 back of your mind you have some design basis event that
6 will challenge the containment leak tightness. I think
7 you do have to go back and examine this connection
8 between design basis events and design criteria.

9 I am not sure that the ordering is proper. I
10 think it could be written. I previously suggested that
11 maybe you define design basis events as an event that
12 has a certain frequency of occurrence, and if you can
13 prove that a frequency is less than that, it is not a
14 design basis event or may be beyond the design basis
15 event.

16 If you cannot prove that the frequency is
17 less, given a limit, then you have to include it in the
18 set. I do not know whether it is even possible to think
19 that way or not.

20 MR. KING: I think it would be very tough to
21 wind up putting those events into the design basis just
22 because you could not come up with numbers to prove that
23 they should not be.

24 MR. ZUDANS: Don't you think that would be the
25 correct thing to do?

1 MR. KING: I think that you would have to
2 exercise a little judgment, looking at the number of
3 events that could get you into that situation, looking
4 at possible mitigating features or systems that you
5 could have.

6 MR. ZUDANS: Unless you cannot perceive as a
7 possibility to use some probablistic numbers from the
8 probabilistic study for that kind of a resolution.
9 Maybe that is where the difficulty is -- to agree what
10 is a good number and again make sure that the number the
11 applicant presents is indeed the correct number for that
12 particular sequence.

13 I am told that you can get any number that you
14 want in terms of risk value. It depends on how you
15 jumble the pieces and bits that form the total piece. I
16 am pretty sure that there is lots of judgment in the
17 decisional process, but that still would be a better
18 way, in my opinion.

19 I will leave the subject.

20 MR. CARBON: Let's go on to the next section.

21 (Slide.)

22 MR. KING: There was a letter from Dr. Okrent
23 of July 1. The first one said criterion 2 appears to be
24 inadequate in that it refers only to historic natural
25 phenomena as a basis for judgment. Criterion 2 is the

1 one that deals with natural phenomena such as
2 earthquakes.

3 We looked at that and felt that the words in
4 criteria 2 do specify that you should provide sufficient
5 margin to account for the uncertainties of the data,
6 which really means that you do a site-specific
7 determination. We felt that this was an appropriate --
8 appropriate words for the criteria in lieu of saying
9 some number like 50 percent beyond whatever. It is
10 really determined on a case-by-case basis.

11 The second comments was on criterion 5. It
12 refers to postulated accidents. Criterion 5 has to do
13 with qualification of equipment. He said it is not
14 clear whether this will limit the environmental
15 qualification to design basis accidents and leave
16 important functions vulnerable to other circumstances.

17 Equipment that is required for accommodating
18 events beyond the design basis will be qualified for the
19 conditions that it sees in those events. Equipment
20 required for design basis accidents will be qualified
21 for its conditions. A separate appendix to the SER will
22 address this point.

23 MR. AXTMANN: I hate to interpret Dave
24 Okrent's words in his absence, but I think part of his
25 problem was calling it postulated accidents, when you

1 really mean DBA.

2 MR. KING: Postulated accidents does mean DBA
3 the way we are using it, if that is what Dave meant. We
4 can clear that up in the definition. I agree we need
5 some words there.

6 MR. LIPINSKI: On 5 in your justification,
7 this is where you deleted the words "include loss of
8 coolant accidents." This is motivated by the fact that
9 you know the design meets the requirements, but I do not
10 see why you deleted the loss of coolant accident words.

11 MR. KING: We deleted them because they are a
12 set of words that are usually associated with lightwater
13 reactors.

14 MR. LIPINSKI: But they are still words to be
15 associated with an LMFBR such that you will not take
16 that coolant and put it somewhere else within the
17 containment building. The design should meet the
18 requirement that you not lose your coolant and you will
19 put in guard vessels and guard pipes to prevent this.

20 MR. KING: We had a separate criteria that
21 talks about the features to mitigate -- to retain the
22 sodium in the event of a leak. That is a separate one
23 from 5.

24 MR. ZUDANS: That is a lower level.

25 MR. LIPINSKI: I know it is still a lower

1 level, but it still is a requirement for an LMFBR.

2 MR. KING: We do have a different criteria
3 that addresses that point. Five is really
4 addressing --

5 MR. LIPINSKI: The natural phenomenon.

6 MR. KING: The environment equipment sees in
7 the event of an accident.

8 MR. STRAWBRIDGE: Twenty-seven is the one you
9 are looking for.

10 MR. KING: Twenty-seven? Right. Twenty-seven
11 is the one where we intend to require that they retain
12 the coolant.

13 (Slide.)

14 MR. KING: Dave's third comment was criterion
15 7 used the term "single failure." Why is single failure
16 okay? That is sodium heating systems.

17 We considered application of the single
18 failure criterion to be acceptable on systems that did
19 not directly affect the ability of the plant to shut
20 down or to remove decay heat. On those systems that do
21 provide shutdown capability or remove decay heat we have
22 added some additional requirements for diversity,
23 redundancy and independence, as well as, in the case of
24 decay heat, that flow paths remain available after
25 single failure such that additional failures can be

1 accommodated beyond the single failure.

2 I think the criteria that implemnt those
3 additional failures are 20, 24 and 35.

4 MR. LIPINSKI: The real issue on single
5 failures is that it implies that you are getting
6 additional reliability and that having met the single
7 failure criteria you do have the desired level of
8 reliability. But the single failure criteria in itself
9 does not guarantee that having met the single failure
10 criteria that you still have a system that meets a
11 desired level of reliability.

12 MR. KING: I cannot argue with that
13 statement.

14 MR. LIPINSKI: I think that is the entire
15 issue throughout here where you are using the term
16 "single failure" to imply that having met the single
17 failure criterion that you now have a level of
18 reliability that is adequate. I think the single
19 failure criteria is a minimum and in addition to it you
20 need statements that say that you have the demonstrated
21 level of reliability.

22 MR. KING: Reliability does show up in the
23 criteria that deal with shutdown systems and decay heat
24 removal.

25 MR. LIPINSKI: In your electrical systems, I

1 think you have the single failure criterion and you do
2 not discuss the level of reliability. That is part of
3 your shutdown heat removal system because you are going
4 to require your diesels.

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 But I think you should take a look. This
2 appears ten or more times throughout the criteria, that
3 the single failure appears to be adequate.

4 MR. KING: There is a specific set of words
5 that show up.

6 MR. LIPINKSI: In my judgment, I don't think
7 it's sufficient to just say single failure. If I have a
8 probability of single failure of .9 in two systems, and
9 I take the single failure, the probability that the
10 other one is going to fail is .9. To me, that doesn't
11 indicate that you still have an adequate system just
12 because you met the single failure criterion.

13 MR. CHECK: Walt, are we having the same
14 discussion we had earlier? We may be annoying you, but
15 I would have to say again and again, what we are trying
16 to do is derive something that is consistent with what
17 is done in water reactors.

18 MR. LIPINKSI: It is the same discussion.

19 MR. CHECK: We know in many cases single
20 failure isn't enough, but that is what we are putting up
21 for this step in the process. This is why we are
22 putting up the principal design criteria. We could have
23 done more, but we explained why we didn't. If it isn't
24 enough, it's not enough. I would ask if the committee
25 feels strongly about this, if they are moving against

1 the general design criteria in the same way, because
2 they have the same weaknesses.

3 MR. KING: I am not sure if because the words
4 are the way they are in the general design criteria that
5 we are ignoring reliability.

6 MR. ZUDANS: In number 7, you state redundancy
7 requirements with a single failure. That is already
8 halfway there. If the redundancy was supplemented with
9 the redundancy and reliability, that would take care of
10 the concerns.

11 MR. KING: The word "reliability" does show up
12 in the criterion.

13 MR. ZUDANS: Not in number 7. It only states
14 redundancy.

15 MR. KING: That's right, the reason being that
16 that is not a system that is used to shut down the plant
17 or to remove decay heat.

18 MR. ZUDANS: How long would it take for the
19 primary system to freeze up if you lost this heating
20 system and you had no heat removed through those loops?

21 MR. KING: I don't have an exact number, but
22 it would probably be in the neighborhood of hours, not
23 days or weeks.

24 MR. ZUDANS: Hours. And --

25 MR. KING: This is the type of system where if

1 you lose the heating, you do not immediately lose you
2 shutdown systems and your decay heat removal systems.

3 MR. ZUDANS: No, as long as you have natural
4 circulation, because if you lost your heat, you would
5 also lose all your power, almost certainly.

6 MR. KING: You could lose your heating systems
7 without losing your power, if the control system failed.

8 MR. ZUDANS: Yes, you could. The fourth
9 comment was, criterion 11 does not give any guidance on
10 reliability requirements for instrumentation and
11 control. Criterion 11 is the instrumentation and
12 control criterion. Again, it is the same logic we
13 talked about on 3. Criterion 11 does not deal with
14 systems that shut down the plant nor remove decay heat.
15 They are monitoring systems. We used the reliability
16 terms criteria to include reliability in those systems
17 that deal with decay heat removal or shutdown systems.

18 Again, that is no different than in the LWR
19 criteria.

20 (Slide.)

21 MR. ZUDANS: I am not quite completely
22 understanding what you said. Criterion 11 doesn't cover
23 any instrumentations and controls covering the shutdown
24 systems?

25 MR. KING: It does not.

1 MR. ZUDANS: It does not. When you are
2 talking about systems, that is included in part of the
3 other criteria that specifically mentions such systems?

4 MR. KING: Criterion 11, the way I read
5 criterion 11, in interpreting it, is, it deals with the
6 other instrumentation and control systems in the plant,
7 but not the plant shutdown systems.

8 MR. ZUDANS: You mentioned the fission
9 product, the reactor coolant boundary.

10 MR. KING: Did you want to go on?

11 MR. ZUDANS: Yes.

12 MR. KING: Okay. His comment again was the
13 same question on single failure. The term here applies
14 to the electrical criterion 15. Again, the logic is the
15 same, that for those systems that deal with shutdown or
16 decay heat removal, we have added additional
17 requirements so that you can accommodate more than a
18 single failure, so that you can protect against common
19 mode failures.

20 MR. LIPINKSI: How is that reflected in the DC
21 power systems? Your second paragraph just says single
22 failure for the battery, yet you find LWR designs that
23 are going well beyond that for DC systems without having
24 been required in the general design criterion. You are
25 admitting that a dual battery system meets your

1 criterion.

2 MR. KING: I guess I am not familiar with why
3 LWR's are going beyond the dual battery system.

4 MR. LIPINKSI: Because dual batteries are not
5 sufficient to give you the reliability that you need.

6 MR. KING: Again, I think these systems are
7 going to be looked at from a reliability standpoint. We
8 don't have words in the general design criterion on it.
9 Maybe in terms of electrical power we should re-look at
10 that.

11 MR. LIPINKSI: The same with diesels. A
12 double diesel with the probability of start is 10⁻²
13 start per diesel, which is a very low reliability.

14 MR. MARK: It is really more than 10⁻², if
15 you ask it to start in two seconds.

16 MR. LIPINKSI: The number doesn't get in much
17 better.

18 MR. MARK: You can bring in a new one in an
19 hour.

20 MR. KING: I would anticipate that if you take
21 a criteria like 35 that deals with residual heat removal
22 there, it does use -- I believe it uses the term
23 "reliability," or 26 does. It is the function that we
24 did add some additional requirements for diversity,
25 redundancy, additional paths so that we could

1 accommodate more than a single failure.

2 In looking at the implementation of that
3 criteria, if electrical power is needed for decay heat
4 removal, I would look at the electrical power systems
5 that supply that power as having to meet the additional
6 -- being able to accommodate or support having those
7 systems withstand more than a single failure.

8 If there is an interconnection between the
9 two -- I guess I am having some second thoughts on 15.
10 Maybe we should look at the words on that, because of
11 the strong interconnection to that with the decay heat
12 removal systems.

13 MR. LIPINKSI: You are going to admit
14 electrical power into the decay heat systems.

15 MR. CHECK: The intent was that if you had a
16 criteria for decay heat removal where you have
17 electrical power needs to perform its function, that the
18 reliability and the requirements of that decay heat
19 removal spec would also have to carry over into that
20 portion of the electrical system that supports that
21 system.

22 I agree, we didn't carry the same words over
23 into the electrical power area, and maybe we should take
24 a look at that. The sixth comment was, criterion 17,
25 which is on the control room, is obscure as to whether

1 it deals with a fire in the control room. The intent is
2 that that criteria would apply if there is -- one of the
3 events that that criteria is intended to help mitigate
4 is a fire in the control room, where it talks about
5 alternate shutdown locations. It doesn't use the words
6 "fire in the control room," but that is one of the
7 events for that criteria.

8 MR. RAY: That is your interpretation of it,
9 but what about the licensee? Is he going to design for
10 that?

11 MR. KING: The design has alternate shutdown
12 locations.

13 MR. RAY: Yes, but is that alternate shutdown
14 location going to be affected if you have a fire in the
15 control room and still maintains habitability? In your
16 justification for this criterion, the emphasis is on the
17 availability of alternative shutdown facilities. In the
18 event the control room is uninhabitable, I can conceive
19 of a situation where you are going to need these
20 external shutdown facilities, even when the control room
21 is habitable, the requirement being such that you have
22 lost your controlling instrumentation within the control
23 room, so you have to go to some other location.

24 If you have a limited fire, for instance, that
25 impacts the instrumentation and control but doesn't

1 impact the environment in the control room, it remains
2 habitable but it can't operate. So it seems to me your
3 wording on the paragraph under criterion 17 talking
4 about the equipment external to the control room should
5 emphasize that these external control facilities be
6 operable regardless of the availability status of the
7 similar equipment in the control room.

8 MR. KING: I think that is the intent.

9 MR. RAY: But that is not what it says.

10 MR. KING: I think you have a good point. Let
11 me fix some words there.

12 MR. LIPINKSI: If you had a fire in the
13 control room and it destroys that wiring, there is no
14 specification that says wiring has to be arranged such
15 that the alternate location functions.

16 MR. RAY: That is the point. Now we are
17 getting down to detail, and that is not what you want,
18 but there should be switching provided in the area of
19 that alternative control area that you can isolate the
20 wiring from the facilities of that control room, and
21 that is not clear here.

22 MR. KING: I think that is the intent, and I
23 think the design is such that I would ask the applicant
24 to confirm that.

25 MR. RAY: We are back to the original point

1 you cited back here, that this kind of thing is what is
2 provided in LWR's, but in this specific detail, several
3 of the applications I have seen in the plants I visited,
4 where we talk about their remote control panel, they did
5 not have switching facilities, and if you had a fire
6 within the control room that impacted the wiring there
7 for controls and instrumentation, it also impacted the
8 wiring available at the alternative shutdown panel, and
9 they now must retrofit that plant to correct it.

10 So, what I'm saying is that in many of these
11 cases, and this is a specific one, there are
12 deficiencies in what the LWR design criteria require.

13 MR. CHECK: We grant that, and in the case of
14 LWR's, there were guides, requirements, regulations
15 promulgated to cover that. I think we are touching on
16 what is called Appendix R, I believe.

17 MR. RAY: That is in the fire protection.

18 MR. CHECK: Yes. It will apply to this
19 particular plant.

20 MR. RAY: Where do you cite Appendix R in the
21 CRBR?

22 MR. CHECK: When we get around to that part of
23 the SER that deals with this.

24 MR. RAY: I see, so your intent there is to
25 invoke Appendix R in your SER revisions.

1 MR. CHECK: Yes, in the same way we are going
2 to do for light/water reactors.

3 MR. RAY: Well, I think Dave's underlying
4 concern was more than fires. It's the kind of thing we
5 are talking about now on that remote control panel.
6 Your justification emphasizes uninhabitability of the
7 control room, and I think his comments go beyond that.
8 It would be well to add a couple of words in this
9 paragraph to make that clear.

10 MR. KING: I understand.

11 MR. LIPINKSI: On criterion 17, you had a five
12 rem whole body requirement, but it doesn't specify the
13 persons remaining in there for any period of time,
14 because I can rotate personnel. They say, each receive
15 a five rem dose. And as I interpret the criterion, it
16 is ambiguous. I could leave a minimum crew in that
17 control room until I got a five rem dose, and I could
18 remove them and replace them, and I could keep doing
19 that indefinitely until I ran out of people.

20 MR. KING: If you've got an accident where
21 you've got five rem in the control room, if the guy goes
22 outside of the control room, he is going to get a heck
23 of a lot more than five rem.

24 MR. LIPINKSI: How do I interpret your
25 criterion on five rem whole body? Does that imply that

1 the individuals are there at the beginning of the
2 accident and remain during the accident?
3 Let's take a TMI 2 accident. It started on a
4 Wednesday. It wasn't over until a Friday, but
5 fortunately, their control room didn't have that high
6 level dose. But let's assume something starts on a
7 Wednesday, it is going to finish on a Friday. How do I
8 interpret the five rem?

9 MR. KING: If the guy is in that control room
10 for the whole period of time, he is going to get the
11 five rem.

12 MR. LIPINSKI: But you are allowing me then to
13 rotate personnel?

14 MR. KING: If he can rotate them without
15 exceeding the dose requirements, rotate them.

16 MR. LIPINKSI: Your interpretation is rotation
17 up to five rem.

18 MR. KING: Yes, if that can be done
19 acceptably.

20 (Slide.)

21 His last two points again talk about the
22 "single failure" words in 22 and 26. 22 deals with the
23 shutdown systems. I think what we have done in 24 and
24 25 to require redundancy, diversity, and independence of
25 two shutdown systems are requirements that make the

1 systems be designed for more than a single failure. 26
2 deals with the heat transport system, and it is
3 interrelated with 35, the decay heat residual heat
4 removal specification.

5 I think what we did in 35 adds requirements on
6 the design such that it has to withstand more than a
7 single failure.

8 (Slide.)

9 MR. KING: That was the end, unless there are
10 any more questions.

11 MR. MARK: Well, I mentioned at the start that
12 I had a number of almost textual items. Am I
13 interrupting? I don't know if this is the time to run
14 through them. It won't take very long.

15 MR. AXTMANN: (Presiding) The subcommittee
16 chairman left word to adjourn at 11:10. You have at
17 least seven minutes.

18 MR. MARK: Do you have your copy of the things
19 there?

20 MR. KING: Yes.

21 MR. MARK: On number 2, where you mention a
22 variety of natural phenomena, they are all plural with
23 the exception of Tsunami. I don't think that's quite
24 right.

25 MR. KING: All right, I will check that.

1 MR. MARK: It is a Japanese word, not a Latin
2 word.

3 Number 9, where you ask that there be a
4 negative reactivity feedback, I just should know this
5 but don't. The temperature coefficient pure and simple
6 in sodium must be positive. As you void sodium, you
7 gain reactivity. Does the doppler temperature
8 coefficient override that?

9 MR. KING: Yes, when you consider all the
10 feedbacks, the doppler is the predominant one, and it
11 overrides any positive effects you get due to the
12 voiding or the positive effects you get due to bowing.

13 MR. MARK: Okay. I just wanted to be reminded
14 how those stood.

15 And number 11, the word "variable" should be
16 plural. It is on the very last line.

17 MR. KING: Okay.

18 MR. MARK: On 14, your justification,
19 postulated accident conditions are the only conditions
20 where the containment barrier is needed, I question
21 that. You certainly need it for beyond the design basis
22 mitigation, too, so the statement is not very persuasive
23 the way it reads.

24 On 24, under normal operation, do you include
25 startup?

1 MR. KING: Yes, startup, shutdown. I think
2 that is defined in the definitions.

3 MR. MARK: Oh, I forgot to check that.
4 Reactivity control is needed in startup just as well.

5 MR. KING: That's defined on page 8. It
6 includes startup and shutdown.

7 MR. MARK: Just as a matter of taste, I
8 suppose, 46, 47, and 48, you manage to include, a single
9 check valve may not be used, an automatic shutdown
10 valve, twice in 47, once in 48. It seems to me that
11 statement could be made once in the main body of 46, and
12 say that here, as in 47 and 8, a single check valve may
13 not be used, and it will improve style and avoid the
14 sort of feeble-minded looking iteration that you get from
15 the impression --

16 MR. KING: The words are straight from
17 Appendix A.

18 MR. MARK: Yes. I didn't see any reason why
19 you should slavishly copy a poor example.

20 (General laughter.)

21 MR. MARK: And 59, you introduce the
22 abbreviation PDC in 59, but it is only in the
23 justification. It has not been used anywhere else that
24 I am aware of.

25 MR. KING: All right, I will spell that out.

1 MR. MARK: And then on 60 you are worried
2 about flow blockage while the assemblies are in the
3 reactor core. Why on earth is that phrase in there?
4 When else in the world would you worry about flow
5 blockage?

6 MR. KING: The reason that is in there is, we
7 don't want to give the impression that we had to go back
8 to put features in the fabrication line to make sure all
9 the holes are drilled right.

10 MR. MARK: You are worried about flow blockage
11 and flow restrictions. That really only happens in the
12 reactor core. There is no flow down at the fabrication
13 point. It seems to me that that phrase -- it would be
14 an advantage to delete it.

15 Now, the justification won't be in the final
16 document, so the fact that you say, while the assemblies
17 are in the core, as a justification, it is not quite so
18 offensive to me as having it in the principal design
19 criterion.

20 Also, you make a reference here and for the
21 first time to the applicant. That is really meaning, I
22 understand these are specific for the CRBR, so it might
23 be all right to apply to the applicant, but that is only
24 down in the justification, so that's right. That's
25 all.

1 MR. CARBON: Walt?

2 MR. LIPINSKI: I have some comments that
3 haven't been covered. Criterion 20, protection system
4 independence, my question is, how does defense against
5 NaK get specified? This goes along with your earlier
6 comment where you talk about control systems, but is
7 this the place where the protection system is to be
8 specified to be split into a double system to be into
9 the other specification?

10 MR. KING: I didn't follow your question.

11 MR. LIPINKSI: The electronics in terms of
12 what would activate a primary scram system and a
13 secondary scram system. Here you are talking about
14 redundant channels, but we are not talking about
15 redundant systems, that each have redundant channels.

16 MR. KING: I think maybe what we need to do is
17 take a look at these words to make sure. They talk to
18 protection systems, and that that includes the portion
19 of electronics as well as mechanical hardware.

20 MR. LIPINKSI: All right, because I can't get
21 to that in here yet.

22 MR. KING: All right. Let me look at that.

23 MR. CARBON: Did you have more comments,
24 Walt?

25 MR. LIPINKSI: Yes. I was trying to get to

1 the appropriate page here. In criterion 31, you are
2 specifically talking about the residual heat extraction
3 system as being part of the intermediate cooling
4 system. This then implies that I don't have a direct
5 path from the primary system to an RHR system.

6 MR. KING: Thirty-one, you say?

7 MR. LIPINKSI: Yes, first sentence. This
8 specifically limits the RHR to the intermediate system.

9 MR. KING: The RHR includes main loops as well
10 as the direct heat removal system.

11 MR. LIPINKSI: But intermediate system, the
12 main heading, we know I'm on the other side of the
13 primary system, now I've got an RHR.

14 MR. KING: Maybe we have a semantics problem.
15 The intent was, the safety requirement on the
16 intermediate cooling system was to provide an
17 intermediate path so you could remove decay heat. I
18 didn't intend by putting those words, "reactor residual
19 heat extraction system," to mean anything other than
20 that. It's a path to remove decay heat out to the water
21 system, the water steam system that eventually comes
22 into the atmosphere.

23 MR. LIPINKSI: Okay, and on page 28, with your
24 explanation of -- the second sentence from the left
25 says, "Additionally, since there are no containment

1 isolation valves in the intermediate system, it is
2 considered a closed system, and acts as an extension of
3 containment." My question is, which way? Into the
4 containment or from the containment out to the steam
5 generators?

6 MR. KING: From the containment out.

7 MR. LIPINKSI: To the steam generators?

8 MR. KING: To the steam generators.

9 MR. LIPINKSI: And one last one. Under
10 criterion 45, piping systems penetrating containment, I
11 guess it is implied that it includes the intermediate
12 system in the listing, yet the intermediate system does
13 not have any valves.

14 MR. KING: The intermediate system may be
15 considered a closed system. There should be a criterion
16 that addresses that.

17 MR. LIPINKSI: Criterion 45 doesn't discuss
18 whether it is open or closed. It says, if I have a pipe
19 penetrating containment, I have to be able to have
20 isolation, yet in the previous statement you said the
21 intermediate system does not have isolation valves.

22 MR. FLOYD: Forty-eight is the one you were
23 looking for.

24 MR. KING: Closed systems penetrating
25 containment. I think the intermediate system falls

1 under 48, which allows you to have a system without a
2 containment isolation valve.

3 MR. LIPINKSI: It says, "shall have at least
4 one isolation penetration valve," and you are saying
5 that the secondary system is seismically qualified all
6 the way through to the steam generator, so it is not
7 demonstrated, it is not required?

8 MR. KING: That's correct. It's built to the
9 ASME code.

10 MR. LIPINKSI: That is all I have, Mr.
11 Chairman.

12 MR. CARBON: Any other? Bill.

13 MR. KASTENBERG: Yes, just kind of a
14 question. If the design changes appreciably in this
15 iterative process, do you have a provision for changing
16 the design criteria, or will they be frozen at the SER
17 stage?

18 Let me give you an example. We discussed the
19 guard vessel this morning. You eliminated a requirement
20 for coolant makeup. Suppose in six or eight months the
21 applicant comes along and says, gee, we want to
22 eliminate the guard vessel or guard pipe for whatever
23 reason. Do you have an option then to go back and
24 review the criteria, or are they going to be frozen?

25 MR. KING: I think you always have an option

1 to review the criteria. The intent would be to assess
2 any design changes against the requirements in place at
3 that time.

4 MR. KASTENBERG: The point Walt was making,
5 you left the criterion out because there is something in
6 the design.

7 MR. KING: There is a requirement to retain
8 the coolant. It doesn't use the words "guard vessel,"
9 so if you remove the guard vessel, you would have to
10 demonstrate whatever takes its place or whatever is left
11 does the same thing that was intended by that design
12 criteria.

13 MR. KASTENBERG: So is the answer then that
14 the iterative procedure could continue up to the time
15 the design is frozen, or even beyond that if there are
16 design changes, or will the criteria be frozen at some
17 point and that is it?

18 MR. KING: The intent is to freeze these as
19 much as possible, but I can't say that we'll never make
20 changes to them.

21 MR. LIPINKSI: Could you be more specific as
22 to which criteria you are talking about on the coolant
23 inventory?

24 MR. KING: I think it was 27.

25 MR. LIPINKSI: Yes. Yes, that's covered.

1 MR. CARBON: Any other comments? If not, I
2 guess that concludes it and we can move on to the next
3 topic.

4 MR. CLARE: While Paul is handing out the
5 package of vu-graphs that cover the presentations that
6 both Paul Dickson and I will be making, I would like to
7 make a few comments that address a subject that was
8 discussed yesterday in the thermal hydraulics working
9 group, as well as reflect a little bit on the discussion
10 you have been having with the staff on the general
11 design criteria.

12 Yesterday, late in the day, Dr. Carbon, you
13 asked me about a reliability number. At that time I
14 gave you an answer. Having had some discussion with the
15 other people who are in the audience over the evening
16 last night, I think I probably answered a question other
17 than the one you asked, and I doubt that I know the
18 answer to the question you asked.

19 MR. MARK: I doubt that Max knows what
20 question he asked.

21 MR. CLARE: That's a possibility also.

22 MR. CARBON: I know the one I thought I
23 asked.

24 MR. CLARE: I would merely emphasize what I
25 said then, that you needed to take what I said with a

1 grain of salt, and perhaps that would be an appropriate
2 subject of discussion later on, and I would recommend
3 also that maybe the best thing to do would be to work
4 that in with our PRA results when those are available.

5 MR. CARBON: Is this my question on how often
6 you expected the DHRS to be called upon?

7 MR. CLARE: That was one of the questions that
8 might have been asked during that exchange. Yes, it was
9 the one where we were talking about numbers.

10 The comments I would like to make on the
11 general design criteria are ones I would like to make
12 having spent a number of years working with the plant
13 designers who have been struggling to interpret the
14 general design criteria and turn them into real steel
15 and wires and transistors and things like that.

16 The changes that Tom King has talked about
17 this morning have certainly not been part of our
18 discussion over the past ten years. However, the
19 Appendix A criteria have been looked at in detail. The
20 criteria that were issued by the staff back in 1976 were
21 looked at in detail, and I think the comments I make
22 will apply to all the criteria that have been discussed
23 this morning.

24 First of all, with respect to the question of
25 design basis accidents, you don't find the words "design

1 basis accidents" in the general design criteria. To
2 make it clear, when we talk about design basis
3 accidents, what we mean is the set of accidents which in
4 the general design criteria are called anticipated
5 operational occurrences and postulated accidents. That
6 combination of events discussed in the general design
7 criteria are identical to the set of accidents we talked
8 about as design basis accidents.

9 So, just to be careful that we don't get
10 involved in a semantic problem there, I don't think it
11 is a problem. The terminology is just slightly
12 different.

13 The other comment I would like to make is
14 about the level of detail, the level of generality in
15 the general design criteria or the principal design
16 criteria for the CRBRP. The general design criteria
17 vary a tremendous amount. There are some 60 of them.
18 They overlap with each other. Some are at a very high
19 plane, as though they had come down from a cloud. Some,
20 on the other hand, are quite detailed.

21 Dr. Mark pointed out a case where the criteria
22 were telling you one type of valve was good and another
23 type of valve wasn't good. Very detailed prescription
24 to the design.

25 I think if you look at the sum of the design

1 criteria, what it reflects is an attempt by the people
2 who put those criteria together over the years to
3 balance what they thought they really did know about the
4 plant, a plant, any plant, what they felt they knew
5 about the design approach that they wanted to implement,
6 and the things that perhaps they wanted to leave some
7 flexibility on.

8 Let me try to give you some examples. The
9 containment. There is apparently a consensus among the
10 regulators and the designers that one should take a
11 passive approach to containment, and that one should
12 design a containment so that failure of a containment is
13 not part of a design basis accident. There is no design
14 basis accident that I know of that involves the failure
15 of any containment for any reactor.

16 The general design criteria are very specific
17 and very detailed to make sure you achieve the high
18 level of reliability that is appropriate to that
19 assumption. That reflects the approach where you make
20 the criteria detailed, and you have already decided what
21 your postulated accidents are going to be.

22 Balancing that are the cases where you want to
23 leave some flexibility. We have been talking about pipe
24 leaks. We have talked about loss of coolant events.
25 Criterion 27, that was just discussed, is a general

1 criterion. It says, make sure you have enough coolant
2 to remove decay heat. And it leaves the flexibility to
3 the applicant and to the regulator to determine what the
4 best design approach is to achieve that.

5 We might decide the guard vessels are right.
6 We might decide that emergency core cooling is right.

7 You will note in the case of the light/water
8 reactor criteria the regulators have gone ahead and
9 prescribed the way that they want to have that done, and
10 they have prescribed that that should be an emergency
11 core cooling system. The general requirement number 27
12 would in fact require some system to be provided, but it
13 doesn't say an emergency core cooling system.

14 So, I would urge you to take an across the
15 board look at the criteria, recognize that there is a
16 tremendous mix, a tremendous amount of overlap, and that
17 it does reflect an attempt to balance the various types
18 of concerns that you have expressed, and I think
19 appropriately so, this morning.

20 With that, I would like to go into my prepared
21 presentation on the discussion of the selection of the
22 design basis accidents. As you pointed out this morning
23 in your comments on the general design criteria, that is
24 a very important phase in determining the adequacy of
25 the safety features of the plant.

1 (Slide.)

2 MR. CLARE: The presentation we have prepared
3 for you this morning falls into three parts. I will
4 discuss at this point the overall approach that we have
5 used to the specification of design basis accidents.
6 Paul Dickson will follow me with a discussion trying to
7 pick up some examples of bounding events that we have
8 applied to the reactor, and the safety features that
9 protect the reactor, and I will close with a discussion
10 of a couple of examples of the bounding events, the
11 bounding design basis accidents that we have chosen to
12 assess the adequacies of the safety features away from
13 the reactor.

14 (Slide.)

15 MR. CLARE: The first question is, what is a
16 design basis accident? Well, if you look at 10 CFR 50,
17 you can get a little guidance on that. 10 CFR 50.2 says
18 that you use these postulated accidents to specify
19 design bases for the plant safety features.

20 (Slide.)

21 MR. CLARE: The design bases are things that
22 determine what the safety functions are. I think we all
23 know from history that there are three basic,
24 fundamental safety functions. You shut down that
25 reactor, you cool it, and you contain any radioactivity

1 releases. But within those three general categories,
2 there can be variations. So, we use design basis
3 accidents to identify those variations of safety
4 functions.

5 We also use the design basis accidents to
6 specify the controlling parameters, the functional
7 process requirements that the safety functions have to
8 meet. For example, a safety function is to shut down
9 the reactor. The controlling parameter would be how
10 much reactivity are you going to insert how quickly so
11 that you have to counteract that with your safety
12 features.

13 (Slide.)

14 MR. CLARE: The general approach we have used
15 to specify our design basis accidents is summarized on
16 this vu-graph. Our accidents have been conservatively
17 defined using judgment to integrate the available
18 information. I emphasize the word "judgment" here. It
19 is an engineering judgment call. As Bill Morris
20 mentioned this morning, the staff and certainly we
21 haven't reached the conclusion that we know enough about
22 PRA techniques and data base to use PRA to specify the
23 design basis accidents for the plant. So, we do use
24 judgment. If you would like to, you can think of that
25 as a qualitative PRA, but we use that engineering

1 judgment to integrate the available information.

2 I have tried to list here what some of the
3 available information is. We do have a considerable
4 body of sodium reactor plant experience running back to
5 Clementine, EBR-I, EBR-II, Fermi, SEFOR. Those are the
6 domestic plants. In addition, there are foreign plants
7 up to and including Phoenix, perhaps the most advanced
8 of the foreign plants.

9 We also have sodium test facility experience.
10 In general, the test facilities are not as large as the
11 facilities we would have in our plant. They are also
12 not designed to the kind of criteria, stringent design
13 criteria we have in the plant. However, we do feel we
14 can gain a lot of knowledge about the behavior of
15 equipment, about what things you need to watch out for
16 with sodium, how it behaves from test facilities.

17 Of course, there are both domestic and test
18 facilities from which we can gather that data.

19 Light/water reactors have a lot of domestic
20 technology. However, there are certain technologies
21 that overlap a great deal. We have been talking about
22 containment. Many of the aspects of containment for an
23 LMFBR are the same as for an LWR. Also, we have to spin
24 a turbine at the end of our heat transport systems. To
25 do that, we have to have a steam water system. Much of

1 that steam water system is similar to what you find in a
2 light/water plant.

3 So, when you try to specify design basis
4 accidents involving those kinds of systems, we do so
5 considering the experience with light/water reactors.
6 We do that by and large considering the light/water
7 reactor experience. That is our largest body of data
8 and that with which we are most familiar.

9 In addition to this experience, we consider,
10 of course, licensing regulations, guidelines, and
11 precedents. I have listed here 10 CFR 50, which is the
12 portion that deals most directly with accidents,
13 Regulatory Guides, providing fairly firm guidance on how
14 we define design basis accidents, and the kind of
15 assumptions we make as to what they would be.

16 Standard format and content defines what you
17 have to have in your preliminary safety analysis. That
18 is taken into consideration. The standard review plan,
19 which is really a guideline for the staff reviewer to
20 use, but it tells us what that reviewer is trying to see
21 and the conclusion he is trying to reach in the safety
22 analysis, so we do look at that. There are a number of
23 unwritten rules in licensing, what I have called LWR
24 licensing experience, the kind of precedents that have
25 developed over the years. They are reflected in the

1 practice of licensing, but not necessarily in the
2 documentation.

3 And, of course, there was a safety review of
4 FFTF. The facility wasn't actually given a license by
5 the NRC, but the regulators did identify their concerns
6 with respect to design basis accidents. Those are the
7 kinds of things that should be looked at in FFTF, and we
8 do consider that in the specification of our design
9 basis accident.

10 (Slide.)

11 MR. CLARE: To show you how we do that in a
12 little more detail, to do that, I want to break up the
13 discussion into three pieces. I do that because we
14 think that there are three important aspects, three
15 pieces of the specification of every design basis
16 accident. The first is, what is the accident
17 initiator. Something starts the process of the
18 accident. In addition to that initiator, we assume in
19 this event that there are some additional equipment
20 failures. Certain things work, certain things don't
21 work. And specifying those failures is part of defining
22 this design basis accident scenario.

23 Then, when we evaluate the effects of the
24 design basis accident, we specify assumptions to be used
25 in the analysis of that event, the analysis of the

1 consequences, and we do that on a conservative basis.
2 That is the third piece of the specification of every
3 design basis accident.

4 (Slide.)

5 MR. CLARE: Let's take a look at some examples
6 as to how we get at those. The initiators are chosen by
7 conservatively integrating the available information.
8 Some of the most pertinent are the sodium reactor test
9 facility experience for the sodium facility, the sodium
10 light/water reactor plant experience. We of course take
11 this general experience, combine that with our knowledge
12 of the general characteristics of CRBRP as well as the
13 design details of the plant. We impose on top of that
14 the licensing regulations, guidelines, and precedents
15 for initiators of design basis accidents, and we come up
16 with what the specific initiators are.

17 I have tried to put up a couple of examples of
18 how this was done. First, I will talk about control rod
19 withdrawal. You had a discussion a little while ago
20 about control rod ejection. I purposely used a word
21 here a little different, control rod withdrawal, that
22 reflects the fact that in a light/water reactor you
23 consider ejection where in a pressurized system you can
24 eject that thing, whereas in our case, considering the
25 sodium experience and the details of our design, all you

1 can do is to withdraw that rod using the control rod
2 drive mechanism. If something were to come loose up
3 there in the support system, rather than being driven by
4 pressure out of the reactor, the control rod would
5 actually drop back down in.

6 So, I considered the light/water precedent,
7 where a control rod will move, and combine that with the
8 general experience and the detailed design, and come out
9 with a similar but slightly different initiator for my
10 design basis accident.

11 Another example is the steam generator leak.
12 There have been leaks -- rather than getting into that
13 in detail, I will be addressing that later in plant
14 experience. Let me just mention that steam generator
15 leaks is a kind of initiator I get from looking at all
16 of the sources, and I will explain that in some detail.

17 MR. ZUDANS: You are not saying that you would
18 look at the whole population of all kinds of initiators
19 at the very beginning, and then you would cull the
20 number of them based on some other criteria? You begin
21 with the fact that you are probably only looking at
22 initiators that are leading to something
23 safety-related? So far, you haven't mentioned that.
24 You just said three factors, initiators, additional
25 equipment failures, and conservative analysis

1 assumptions. You look at all the initiators that you
2 can get from experience, regardless of their ultimate
3 result.

4 MR. CLARE: Perhaps I left out an example. I
5 mentioned that we do know just from fundamentals what
6 the three basic safety functions are to protect the
7 public health and safety. You want to shut down the
8 reactor, you want to cool it, and you want to contain
9 any radiation releases.

10 MR. ZUDANS: You didn't start with that, but
11 that answers the question.

12 MR. CLARE: What we do, we start with those
13 three basic categories, and then try to look at the kind
14 of accident initiators that can present challenges to
15 those basic functions.

16 MR. ZUDANS: That is okay. I must have missed
17 that statement.

18 (Slide.)

19 MR. CLARE: The second aspect of the design
20 basis accident is the additional equipment failures. We
21 again use the conservative judgment to integrate all the
22 available information. In this particular case, one of
23 the most important input parts of the data base is in
24 fact the licensing regulations or guidelines. I have
25 tried to list some of them here. We have been talking

1 about them this morning. The traditional regulations,
2 guidelines, and precedents are that you assume the loss
3 of off-site power or on-site power for the design basis
4 accidents.

5 We have also talked this morning about some
6 other events. For some other events, we go beyond that,
7 but for the design basis accidents, this is the set of
8 assumptions that are required for licensing. Further
9 than that, there is a requirement that a single active
10 failure should be considered in a number of cases, and
11 that stems largely from the general design criterion.

12 Something that is not stated quite so
13 explicitly in the general design criteria is that we
14 assume that non-safety related equipment does not
15 function to mitigate these design basis accidents. We
16 talked yesterday about shutdown heat removal. We do
17 have a capability to remove heat out through the
18 condenser with the turbine. That is not safety related
19 equipment, not seismic category 1 equipment.

20 So, we assume that equipment is not
21 available.

22 MR. LIPINKSI: That on your list is a single
23 passive failure, but it's in the criterion.

24 MR. CLARE: There are requirements of various
25 sorts in these licensing regulations and guidelines on

1 single passive failures. The one that sticks out in my
2 mind is in a branch technical position, which is part of
3 the standard review plan, which says, in addition to
4 whatever initiating event you may have, you have to
5 assume that if you try to bring your auxiliary feedwater
6 system into play, that you have a break in the line, in
7 one of the lines by which you are trying to deliver
8 auxiliary feedwater to one of your steam drums.

9 That is an example where the staff in writing
10 its guidelines has gotten well beyond what the general
11 design criterion specifies as a single active failure
12 for the decay heat removal systems.

13 MR. LIPINKSI: The criteria we just reviewed
14 says, either assume a single active failure that the
15 passive equipment works or assume that the active
16 equipment works, and assume a passive failure. in the
17 criteria we just reviewed.

18 MR. CLARE: Was that in the containment area?

19 MR. LIPINKSI: No, I think it is probably with
20 respect to residual heat removal. Could the staff help?

21 MR. CLARE: I missed that point. It could
22 very well be there.

23 MR. KING: There is a definition of single
24 failure in Appendix A which we have used unchanged. It
25 says -- there's a footnote to that definition which we

1 have also included in our appendix, our GDC.

2 MR. CLARE: I didn't intend to say anything
3 different from that in my discussion here.

4 The only place we have gone beyond the single
5 failure is where we required number 35, residual heat
6 removal specification criteria, where we have required
7 that after the single failure, we still have two flow
8 paths available for decay heat removal.

9 MR. CLARE: That certainly would imply that if
10 I were to get a passive failure out in my portion of --
11 the sodium portion of my DHRS, I would still be able to
12 remove heat by another path. The words are not quite
13 there, but I believe the implication is clear that if
14 you have a failure in one, you could take care of it
15 with another.

16 We have also recognized in the next point in
17 terms of the additional protection against failure which
18 comes from a special LMFBR consideration, I have
19 identified it here as an example, the reactor shutdown
20 system. We do not depend on the light/water reactor
21 precedent. Essentially, the staff is saying, they are
22 going to incorporate the special LMFBR consideration
23 into this plant, and require that the shutdown system be
24 able to accommodate more than a single active failure.

25 MR. KING: Each of the independent systems

1 must be able to withstand a single failure for the
2 shutdown system.

3 MR. CLARE: And then, of course, in
4 determining what additional equipment failures we assume
5 for a particular event, we do consider the detailed
6 design of Clinch River, what equipment is safety
7 related, what isn't, how well do we go about designing
8 something.

9 (Slide.)

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 The conservatisms, the analysis assumptions
2 that we specified for each of our design-basis events
3 are done specifically to envelope the uncertainties in
4 both the design parameters. My fuel pin might be a
5 little fatter than I really intended for it to be, or a
6 little skinnier than I intended it to be. So that there
7 is a little uncertainty there.

8 There is also some uncertainty in the accident
9 phenomenology heat transfer coefficients, for example.
10 And I have listed some examples here. The pump head,
11 not delivered quite at the head of my design point, so I
12 specify in my analysis uncertainties. If high head is
13 worse, I would assume a somewhat higher head in my
14 analysis; if a lower head were worse, I would specify a
15 somewhat lower head.

16 Similarly, pressure drops in the core around
17 the loops, I provided uncertainties on heat transfer
18 characteristics, and as an example of another sort,
19 since we do burn sodium in some of our plant accidents,
20 the sodium burning chemistry has some conservative
21 uncertainties that we specify for the evaluation of the
22 consequences of the design-basis accident.

23 Now, as I mentioned earlier, we would like to
24 spend a while talking about some examples of these
25 events and how we have -- examples of what we have

1 specified for the initiators and why what we specified
2 is for the additional specifications.

3 Paul Dickson will talk about those examples
4 related to the reactor and specifically the reactor
5 shutdown system because it is a reactor shutdown system
6 that is a safety feature that provides function to
7 protect directly against the kinds of events he will be
8 talking about.

9 We do have both the primary reactor shutdown
10 system and the secondary reactor shutdown system to
11 mitigate those accidents.

12 MR. ZUDANS: You gave me the answer before,
13 and I just want to make sure that I properly understood
14 it. This is the first picture you should have flashed.

15 MR. CLARE: I thought about that.

16 MR. ZUDANS: And you should have said, we will
17 now proceed to identify the initiators and the other two
18 items, additional equipment failures and so on and so
19 forth that fall within this set. Then I would have had
20 no questions, and I would have been very happy about
21 it. Obviously, you thought the same way, but you chose
22 to give it in a different way. That was the reason for
23 my question.

24 Now, tell me as a professional, if you look at
25 this picture, forget about other things specifics, plant

1 specifics, isn't this here a statement that should
2 proceed the design criteria and you should be able to
3 draw the principal design just based on this particular
4 input in terms of what you are designing against? For
5 example, Criterion 27 satisfies one of the aspects;
6 right?

7 MR. CLARE: I think one could say that even
8 before you develop the General Design Criteria, that you
9 could say that these are the three key things I am
10 trying to achieve with high reliability by specifying
11 those General Design Criteria. And in fact, those items
12 are identified in 10 CFR 100 as being the key general
13 characteristics, general requirements on the plant that
14 must be provided.

15 MR. LIPINSKI: When I look at your
16 confinement, containment confinement, isn't that there
17 because you are going beyond the DBA, not for the DBA?

18 MR. CLARE: No.

19 MR. LIPINSKI: We were just told you don't
20 need a containment cooling system because you never get
21 up to the containment condition.

22 MR. CLARE: That's correct. This confinement
23 does not involve containment cooling.

24 MR. LIPINSKI: No. But the fact that you
25 would have the double concept with the containment steel

1 shelves surrounded by the concrete, if I look at all
2 your DBAS I do not really need the confinement, do I?

3 MR. CLARE: That is basically correct. The
4 exception I will note is not really a design-basis
5 accident but it is a radioactivity release inside
6 containment which we take as a de facto design-basis
7 accident for the DBA, the site suitability source term.
8 This is designed for the site suitability source term;
9 and since the intent of the site suitability source term
10 is to bound the design-basis accidents from the
11 standpoint of siting the plant, we have provided the
12 features in the containment confinement system as if
13 that were essentially a design-basis requirement. But
14 it does not involve cooling of containment.

15 So to summarize where I think we have been,
16 these are the three traditional top-level safety
17 functions to be performed. What we have to do is to
18 specify design-basis accidents that essentially
19 challenge these functions so that we know what the
20 features are that we are going to provide, the detailed
21 safety functions and what the parameters are, the
22 accidents that we have to be able to mitigate with those
23 systems.

24 I mentioned that Paul Dickson will address
25 reactors. I will come back and address some examples

1 out of these two categories (indicating), and I will
2 note that while we think generally of heat transport
3 loops and heat sinks and diesel generators as being
4 important to shutdown heat removal in specifying our
5 design-basis accidents we have found that there are some
6 related safety functions that have to be performed on
7 this particular plant anyway in order to assure the
8 continuation of the shutdown heat removal function
9 following one of our design-basis accidents.

10 We have to be able to mitigate sodium fires
11 out in our steam generator building. If we did not
12 mitigate those properly, the effects of the fire might
13 be such that we would disable these systems somehow,
14 some fraction of these systems. So that is a safety
15 function related to shutdown heat removal. Sodium-water
16 reaction, if we did not properly mitigate a sodium-water
17 reaction, it might affect our shutdown heat removal
18 capability. So that is a safety function.

19 Those spent fuel is not stored in the
20 reactor. It is fuel which we have to remove decay heat
21 from, so we have a safety function to remove decay heat
22 from our spent-fuel storage pool. Similarly with the
23 mitigation of radionuclide releases, we, of course, have
24 the containment and confinement systems in addition in
25 order to prevent sodium fires in certain cells in our

1 containment from being a challenge to containment
2 integrity, we provide cell liners. So that it is a
3 safety function for the cell liners that relates back to
4 the mitigation of radionuclide releases.

5 Also, as we talked about a while back, control
6 room habitability is important. I suppose I could also
7 put that up here under shutdown heat removal. When I
8 made up the slide, I was thinking about habitability
9 from a radiation protection standpoint, and because it
10 was from that standpoint, I identified that under
11 radionuclide release.

12 However, the reason you need to be in the
13 control room is, of course, to be able to principally
14 assure your continuing to remove heat from the reactor.
15 So this, I think, is a pretty good summary of the
16 detailed safety functions that we have found are
17 necessary in our plant in order to achieve the three
18 principal objectives for protecting the public health
19 and safety. And we will talk about the details and a
20 few examples.

21 MR. CARBON: I am puzzled a little bit as to
22 why you don't have a fourth one there which would be
23 Number 1; that is, that you don't have accidents in the
24 first place.

25 MR. CLARE: We certainly feel that that is a

1 very important objective in the design of the plant.
2 The topic of discussion is design-basis accidents, which
3 inherently assumes that somehow I have not achieved that
4 first objective of having an accident. Again, that
5 tends to be a traditional outlook in the licensing
6 field, I guess, from my perspective.

7 We do feel it is important. We spend an awful
8 lot of time making sure we do not have accidents.
9 However, that is not part of a discussion on what are
10 your design-basis accidents, so I did not include it
11 here.

12 MR. ZUDANS: I would like to comment because I
13 like this picture very much in the sense that now I
14 could imagine a Monte Carlo process where I throw in a
15 number of initiators and I look for the one that
16 challenges or a specific system. That then becomes the
17 design basis for that specific system, and I can proceed
18 ad infinitum.

19 And, of course, you cannot do an infinite
20 number of exercises, so you go back to past
21 experiences. And that is another way of finding DBAs
22 for a specific component by which to design that. That
23 is the objective.

24 The criteria we discussed this morning should
25 really only look at this set and not the other set. The

1 other set is only the result of set targets at this
2 level to find some specific in mechanics as to how to
3 design a component, that these would not be violated.

4 MR. CLARE: I think that is right. The only
5 thing I would do is couple them to your Monte Carlo
6 process, with admitted limitations, is what was
7 suggested by one of the judges on the Atomic Safety and
8 Licensing Board, which is to combine that with some
9 horse sense. And, of course, we take bounding
10 assumptions without having examined all the subsets.

11 MR. ZUDANS: Of course, I don't disagree.
12 That's good.

13 MR. CARBON: But, Xenon, your General Design
14 Criteria do not all flow from these. It seems to me
15 that you are saying they do, and they really don't.

16 MR. ZUDANS: I am saying they don't. Some of
17 the General Design Criteria, like 27, fit the scheme
18 very nicely; others don't.

19 MR. CLARE: I don't know of any General Design
20 Criteria that don't fit this scheme, I might add.

21 MR. CARBON: Number 1 says quality assurance.

22 MR. CLARE: Quality assurance just says that
23 whatever system I come up with -- my reactor shutdown
24 system, for example -- I will implement with a high
25 quality in order to achieve a high reliability.

1 MR. CARBON: Perhaps it is semantics, but from
2 my way of using the words, Number 1 says you don't need
3 a reactor shutdown system.

4 MR. CLARE: I also apply quality assurance to
5 those type of systems.

6 MR. STARK: While we are waiting for Dr.
7 Dickson to get ready, I Xeroxed something that I think
8 addresses Dr. Lipinski's comments this morning.**I think
9 he made a comment stating you are asking whether the
10 single failure and independence requirements can
11 continue on into the electrical protection system.

12 MR. LIPINSKI: Right.

13 MR. STARK: What I have Xeroxed here, and I
14 will give it to the chairman, is 50.55.A paragraph (h),
15 which discusses protection systems. It basically says,
16 for construction permits issued after January 1, 1971,
17 protection systems shall meet the requirements set forth
18 in addition to revisions to IEEE 279. And, in fact, I
19 have also Xeroxed IEEE 279, and in it they provide
20 definitions for single failure criteria and channel
21 independence. And I will submit the whole package that
22 I think addresses your question.

23 MR. LIPINSKI: That won't resolve the issue,
24 because when you are talking reactivity control system,
25 by definition those are the mechanical drive and

1 reactivity absorbers. Your criteria does not go back
2 and say, the electronic systems have to have two
3 independent sets of channels that are redundant and
4 multiple within themselves.

5 MR. STARK: But they are part of the
6 protection system.

7 MR. LIPINSKI: Yes. But that is what I am
8 saying. Your protection system criteria does not get
9 that idea across.

10 MR. STARK: But they are required by the
11 regulations --

12 MR. LIPINSKI: No, this does not require
13 primary/secondary system, it just says -- 279 allows me
14 to have a two-channel system. That specification says I
15 can get by with two channels. It does not say I have to
16 have a triplicated system. I can take one channel and
17 put it in a test mode so long as the interval is short
18 compared to the reliability I need to guarantee a safety
19 function with one remaining channel in operation.

20 There is no connotation that says I have to
21 have two triplicated sets of measurements to peak
22 primary and secondary systems.

23 MR. STARK: I believe they even address
24 testability, too.

25 MR. LIPINSKI: Yes, you will find a statement

1 on a two-channel system. You can take one out of
2 service --

3 MR. MORRIS: Maybe we should make it clear
4 that the Staff interprets "systems," the terminology
5 "reactor shutdown system," to include all the systems,
6 including the electronic components. That's the general
7 interpretation. That is what you will see reflected in
8 the detailed criteria that are developed in the SER that
9 emanate from this general criterion.

10 I think you recall that at the subcommittee
11 meeting on electronic controls that this was brought out
12 in pretty good detail at that time that that is what
13 would be coming forth in the detailed design. But
14 generally, we interpret "systems" to include the whole
15 system.

16 MR. LIPINSKI: In the LWR they are requiring a
17 backup boron injection system so that you don't have the
18 problem of trying to find out what's going on with the
19 rods in the plant protection system. In your case, you
20 do not have the equivalent of the boron system, so now
21 you have to be very precise in your definition as to how
22 you are accomplishing that equivalent function for the
23 LMFBR.

24 All I am saying is as I read your criteria I
25 do not come away with what you are requiring for the

1 protection system; I do for the rods. If you are
2 defining reactivity control systems to include sensors,
3 then I don't have a problem, but your definition doesn't
4 say that specifically.

5 MR. KING: I thought I agreed this morning to
6 take a second look at those words to make sure it is
7 clear.

8 MR. DICKSON: Shall I go on?

9 MR. CARBON: Yes.

10 MR. DICKSON: What I am going to cover are
11 three events. One is an undercooling event, and two are
12 overpower events.

13 (Slide.)

14 The undercooling event I will touch on is not
15 really a design-basis accident, because it's a
16 natural-circulation event. In the liquid metal plant in
17 general, and in CRBR in particular, the undercooling
18 events rarely have much of an effect on the core. Steam
19 line breaks and events out in the intermediate system
20 have no effect on the core. The core just thinks it's a
21 normal scram.

22 A few events do have some effect on the core,
23 such as a pump seizure, there is a slight temperature
24 rise. The most dramatic effect on the core is from
25 natural circulation events. So we look at that event as

1 a bounding case for the core. Of course, the initiator
2 for that is loss of off-site power.

3 (Slide.)

4 Then following the format George laid out
5 earlier, the other additional equipment failures that we
6 assume is all three diesel generators fail to start.
7 Then the two out of three logic systems is all that's
8 required to trip either shutdown systems. So by
9 definition, one train in that logic system in either
10 shutdown system can fail and that shutdown system will
11 still work.

12 On top of that, only one rod in the system
13 that does work fails to insert. Now, in the
14 natural-circulation event it really makes very little
15 difference, one rod or the fact that only one shutdown
16 system is used.

17 (Slide.)

18 MR. CARBON: Is there ever a time when one of
19 the three logic circuits is disabled for maintenance or
20 that kind of thing?

21 MR. DICKSON: For testing, yes, sir.

22 MR. CARBON: Is that very much time?

23 MR. DICKSON: There is a relatively short
24 interval of time.

25 Can you be specific, George?

1 MR. CLARE: It would be a relatively short
2 interval of time. But the other pertinent aspect of
3 that is when it's undergoing a test, I believe without
4 exception the reactor is put into a tripped condition so
5 the two remaining channels are in a one-out-of-two
6 configuration.

7 MR. DICKSON: That's a good point.

8 MR. LIPINSKI: They can test channels of
9 two-out-of-three logic, but the logic that the system
10 propagates out from the channel and tells the rods to go
11 is never functionally tested to drop the rods. They go
12 as far as the breakers. The system is never totally
13 defeated.

14 MR. DICKSON: No, it's not. In fact, as
15 George said, when one of the three trains is under test,
16 when either of the other two gives a trip signal, it
17 will trip.

18 MR. CARBON: That takes care of my question.
19 Either of the other two will.

20 (Slide.)

21 MR. DICKSON: In addition to that, there are a
22 variety of assumptions. You have seen them before.
23 Take the minimum pump head initially, a maximum core and
24 system pressure drops -- that's not only initially, but
25 throughout the event. We do this in all our accidents.

1 So this is not really a different list. You will see it
2 again, although I will not dwell on it each time.

3 For this one it is a little different. We
4 assume the pumps stop with the maximum impeller
5 backpressure; that is, it stops in its worst location.
6 We take a worst-case doppler coefficient, including all
7 uncertainties, minimum control at shutdown worth, which
8 is one stuck rod, as I mentioned before, 3 sigma hot
9 channel and hot spot factors and that's an abbreviation
10 for a combination of direct factors plus statistically
11 combined uncertainty factors.

12 We looked at the highest power and the highest
13 temperature hot rods at the worst time in life. For the
14 natural-circulation event that means we look at the
15 beginning of life for the fuel when it is hottest and at
16 the end of the cycle for the blankets when they are the
17 hottest.

18 We take the worst end of the uncertainty range
19 for all properties, for example, fuel CP and fuel clad
20 gap conductance. At the present time we don't take
21 credit for inter- and intra-assembly flow need
22 redistribution. We are developing a code that will take
23 care of that, and that will be eliminated not to take
24 out any conservatism but because it will more reasonably
25 describe what is going on in the core when you account

1 for that flow distribution.

2 All negative reactivity feedbacks are
3 neglected. We take a conservative 2/10ths of a second
4 delay for the PPS logic scram breaker and the control
5 rod, unlatched time delays. All those assumptions are
6 assumed to occur at the same time.

7 MR. CARBON: In your general analyses, though,
8 you do allow for doppler, do you not?

9 MR. DICKSON: Yes, sir.

10 MR. CARBON: So your third-to-the-last bullet,
11 should you really be correct to say "except doppler"?

12 MR. DICKSON: That is correct. That is an
13 overstatement. I shouldn't say "all negative." Just
14 the slower ones are neglected.

15 MR. KASTENBERG: How sensitive are your
16 calculations to the stuck rod, whether you have one or
17 two or none?

18 MR. DICKSON: In that event it doesn't make
19 much difference because just a few dollars in it was
20 already just critical and the negative reactivity
21 insertion goes in before the flow coasts down. So you
22 get slight difference early on in the amount of neutrons
23 still bouncing around. But it is small compared to the
24 sensible heat and the decay heat. So you almost don't
25 see a difference there. That's why I commented. On

1 that chart it was gilding the lily, I guess, but since
2 we do it as a matter of form on every event, we do it on
3 that one.

4 (Slide.)

5 This one is going to be covered in 2. This is
6 not our worst reactivity insertion event, but it's the
7 worst reactivity insertion event -- let me correct that
8 -- the worst reactivity insertion event is the SSE.
9 This one is a little different, so we decided to cover
10 both of them. It's the rod runout, which is not as bad
11 as the SSE, but as I said, it's different. So we cover
12 it.

13 (Slide.)

14 The initiator of that event, of course, is the
15 controller failure. You could also include in this
16 under "controller" meaning control room operator as well.

17 (Slide.)

18 The additional failures we assume then is that
19 our high flux blocking circuit fails. We have a
20 blocking circuit at 103 percent of full power that it
21 will stop the rod from moving out.

22 This goes back to your comment, Dr. Carbon.
23 We want accidents not to happen rather than to take
24 steps to mitigate them. So we have blocking circuits to
25 make sure that the accident doesn't happen. I believe

1 at the INC meeting the designer of this system said his
2 objective was to never challenge the PPS system. And
3 that's what he is working on.

4 Also, there is a flux to flow mismatch
5 blocking circuit. A rod bank position limiter circuit.
6 This one is still being designed. It is not yet in the
7 design, nor is it described in the PSAR. But it's under
8 design because we want to have a rod bank position
9 limiter circuit.

10 There is a single rod out of alignment
11 blocking circuit that is designed. There are actually
12 two trains of this. One comes from the absolute
13 position indicator, which is a measure of where the
14 drive line is. An average of those are all taken, and
15 the furthest one away from the average is then compared.

16 A second train looks at the relative position
17 indicator, which comes from counting the number of steps
18 that has been stepped in by these control rods, keeping
19 track of those, again taking an average and determining
20 which one is furthest out. If any one is out by more
21 than half an inch, it will block and prevent any further
22 out-motion until the system is corrected.

23 In addition to both of those blocks, those two
24 signals, one from the absolute indicator and one from
25 the relative indicator, are compared. And if they

1 differ by more than a set amount, an alarm goes off in
2 the control room to let the operator know that one of
3 the systems may not be telling them quite the right
4 story.

5 Then again, the two-out-of-three logic to trip
6 either shutdown system. Only one shutdown system
7 operates, and one rod in that system fails to insert.

8 MR. CARBON: In your two-out-of-three logic,
9 does the operator always know right away if one of the
10 three logic trains is inoperable?

11 MR. DICKSON: Yes.

12 MR. CARBON: How does he know this?

13 MR. DICKSON: I don't know the details.

14 MR. CARBON: Lights light up, or alarms?

15 MR. DICKSON: Alarms sound in the control
16 room. And you can query the computer to determine just
17 exactly what the failure is.

18 MR. LIPINSKI: There is a regulatory guide
19 that deals with the bypass and inoperable safety
20 systems. They have to be indicated to the operator in
21 the control room.

22 MR. CARBON: He would know immediately?

23 MR. LIPINSKI: Yes.

24 MR. DICKSON: I guess since Dr. Mark isn't
25 here, I can comment on our inoperable status monitor

1 which when I mentioned it some months ago he objected
2 to, did we not want the status monitor to operate? But
3 I was only quoting the regulations.

4 MR. CARBON: Is shutdown required right away?

5 MR. LIPINSKI: No. With the single-channel
6 failure the system is still operational. If you have a
7 legitimate call for scram, the system would still
8 function. If the channel -- what happens if it's
9 inoperable when you put it in that state, they
10 immediately go to one out of two.

11 MR. CARBON: Does the reg guide require that
12 they immediately go to one out of two, shift over?

13 MR. LIPINSKI: That I don't recall in detail.
14 I believe it does. You are supposed to indicate that
15 the system is out of service, and if you know it's out
16 of service, then you go to a lower level of redundancy,
17 maybe one out of two.

18 (Slide.)

19 MR. DICKSON: In analyzing this event, we take
20 the rod bank operating at the core midplane which has
21 the highest differential worth so you get the highest
22 amount of rod runout worth. We take the maximum rod
23 worth assumed for rod runout, which says that that had a
24 plus 3 sigma value on its worth. Now the rest of the
25 rods that go in are all minus 3 sigma on their worths.

1 And since some of those cannot happen in opposite
2 directions in any one given set of rods, it is an overly
3 conservative assumption. But we can live with it.

4 Again, we take the so-called thermal hydraulic
5 design value conditions; that is another way of saying
6 the minimum pump head and the maximum pressure drops
7 throughout, which includes in those maximum pressure
8 drops fouling of the steam generators and plugging of
9 steam generator and IHX tubes over the lifetime of the
10 plant.

11 And we take an extra 20 degrees in the
12 temperature on top of the normal thermal hydraulic
13 design value. Again, worst-case doppler. Minimum
14 control rod shutdown worth, 3 sigma hot spot factors and
15 so on. I won't go through that whole list again, but I
16 will note them only to reemphasize that that is the type
17 of conservatism that we do take in these events.

18 (Slide.)

19 I might also note that I did include among
20 those failures the failure of the speed controller, but
21 for the analysis in Chapter 15 we also assume the speed
22 controller of the rod that has run out has also failed
23 so that it runs out at its maximum mechanical speed of
24 72 inches per minute. That was the design requirement
25 that has been met, and the speed control is really

1 limited to about 45 inches a minute. We still use the
2 72. On the rod bank runout, we do not assume that it
3 runs out at higher than its design speed because it
4 would take failure of six independent separate speed
5 controllers to change from a normal design speed.

6 The next one is the SSE reactivity insertion.

7 (Slide.)

8 I want to explain that a little bit with some
9 pictures partly because I like pictures better than
10 words, I guess, and I had to get one or two in here.
11 This is a cutaway of the lower internals of the CRBR.
12 These are the lower inlet models shown up here with no
13 fuel or blankets inserted. They would get inserted into
14 the holes that you see at the top of the modules.

15 So that fuel and blanket and control rod
16 assembly or control duct assembly structure are
17 cantilevered here and then are fastened -- not fastened
18 -- but constrained at two former rings that have an
19 interconfiguration that matches the outer configuration
20 of the core. At this place right here (indicating),
21 which is referred to as the above-core load pad and
22 here, the top load pad (indicating).

23 (Slide.)

24 I might leave this on to keep you oriented
25 while I put this one on. These are the inlet nozzles of

1 all of the assemblies as they stick into the lower inlet
2 modules. And then the core has a gap between the
3 assemblies and even a gap at the load pads except that
4 it is a smaller gap at the load pads. There is one
5 plane here at the lower core former and another one at
6 the upper core former.

7 The whole objective of this system is that
8 when it's cool at refueling temperatures they will be
9 loose enough that they can be inserted and removed
10 without excessive force. But when the system expands at
11 temperature, they will be locked into place, maintaining
12 a core configuration with a certainty as to where the
13 control rod locations are and so that the assemblies do
14 not move.

15 If that is the only mechanism that happened,
16 simple thermal expansion, that would be relatively easy
17 to do. We do have two other mechanisms at play.

18 (Slide.)

19 One is differential thermal expansion. The
20 other is radiation creep and growth that has a
21 comparable effect to differential thermal expansion
22 except it is over a longer time period. That is
23 illustrated on this next slide.

24 (Slide.)

25 Here we see an off-power system and nice

1 straight fuel rods. Those are not irradiated rods
2 because they would have some bow to them. And the
3 bowing from the radiation creep and swelling would
4 aggravate the condition I am talking about. But
5 basically it is illustrated here.

6 When you go on power, these shield assemblies
7 would tend to not expand, or rather bow, because they
8 are rather uniformly heated. But most of the other
9 assemblies will tend to bow in this type of
10 configuration, moving away from the above-core load pad
11 and constraining themselves tightly at the top load
12 pad. They do that of course because they have a
13 gradient across them, a thermal gradient across them, as
14 well as a neutron fluence gradient across them.

15 The bowing is not uniform because the
16 temperatures are not uniformly decreasing as you go from
17 the center out. Even if we didn't have a heterogenous
18 core, they wouldn't be uniform because you would have
19 cooler control assembly locations. But with our
20 combination of both control assemblies and blanket
21 assemblies in the core, this bowing is quite complex.

22 Now, as these things went to bow and form a
23 tight portion in through this region and leave a gap out
24 at the side, they won't always fit exactly perfectly.
25 If any one of the hexes is turned slightly, it can

1 conceivably leave a little bit of a gap. The concept
2 is, with that little bit of a gap, if you rattle it as
3 in an earthquake and it only has a little gap because
4 it's been turned, it can then rotate and slip into
5 position and close up some of that gap.

6 So it's been held a little apart by virtue of
7 some stackup of some gas. And then when it's shaken
8 during an earthquake, the gaps close. The assumptions
9 we used in this analysis is the power is lost to the
10 pumps and the reactivity insertion due to core
11 compaction effects comes in at the worst time in the
12 event to delay in control system scram speed due to
13 seismic-induced forces on the drive line and the guide
14 structure is also included.

15 MR. CARBON: Do you end up with a greater
16 reactivity step than you would, say, with fresh cold
17 fuel, more than one good-size gap?

18 MR. DICKSON: Well, the fresh cold fuel is one
19 of the lowest insertion points in time. We look at this
20 over a variety of cycles and find the worst place in
21 time to apply this event. It is not at the end of cycle
22 4. It is not at the end of cycle 4 because the fuel is
23 cooling down towards the end although the irradiation is
24 worse then, the irradiation bowing. It's somewhere in
25 the middle of the equilibrium cycle that it has the

1 largest potential.

2 I might note that what we analyzed for is 60
3 cents. Nominally, what could happen -- and that
4 "nominal" is based on as-measured FFTF assembly
5 dimensions -- it's only a 14-cents event. There is a
6 significant amount of uncertainty in that analyses,
7 however, and the amount of uncertainty is even greater
8 than the nominal value. It is 30 cents of uncertainty.
9 So our prediction is on the 3 sigma basis we are talking
10 about a 44-cent event as far as the core restraint
11 system is concerned with an allowable of 60 cents which
12 is what is analyzed for.

13 When I say "what is analyzed for," I mean
14 again a two-out-of-three logic to trip either shutdown
15 system, only one shutdown system operates and only one
16 rod in that system fails to insert.

17 (Slide.)

18 On this basis it is the primary system that
19 works, or both. We don't even anticipate any failures.
20 If the secondary system only works, then you would have
21 some fuel failures. But we are a long way from sodium
22 boiling and core cooling geometry lost. Again, the same
23 type of conservatisms are noted.

24 (Slide.)

25 The conclusion is that the undercooling and

1 overpower transients have been looked at. We looked at
2 the worst cases on an extremely conservative basis, and
3 all events meet the acceptance criteria of Chapter 15.

4 MR. CARBON: These calculations you have come
5 up with are quite a bit higher total sodium void worth
6 than some accident conditions than we used to calculate
7 5 years ago or something. Is there any chance that some
8 people feel the 60 cents or whatever is really an
9 inadequate amount?

10 MR. DICKSON: No. The 60 cents is not related
11 to sodium void worth.

12 MR. CARBON: I know that.

13 MR. DICKSON: The 60 cents is related strictly
14 to the amount of gap you can have there.

15 MR. CARBON: I am saying some of our
16 calculations seem to change with time, for reasons that
17 I do not understand.

18 MR. DICKSON: Well, some of them do. The
19 sodium void worth, for example, changed somewhat from
20 the change from ENDF/BIII to ENDF/BIV. In fact, if you
21 take rod data from ENDF/BIII to ENDF/BIV you will find a
22 fairly significant change. If you take either of those
23 and normalize them to the critical experiments, say, the
24 ZPPR-11 experiments, you get essentially the same result.

25 The reason for that is, of course, when you

1 normalize to reality, you must predict reality. What
2 you have to do with the ZPPR-- with the ENDF/BIII
3 analyses is increase it, put on a positive bias to match
4 the ZPPR-11 and with ENDF/BIV it's a very small negative
5 bias to match ZPPR-11. But since we do have very good
6 data from ZPPR-11, including good uncertainty data and
7 have analyzed it thoroughly, we feel very comfortable
8 that we have a very good handle on where our sodium void
9 worth is and what our uncertainties are relative to that
10 sodium void worth at this time.

11 MR. CARBON: You also feel very confident
12 about the compaction of the reactivity?

13 MR. DICKSON: Oh, yes. We have had a base
14 program underway for a number of years in which we have
15 a full-scale mockup of the Clinch River-type fuel
16 assemblies. They are mocked up at least to the extent
17 of the load pads being the right configuration, although
18 they are in air, not sodium.

19 We have subjected that particular rig to a
20 variety of tests over some at least 5-year time period,
21 checking for the type of misalignments one can get, the
22 type of stackup one can get. We feel we have a very
23 good handle on that. There is still some residual base
24 program going on in this area to define the creep and
25 swelling equations that one must use. That's probably

1 the most uncertain part in the whole thing, which is why
2 we have a 14-cent nominal and a 30-cent uncertainty on
3 top of that for a total of 44 cents.

4 I can't conceive of the uncertainty growing
5 that much larger or any other change making it that much
6 larger. In fact, some of that uncertainty will
7 disappear when we have as-built measurements. That
8 uncertainty includes an uncertainty on the size of the
9 load pads itself or the size of the gap you get. When
10 you measure the assemblies as they're built, you have a
11 way to eliminate that one set of uncertainties. And
12 that is a fair amount of it.

13 MR. MARK: I am sorry I had to be out for a
14 while. You probably went over this. How confident are
15 you that you have got, A, the right plutonium isotope
16 set and the cross-sections to go with those? Or does it
17 matter very much?

18 MR. DICKSON: It matters to the extent that it
19 changes your loadings if you change the isotope set, and
20 it matters to the extent that you would have a different
21 source term if you had larger amounts of certain
22 isotopes. From the standpoint of --

23 MR. MARK: I was thinking more of the
24 criticality than of the source term, of course.

25 MR. DICKSON: Because of the uncertainty, one

1 of our requirements is to be able to operate this plant
2 either with the grade of fuel that is being loaded into
3 FFTF and for which there is a supply for us, or with
4 effluent from a light-water reactor. We have looked at
5 both. There is no particular problem.

6 I might note that at the time this project
7 started we intended to have light-water reactor recycled
8 plutonium to use because at that time there was a plan
9 to have recycled plutonium available. That disappeared
10 over time, and we had to go to alternate sources. We
11 can use either plutonium source of any isotopic
12 composition. As we recycle it in Clinch River, we
13 gradually convert it to the same form either way.

14 I might note that we do not, as the
15 light-water reactors do, build up the plutonium isotopes
16 238 and 241, which are particularly bad actors from a
17 radiological health standpoint. Rather, we burn them
18 out. If we started with light-water reactor plutonium
19 and continued to recycle it, we would build up plutonium
20 239 and burn out the 238 and 241.

21 MR. MARK: I wonder if anyone happens to have
22 here any samples of the isotope set that you would
23 expect to encounter at one or two stages in your
24 cycling?

25 MR. DICKSON: We have taken FFTF-grade

1 plutonium and run it through 18 cycles, starting a
2 recycle after 4 years. You don't get enough back to be
3 able to recycle early, putting a little feed into the
4 fifth year, then continuing to recycle.

5 MR. MARK: I would be interested in the
6 relative abundance of 238, 239, 240, 241, 242.

7 MR. DICKSON: Plutonium-238, wherever it
8 starts off, burns down in Clinch River at equilibrium,
9 which may be 20 or 30 years, I'm not going to tell you
10 we get to equilibrium quickly, but it will ultimately
11 equilibrate at .13 percent, which is trivial. It is
12 less than we use in either FFTF grade or light water
13 reactor recycle. The worst case from a radiological
14 dose standpoint is our assumption that our fuel gets
15 made 5 years before it is used with a fairly large
16 amount of plutonium-241 because from that we build up
17 americium-241, which leads to increased amounts of
18 curium isotopes, which is the major source for early
19 buildup of plutonium-238.

20 Once we get into a recycle mode, we then burn
21 down, as I mentioned, the plutonium-238 as well as the
22 plutonium-241. I don't recall the equilibrium value of
23 that, but it is below the original source of either
24 FFTF-grade or the light-water reactor recycle.

25 MR. MARK: I am wondering if I could trouble

1 someone, perhaps this applies to Paul Boehnert, a couple
2 of samples like the Starkey and after a certain amount
3 of beating up slightly the isotope list. The reason for
4 asking the question is yesterday we were favored with --
5 I don't know if you were still here --

6 MR. DICKSON: Yes, I was.

7 MR. MARK: -- favored by Tom Cochran, and he
8 used the particular isotopic distribution there and it
9 wasn't clear to me whether that was the one that should
10 have been used for Clinch River or not.

11 MR. DICKSON: In Dr. Cochran's analyses he
12 made the assumption that recycling plutonium through a
13 light-water reactor through Clinch River would be the
14 same as recycling it through a light-water reactor.

15 MR. MARK: I believe he did, because he listed
16 some recycle light water isotope lists.

17 MR. DICKSON: And he used that as a basis of
18 increasing the dose.

19 MR. MARK: Precisely.

20 MR. DICKSON: On the contrary, we burn out the
21 isotopes that he suggested.

22 MR. MARK: That's why I would like to see what
23 should have been used there.

24 MR. DICKSON: Can we provide him that? I am
25 asking the Staff.

1 MR. CHECK: Certainly.

2 MR. DICKSON: All right. Yes.

3 MR. CHECK: My goodness, I didn't realize I
4 had that -- certainly, yes, of course.

5 MR. MARK: Well, I would just like to see a
6 sample in order to clear up in my mind where Cochran's
7 statement came from.

8 MR. DICKSON: Do any of you happen to have a
9 copy of it?

10 (No response.)

11 MR. CLARE: Dr. Mark, the information I think
12 you are looking for is available both in our
13 environmental report with the fuel cycle effects and
14 also in the Staff's supplement to the Final
15 Environmental Statement, a draft of which is available.
16 And the supplemental is scheduled to come out very
17 shortly and within a very short period of time I am sure
18 we could make that information available.

19 MR. DICKSON: I am sure that was in there, but
20 that full run of 18 cycles, I didn't think it had been
21 published.

22 MR. MARK: Well, I have left Boehnert with
23 those suggestions, and he will be able to find some
24 numbers for me. Thank you.

25 MR. KASTENBERG: I have a question. Yesterday

1 we saw the results of some calculations for the SSE in
2 the thermal hydraulics meeting. If I recall, on one
3 table it showed for one specific case that you exceeded
4 the fuel melting temperature or reached the fuel melting
5 temperature for one case that you ran. I wonder if you
6 consider that as part of the design basis -- unless I am
7 missing something.

8 MR. DICKSON: I am not sure what you mean. Do
9 we consider fuel melting as part of the design basis?

10 MR. KASTENBERG: In one of the cases I believe
11 you showed you reached the melting temperature somewhere
12 in the core. We were talking about the General Design
13 Criteria, and I would think fuel melting would be
14 excluded from the design basis.

15 MR. DICKSON: We exclude fuel melting for all
16 anticipated upset or emergency events. For faulted
17 events we only require core-coolable geometry as our
18 ultimate criteria. We have further defined that as
19 being no coolant boiling. And we are not even close to
20 coolant boiling in that particular event.

21 MR. CLARE: I think a clarification would be
22 helpful. That was reached at the center of the fuel
23 pin. That is not an indication that anything close to
24 an assembly or even one pin would actually meet the
25 melting temperature or exceed it over any significant

1 fraction of its area.

2 MR. KASTENBERG: Are you saying the General
3 Design Criteria permits you to reach melting?

4 MR. CLARE: At the centerline of the fuel
5 pellet, yes.

6 MR. ZUDANS: That contradicts all the
7 discussions. These events we are discussing right now
8 are not included in the design-basis events. This is
9 the power blackout, which is supposed to be considered
10 generically and independent of GDC.

11 MR. CLARE: What we are discussing here is the
12 safe shutdown earthquake which inserts a 60-cent step of
13 reactivity.

14 MR. ZUDANS: But that is not part of the GDC.
15 These events are bounding events for natural
16 circulation.

17 MR. DICKSON: No, sir. He is talking about an
18 SSE, not natural circulation.

19 MR. KASTENBERG: The subject of this talk is
20 design-basis events. That's the subject of his talk.
21 He has a case where he reaches fuel melting, and I am
22 asking him whether that is permitted under the General
23 Design Criteria.

24 MR. DICKSON: Yes. Centerline melting over a
25 fairly small range of the fuel of as much as 17

1 inches -- I am sorry, 17 percent of the cross-sectional
2 area, for one pin under the conditions that I outlined,
3 all the uncertainties and the secondary scram only.
4 That does not challenge core-coolable geometry at all.
5 Pins have been operated for long periods of time. I
6 might also try to put that in context with a curve.

7 MR. CARBON: Excuse me. Let me add something
8 in relation to the principal design criteria. If you
9 look at the definition for fuel damage limits on page 6
10 of that final draft, it has under that definition,
11 "Allows a limited amount of melting." So it does allow
12 some limited amount of fuel melting in the core-basis
13 events.

14 MR. DICKSON: If I could put that in a little
15 more context here, the amount of time we are talking
16 about is on the order of a second or two.

17 MR. CARBON: Did you say Criterion Number 6?

18 MR. KING: Page 6. Definition of fuel damage.

19 MR. ZUDANS: These three events that you have
20 just described, one was an undercooling event and, two,
21 the reactivity insertions, you can get out of them only
22 by the fact that you have natural circulation available.

23 MR. DICKSON: No, sir, no. The only event
24 that involve' natural circulation was the
25 natural-circulation event.

1 MR. ZUDANS: If you lost power to all your
2 pumps, what else do you have there to remove the heat?

3 MR. DICKSON: I haven't lost power to all the
4 pumps in the other two events. I still have motive
5 power. In the case of the SEE, I have lost off-site
6 power.

7 MR. ZUDANS: You say power lost to pumps. I
8 assume you lost all power. You don't mean that?

9 MR. DICKSON: That is not well worded. That
10 is the pumps are tripped from full power because that is
11 what provides the power for -- that's what provides -- I
12 am sorry. The motive power for full power is the
13 off-site power. The diesels only run this pony motor.

14 MR. ZUDANS: That makes a big difference if
15 you have the pony motor still running. You can run it
16 about 10 percent of your flow in natural circulation.
17 What about the other event?

18 MR. DICKSON: The rod runouts are still
19 power-available.

20 MR. LIPINSKI: What if one of the diesels fail
21 to start?

22 MR. DICKSON: I didn't mean to imply all three
23 of those events happened at the same time. Those are
24 three separate events.

25 MR. LIPINSKI: The loss of power is loss of

1 off-site power and the first set in that second set of
2 assumptions was the diesels fail to start.

3 MR. DICKSON: That applied to one event.

4 MR. LIPINSKI: That was station blackout?

5 MR. DICKSON: Yes. But the next two events,
6 the rod runout and the SSE, were not combined.

7 MR. ZUDANS: I am glad you corrected my
8 understanding, because you did not say the pony motor
9 was still running. So you did lose all the power. The
10 only time you lost all the power was in bounding core
11 undercooling event.

12 MR. DICKSON: That's correct.

13 MR. ZUDANS: And the only way you can get out
14 of that is by natural circulation?

15 MR. DICKSON: That is correct.

16 MR. ZUDANS: And that is not a design-basis
17 event?

18 MR. DICKSON: That's correct, but it bounds
19 for the reactor all design-basis undercooling. It
20 bounds all design-basis events, and no other
21 design-basis event.

22 MR. ZUDANS: If that's the case, it totally
23 contradicts, if that is the case, which it is, I can
24 see, I can't see how it could be left out of the General
25 Design Criteria if it is a bounding event. You are

1 designing to it. It is not mentioned. Well, what I
2 heard from Staff was station blackout is a different
3 generic issue and it will be resolved for other plants
4 and it will be resolved for this one. But you have
5 already resolved that for design, and it's hard for me
6 to understand why that's left out.

7 MR. CLARE: I think we have to understand that
8 there is a difference between saying we have designed
9 for natural circulation in the main coolant systems and
10 saying that we have accommodated the station blackout is
11 a design-basis accident. There is a difference between
12 those two. We chose the presentation of the
13 natural-circulation event here because in a sense it is
14 the only interesting undercooling event there is. If
15 you go beyond that, if you go back down from that to
16 something that is in the design basis, it's really not
17 very interesting. This is essentially a normal scram,
18 as Paul pointed out in his presentation.

19 MR. ZUDANS: I have no complaints with you
20 guys. I have complaints with Staff. I don't understand
21 how you cannot make this part of the package of the
22 General Design Criteria.

23 MR. MORRIS: Bill Morris, NRC Staff. Perhaps
24 part of our reservation with regard to the station
25 blackout in regard to making it a design-basis event is

1 that there is a precedent. When you have a design-basis
2 accident, the safety systems that mitigate that accident
3 must meet certain criteria. One of those criteria is
4 the single-failure criteria.

5 We think that at this time it would be a
6 compounding of the number of failures that would have to
7 occur before you get to a station blackout situation and
8 then in addition require that the single-failure
9 criteria be met by the systems to mitigate the event.
10 For instance, the stream-driven turbine, that would meet
11 the single-failure criterion. We don't think that
12 that's a reasonable thing to do. That is one of the
13 reasons that we stop short of thinking of this as a
14 design-basis accident. We think that there is just too
15 much that would be an unreasonable compounding of
16 failures.

17 I think that is part of our hesitancy in going
18 ahead and including that under the spectrum of the
19 DBAs. Perhaps the Applicant has another view of that.
20 But that, in conjunction with the fact that there is an
21 unresolved safety issue, we would like to see where we
22 step before we change what the LWRs are doing.

23 We think we are just about in the right spot.
24 We are taking cognizance of the fact that it can occur.
25 We are looking at the event. We expect that the event

1 will be adequately mitigated, but we do not think that
2 it is yet reasonable to say we must mitigate it the same
3 way we would mitigate other design-basis accidents.

4 MR. KASTENBERG: Could I go back to the
5 question I raised before? I was thumbing through the
6 material you handed out, and it does define fuel damage
7 limit. And one of the things in fuel damage limit is
8 fuel melting.

9 I noticed somewhere like in Criterion 26 it
10 says something like provides fission cooling to prevent
11 exceeding acceptable design limits. But it never says
12 what the limit is. I am asking how much fuel melting
13 are you prepared to accept? Have you specified that?

14 MR. KING: That's not in the criteria. That's
15 something that we can address when we implement the
16 design. I don't have a number for you today.

17 MR. KASTENBERG: So we can't tell whether the
18 case we saw yesterday meets the General Design Criterion
19 or not?

20 MR. KING: We do not have a position on the
21 case that we saw yesterday.

22 MR. CARBON: Let's go on then to the third
23 topic.

24 MR. CLARE: We will move a bit away from the
25 reactor at this point and talk about the design-basis

1 accidents that we have looked at out in the plant. The
2 first subject I want to discuss is the containment
3 design-basis accident.

4 (Slide.)

5 I note first that with respect to this
6 accident we did cover it in detail on May 24, 1982,
7 before the subcommittee. And perhaps if I don't cover
8 something in sufficient detail here, you might find it
9 of interest to turn to the transcript of that meeting.

10 To summarize our thought process that was
11 discussed at that meeting with respect to the
12 containment design-basis accident initiator, we did look
13 at the significant radioactive inventories present in
14 the containment building. That included the reactor
15 fuel, the cold traps, the cover gas, and the reactor
16 coolant.

17 We found that the release of coolant into an
18 air-filled cell would be the bounding source. We would
19 note that we would only have a significant quantity of
20 primary coolant in an air-filled cell during a
21 maintenance condition where we had deinerted that cell
22 in order to perhaps do in-service inspection or
23 preventive maintenance on some of the equipment itself.

24 Now, I put a little bullet in here that says
25 that LWR practice is somehow consistent with this. We

1 would merely note that when one thinks of the
2 design-basis accident for an LWR, what one thinks of is
3 the release of the reactor coolant into the containment
4 building. That release does provide a radioactive
5 inventory and does provide an energy source which can
6 create the driving force to exacerbate any leakage from
7 the containment.

8 Similarly, we have a release of the
9 radioactive primary coolant in the containment. The
10 burning of that coolant does increase the temperature
11 and pressure in containment, and it provides the driving
12 head for increasing the leakage from the containment
13 building. So considering light-water practice as
14 applied to this accident initiator, there is some
15 correspondence there, and that gives us a feeling that
16 maybe we are on the right track.

17 Now, when we go to try to specify in somewhat
18 more detail what the initiator would be in containment,
19 one thing we do in a kind of horse-sense approach is we
20 look for the largest single inventory that's available
21 during any maintenance activity in an air-filled cell.
22 We find that that inventory is what is in what is called
23 the primary sodium storage tank, which is just a big
24 tank down in the bowels of the containment building
25 where we can store the equivalent of something more than

1 one full loop's worth of primary coolant.

2 Now, in discussing how we come up with
3 initiators, I said we try to factor into our thinking
4 the experience that has taken place. With regard to
5 this, we would specifically factor in the experience at
6 sodium reactor facilities and sodium test facilities.
7 The conclusion, having looked at that, is there have
8 been no significant sodium fires. And that if one were
9 to baldly apply that experience, one would say there are
10 no sodium fires that are of significance and one should
11 not bother with that for the containment design.

12 We have been conservative. We have ignored
13 that experience that says it is not a problem and said
14 we indeed will take the leak in the primary sodium
15 storage tank during maintenance for our containment
16 design-basis accident.

17 (Slide.)

18 The equipment failures -- I have used the word
19 "equipment" here loosely -- that we couple with this
20 leak in the primary sodium storage tank is violation of
21 the plant procedures, which will require a very small
22 inventory in that cell prior to deinerting the cell.
23 And by doing so, we would assure that should a leak
24 occur during maintenance there would not be a
25 significant radioactivity inventory, there would not be

1 a significant source of the thermal energy which
2 exacerbates containment leakage.

- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1 It would also have to be a violation of what I
2 have termed health physics guidelines because of the
3 presence of the large sodium volume -- and we are
4 talking something on the order of 35,000 gallons now --
5 is a major gamma source for periods well beyond plant
6 shutdown and any maintenance activities in that cell
7 would give high operator doses.

8 So one would actually have no motivation to
9 deinvert that cell and go into it when you had this large
10 volume in. We assume the good sense of the operators
11 fails there and we go ahead and deinvert that cell, even
12 with a large volume there. The tank that that sodium
13 volume is stored in is an atmospheric tank -- a seismic
14 category 1 tank. Presumably any leak from it would
15 probably be a small leaking kind of leak. It could be
16 extinguished manually. We assume that no manual action
17 is taken to extinguish that fire.

18 Beyond that, when it comes to the containment
19 isolation system that would have to operate to mitigate
20 the event, we assume various combinations of failures in
21 the containment isolation system. I will note that this
22 practice of assuming failures in the containment
23 isolation system is consistent with the practice in
24 lightwater reactors.

25 We have, just as we do in the plant protection

1 system, two sets of logic. Each set of logic is a
2 two-out-of-three logic. The sensors for the two systems
3 are radiation monitors. One set is diverse in terms of
4 the type of radiation that would be sensed. So when we
5 consider the design basis accident we consider the
6 failure of one complete set of the monitors or, as an
7 alternative, failure of one train of the logic that
8 those monitors feed or failure of the containment
9 isolation valves that should be closed by that logic.

10 In addition to that, we would assume failure
11 of one of the three diverse radiation monitors feeding
12 the logic and feeding the valves for the other set of
13 containment isolation valves.

14 Now the analysis conservatisms that we couple
15 with that accident scenario are that the sodium
16 inventory in the primary sodium storage tank is at a
17 maximum. The tank is as full as it can be.

18 (Slide.)

19 MR. CLARE: We assume the spill of the entire
20 35 gallons is instantaneous. There is no mechanism,
21 just all of a sudden that sodium ends up on the floor of
22 the cell. We assume the maximum reaction energy. We
23 look at the chemistry of sodium burning and even though
24 experiments suggest that some sodium Na_2O_2 would be
25 formed, in fact we assume it is all monoxide formation

1 which, because this is an oxygen-limited fire increases
2 the thermal energy that is deposited into the
3 containment. As I mentioned, we consume 100 percent of
4 the oxygen.

5 The cell that this tank is contained in is way
6 down in the bottom of containment. In fact, there are
7 no direct connections between the operating floor of the
8 containment and this particular cell. However, we go
9 ahead and assume that for purposes of the fire analysis
10 the convection of the reaction products up into the
11 containment, the convection of oxygen down into the area
12 where the pool is burning there is a direct interchange
13 which exacerbates the burning in that cell.

14 From a radiological standpoint, we assume an
15 end-of-life sodium contamination. We assume we have
16 been operating since day one with fuel that is failed to
17 the extent that one percent of the fission gases can
18 leak out. We also consider end-of-life plutonium
19 contamination of the sodium -- that's 100 ppb of
20 plutonium.

21 We do assume there will be leakage from
22 containment at the specified leakage rate. As I believe
23 has been suggested by some of the Committee members in
24 earlier meetings, because of the sodium aerosol that
25 would be present, it is quite likely that any leakage

1 paths that did exist would be plugged by that sodium.

2 We take no credit for that.

3 Once any radionuclides get outside containment
4 we assume no fallout getting to either the site boundary
5 or the low population zone where we do our dose
6 calculations, and we couple that with a 95 percentile
7 meteorology, which is again a lightwater practice in
8 doing the accident evaluation.

9 (Slide.)

10 MR. CLARE: That then is representative of the
11 kind of accidents we looked at from the containment
12 standpoint. That is a bounding accident for the
13 containment.

14 The other example of an event I would like to
15 talk about is also one we touched on back at our June 25
16 meeting of the Subcommittee. That is the sodium-water
17 reaction in the steam generator that would result from a
18 steam generator leak.

19 Looking at the information that is available
20 to us in trying to define what the accident initiator
21 is, we find that indeed steam generator leaks have been
22 postulated in lightwater reactor licensing procedures.
23 In fact, steam generator leaks have occurred not only in
24 lightwater plants but also steam generator leaks have
25 occurred in sodium facilities.

1 However, there have been no rapidly-developing
2 sodium-water reactions. These are sodium-water
3 reactions, when I say "rapid" I mean sodium-water
4 reactions that would exert a significant pressure that
5 would somehow challenge the intermediate heat transport
6 system or the intermediate heat exchanger.

7 I should have noted up front that the safety
8 function with respect to the sodium-water reaction would
9 be the relief of that pressure from the evolution of the
10 gases in that reaction, so there would be no challenge
11 to the intermediate heat transport system piping or the
12 intermediate heat exchanger that might then result in
13 the release of some significant amount of
14 radioactivity.

15 The experience base tells us there has been no
16 guillotine tube failures in sodium-water reactions.
17 That would be, in fact, a rapidly developing one. It
18 just has not occurred. We have specifically done
19 experiments trying to investigate the phenomenon of
20 sodium-water reactions, and we found there is very slow
21 propagation. If we had a leak in one tube, it would
22 take a considerable period of time before the effects
23 from the sodium-water reaction of that would cause some
24 adjacent tube to fail in the steam generator.

25 Not being satisfied with the results of the

1 experiments, we did some bounding analysis, set
2 ourselves up an adiabatic problem to see how fast we
3 could heat up an adjacent tube and cause it to weaken to
4 the extent it would fail, and we found that propagation
5 would be no faster than a second -- a very conservative
6 bounding analysis.

7 We looked at foreign sodium reactor plants to
8 see what their licensing assumptions are in terms of
9 their design basis accidents. We found that they
10 assumed anywhere -- I actually could have put zero
11 here. Some foreign reactors, to the extent we can
12 determine, do not assume any steam generator tube
13 failures in their licensing processes. Some consider up
14 to three tube failures.

15 So the initiator we selected, conservatively
16 integrating this information, is that we would have some
17 small leak that could cause damage on adjacent tubes and
18 also pressurize slowly our intermediate heat transport
19 system, followed by the equivalent of one double-ended
20 rupture of a steam generator tube, in spite of the fact
21 that none has occurred. And then we postulated two
22 additional double-ended guillotine failures at
23 one-second intervals following the initial failure.

24 This, in spite of the fact that the experience
25 shows slow propagation. We have just taken the time to

1 get a bounding answer from our adiabatic problem.

2 (Slide.)

3 MR. CARBON: If I remember correctly, this
4 last assumption -- two additional one-second
5 intervals -- it was much more conservative than any of
6 the foreign LMFBR tube failures. Is that correct?

7 MR. CLARE: That is almost correct. I believe
8 in the UK they assume exactly what we do, which is to
9 say three tubes at one-second intervals.

10 MR. CARBON: In any case, there is no foreign
11 experience operation where they take a more conservative
12 assumption.

13 MR. CLARE: To the best of our knowledge, that
14 is correct.

15 (Slide.)

16 MR. CLARE: The additional equipment failures
17 that we combine with that event are listed here. I
18 mentioned that we would identify a precursor that could
19 initially raise the pressure on our system. That
20 precursor would create a leak detection system that
21 would alarm in the control room and tell the operator to
22 do something about it. We assume a combination of that
23 leak detection and the operator failed to do anything.
24 We also failed a set of rupture discs that
25 relieve at intermediate failure. We assume that fails.

1 From the standpoint of the radiological consequences, we
2 assume that there is a preexisting undetectable IHX
3 leak. This would be a leak in an IHX tube that was so
4 small we could not detect it with any of our plant
5 instrumentation.

6 That is important because if as a result of
7 this event we depressurize the intermediate heat
8 transfer support system some sodium might migrate and by
9 reaction with the water could eventually be taken up out
10 of our relief system. So that is a conservative
11 assumption from a radiological consequences standpoint.

12 From the standpoint of the actual pressure
13 developed as a result of the sodium-water reaction, we
14 assume the loss of offsite power that would trip the
15 plant and initiate a transient in our steam generator
16 system just prior to the sodium-water reaction. What
17 that does is to create an adverse condition in the
18 evaporator module of the steam generator system.

19 It essentially overcools the water. The water
20 becomes more dense and if you had a leak at that point
21 in time you would inject more water mass because it
22 would be more dense through a double-ended guillotine
23 rupture of a tube and it would be exacerbated in the
24 steam generator.

25 (Slide.)

1 MR. CLARE: The analysis conservatisms having
2 established the scenario, well, again, I have included
3 this precursor fails to burst the rupture. I do not
4 mean to take double credit for it -- pardon me for
5 that. We do assume the tube failures are
6 instantaneous. It takes no time for these double-ended
7 ruptures to occur.

8 At one second, instantaneously we are dumping
9 water in as calculated by the RELAP-4 code, which is a
10 conservative blowdown case which has been well
11 established by GE in the licensing of their boiling
12 water reactors.

13 We have taken these tube failures at the worst
14 failure locations and the failure locations vary as to
15 the relative severity. In the evaporators, it turns out
16 the worst location, I believe, is up towards the top at
17 the upper tube sheet, and the superheater the worst
18 location is at the bottom at the lower tube sheet.

19 In modeling the rupture discs that would be
20 burst by the high pressure in the intermediate heat
21 transport system, we make a conservative model of the
22 rupture disc in our TRANSRAP code, which is the computer
23 code we used to analyze this event. The model of the
24 rupture disc that is in TRANSRAP that has been modeled
25 to be conservative based on test data, where we

1 specifically went out and tried to characterize the
2 behavior of those discs.

3 The reaction model, which is to say the
4 chemical reaction model, where we have the sodium
5 combining with the water, we assume the reaction is
6 instantaneous, as soon as the water gets into the sodium
7 side. The efficiency of that, and the transfer of
8 hydrogen gas that would be developed in the reaction is
9 all conservative test data.

10 Finally, when we try to evaluate the
11 propagation of the pressure wave down the heat transport
12 piping to examine its damage there, we conservatively
13 neglect the effect of energy absorption in the structure
14 and straining of the pipe itself, also any energy
15 absorption by the motion of the pipe which would
16 actually transfer energy into the snubbers by which the
17 pipes are supported. So we conserve all the energy in
18 the fluid as that pressure wave travels down the pipe
19 and we evaluate the effects on the intermediate heat
20 exchanger.

21 Now I mentioned in my earlier portion of this
22 presentation that the sodium-water reaction is related
23 to the decay heat removal function in the plant. The
24 way that is related is if I get a sodium-water reaction
25 in one loop I want to be sure that the effects of that

1 are accommodated within that loop, so that any gas
2 releases, sodium releases associated with that will not
3 propagate temperature or pressure effects over into
4 another loop. They would disable that other loop for
5 its decay heat removal function.

6 By performing this analysis and assuring that
7 our pressure relief capability for this rupture disc, we
8 believe we have accommodated this event and protected
9 our decay heat removal function from the effects of the
10 sodium-water reaction.

11 This, then, completes my discussion of a
12 couple of examples of how we have specified our design
13 basis accidents out at the plant. I hope it gives you a
14 feeling for how we did it. We would be here all
15 afternoon if we tried to do that.

16 MR. ZUDANS: I would like to return to your
17 design basis accident for containment. You do not have
18 to put up the slide. We discussed it before in the
19 previous meeting, I remember, and I am still having some
20 doubt in my mind whether or not this is the limiting
21 design basis event.

22 The rationale for not assuming any major
23 primary coolant pipe breaks or maybe in the intermediate
24 context is not too convincing as yet.

25 MR. CLARE: Perhaps we have not been clear.

1 Let me back up and try to do that.

2 We do postulate significant leakages and spray
3 fires in the inerted cells, even to a size well beyond
4 what we have actually specified in the design basis.
5 Our cells would be capable of mitigating those within
6 the cell. Indeed, one reaches very high pressures,
7 relatively speaking, high pressures and temperatures in
8 the cell in which a leak would occur.

9 We do not mean to say anything else. However,
10 the cell itself is designed to contain those effects.
11 Hence, there would be no challenge outside that cell to
12 the containment boundary itself.

13 Now in evaluating our containment we do go
14 ahead and assume that, for example, the cell leaks. We
15 leak radioactivity out of that primary heat transport
16 system cell and we evaluate the potential for those
17 radionuclides offsite and indeed the doses are low.

18 MR. ZUDANS: I do not disagree with that
19 statement. That is okay.

20 Suppose you had a break someplace where you
21 lose the primary coolant inventory? It is not the cell
22 I am concerned about. I am concerned about your heat
23 removal capability at that point. You could have a
24 break in one of the primary coolant pipes, and since you
25 cannot stop the leak you cannot refill it fast enough

1 because your refilling capability is something like --
2 what was it -- 5060 gallons on the DHRS system.

3 What are you going to do in that case? What
4 am I missing there?

5 MR. CLARE: We explored that briefly yesterday
6 in the working group meeting. We provided the elevated
7 piping catch guard vessel approach to contain that
8 leaked inventory. That does depend on the pumps
9 tripping and we have provided a pump trip function as
10 part of our plant protection system, essentially the
11 same set of logic and instrumentation that provides for
12 the control rods to insert into the core.

13 It trips our primary coolant pumps to assure
14 that that will be done. We could detect any significant
15 leak before the volume of sodium in the system had
16 dropped far enough that it would be -- that it would
17 endanger the long-term decay heat removal capability.

18 MR. ZUDANS: I guess you are probably right,
19 that you have looked at many of the scenarios where you
20 are nicely protected, but if I were to just walk along
21 the primary coolant pipe I would find some locations
22 where it is not enclosed in a protected system that
23 would maintain that volume.

24 Supposing I just postulate a break at that
25 location?

1 MR. CLARE: If you postulate a leak at any
2 point in our primary piping, what I just said about
3 maintaining the inventory remains true.

4 As I said yesterday, that elevation is such
5 that when combined with the tripping of the main motors
6 of the pump, which limits very much the pressure
7 available to push sodium up and over the top of the
8 guard vessel or to that elevated portion of the piping,
9 you will find that the inventory is protected.

10 MR. ZUDANS: Supposing you had a break. Let's
11 assume the pipes run out in less than 100 seconds. They
12 do not pump too much sodium out. I do not know how much
13 they would pump out if I postulated a break, say, on the
14 cold leg in an unprotected area. What would be left in
15 the system after it goes back and pumps it up?

16 MR. CLARE: For any size leak we use in our
17 design basis, and you are using the term "break" and I
18 do not want to misrepresent it, we do not consider a
19 double-ended rupture in our design basis.

20 MR. ZUDANS: I know you do not.

21 MR. CLARE: But for any leak at any location
22 we feel we will have enough. We feel we can perhaps
23 come back with all the numbers of volumes and elevations
24 and pumps heads and flow rates if you would like to go
25 over that in detail.

1 MR. DICKSON: A simple answer that could be
2 given to that is that for a leak at any point, the guard
3 vessels have all been sized so that the minimum safe
4 level is a little over two feet above the outlet nozzle
5 of the reactor vessel. That is where it will settle out
6 from the leak at any point.

7 MR. ZUDANS: That is the leak if you assume a
8 certain-sized break.

9 MR. CLARE: That is essentially independent of
10 the leak size.

11 MR. DICKSON: It is independent of the leak
12 size, so long as the pumps trip.

13 MR. ZUDANS: If it is independent of the leak
14 break size, look at the scenario where you make the cold
15 leg -- double-ended guillotine break. What will happen
16 to the inventory?

17 MR. CLARE: From an inventory standpoint, you
18 will be just fine.

19 MR. ZUDANS: What happens to your capability
20 to remove the decay heat after that because your DHR
21 will not function because of the overflow.

22 MR. CLARE: That is correct, but you would
23 still have the heat removal capability through all three
24 of your other loops.

25 MR. DICKSON: Two, George.

1 MR. CLARE: At the inlet nozzle I would still
2 have a capability to remove heat through that loop. I
3 could postulate places in the loop where that would not
4 be available.

5 MR. ZUDANS: Are there not places where there
6 are points higher than that nozzle?

7 MR. CLARE: It is higher than the inlet
8 nozzle. We specifically arranged that to be the case.

9 MR. ZUDANS: Your pumps are in the hot leg.
10 The pumps' center line is eight feet below your free
11 level in the reactor vessel.

12 MR. CLARE: The minimum safe level is above
13 the impeller level in the pump. We have demonstrated in
14 the water test and will demonstrate in the sodium test
15 that the pony motor, the pump operating on the pony
16 motor will continue to circulate sodium, given a leak
17 that fills up a guard vessel, et cetera.

18 MR. ZUDANS: Those two loops, you are telling
19 me now, they are still functional in a double-ended
20 guillotine break?

21 MR. CLARE: I do not want to mislead you that
22 the guillotine in the cold leg is not something that we
23 can perfectly accommodate.

24 MR. ZUDANS: I am not asking you to
25 accommodate it. I am asking to hear whether you make

1 that statement, because in fact I thought you made that
2 statement that you still have two loops to cool.

3 MR. CLARE: That is correct.

4 MR. ZUDANS: Will you be able to pump in those
5 two loops?

6 MR. CLARE: We will.

7 MR. ZUDANS: If so, you are not in bad shape.

8 MR. CLARE: We definitely will have capability
9 to circulate sodium using the pumps in that kind of a
10 scenario.

11 MR. ZUDANS: How are you going to stop the
12 sodium from flowing through a break in that loop? There
13 is no reason for the sodium level not to be the same in
14 a broken loop as it is in an unbroken loop.

15 MR. DICKSON: Under pony motor flow, the loops
16 are at negative absolute pressure. The pony motors can
17 develop five foot of head, which is only enough to raise
18 the sodium level to about the lip of the guard vessel.
19 That is what defines the minimum safe level with
20 relation to the pony motor head.

21 MR. ZUDANS: And the negative pressure exists
22 in the highest point in the loop?

23 MR. DICKSON: That is correct.

24 MR. ZUDANS: Therefore, the level in the
25 reactor --

1 MR. DICKSON: This gets back to the level of
2 the reactor vessel plus the foot of head. If you have
3 not turned up the pony motor in that loop, you would go
4 to the minimum safe level plus about four to five feet,
5 which takes you up to about the lip of the guard
6 vessel. If you leaked into the guard vessel, then you
7 fill the guard vessel.

8 If your leak is outside in the elevated piping
9 outside the guard vessel, then the leak stops.

10 MR. ZUDANS: What you are also saying is the
11 negative pressure at the hot leg outlet at the reactor
12 vessel is --

13 MR. DICKSON: Not at the outlet of the reactor
14 vessel. That would have about two feet of sodium head.

15 MR. ZUDANS: Let us say the two feet of sodium
16 head is enough to provide the sodium inlet losses in
17 that pipe and still leaves a reserve so that negative
18 pressure can be developed later at a higher point in the
19 pump.

20 MR. DICKSON: Correct.

21 MR. ZUDANS: This what I think we really need
22 to see, because that would set my mind to ease if you
23 could show what the calculated pressures and flow rates
24 are at different points in the system.

25 MR. DICKSON: We will do that. What we did,

1 we set the elevations of the pump, the pump impeller,
2 the minimum safe level allowed in the pump all with
3 regard to that very concept that a leak anywhere should
4 not disable the other two loops because you will not
5 lose the inventory.

6 We also sized the guard vessels on the same
7 basis. In some cases we would like them larger to make
8 inspection easier, but they must be sized to accommodate
9 just the amount of sodium loss.

10 MR. CLARE: There is a complete discussion of
11 this in section 5.3 of our PSAR. Perhaps we can work
12 with Paul and get you a copy.

13 MR. ZUDANS: I have the whole thing. I do not
14 think that has enough detail for me. That would
15 eliminate one issue completely.

16 Now whether or not you can cope with a sodium
17 leak through that double-ended guillotine break, that is
18 another aspect -- whether or not the containment can
19 cope with it. That is another aspect. But the fact
20 that you can assure the residual heat removal under
21 those conditions is very significant. It seems like you
22 had that in mind all the time when you designed.

23 MR. CLARE: The consideration is essentially
24 the same, regardless of the leak size.

25 MR. ZUDANS: For example, the following

1 situation. At some point in a transient the pump
2 suction will be big enough to depress the reactor vessel
3 and suck in the argon gas.

4 MR. CLARE: We have sized everything so that
5 will not occur.

6 MR. ZUDANS: You will have to show me.

7 MR. CLARE: We will bring the numbers in.

8 MR. ZUDANS: I do not think I can find that.

9 MR. CLARE: We will provide a section number.

10 MR. CARBON: Please do take that as a specific
11 request.

12 How much sodium would leak out in that case?
13 How much would you pump out -- appreciably more than the
14 35,000 gallons?

15 MR. CLARE: Oh, no. Significantly less in
16 terms of anything that would get out of --

17 MR. CARBON: It would still be in an inerted
18 cell.

19 MR. CLARE: Yes, it would.

20 MR. CARBON: So you go through the same
21 assumptions here. It would seem that you would not
22 challenge the containment as much there as you would
23 under the case you gave us.

24 MR. CLARE: That is right.

25 MR. CARBON: And you said you did not want to

1 mislead us and imply that you could not handle it. What
2 is it that you could not handle?

3 MR. CLARE: A double-ended rupture of the cold
4 leg pipe leads to -- would lead to an immediate
5 reduction of flow through the core. You have
6 essentially provided an alternative for sodium to get
7 out of the inlet plenum of the reactor. One could
8 have -- one would have a reduction in the heat removal
9 capability running through the core.

10 Then it is a question of the race between the
11 reactor shutdown system to bring the power of the
12 reactor down quickly enough so that the flow would still
13 provide adequate heat removal for whatever the heat flux
14 being delivered into the sodium would be, and because of
15 the piping integrity considerations, which we believe
16 suggest that it is appropriate to move that double-ended
17 rupture of an inlet pipe well beyond the design basis.
18 We have not specifically provided shutdown system
19 capability to win that race

20 MR. ZUDANS: Well, I think that is a good
21 argument. If you rely on piping integrity analysis as a
22 reason for not looking into that thing.

23 MR. CLARE: That is right.

24 MR. ZUDANS: Then you have to remember that
25 there does exist something called Murphy's Law.

1 MR. CLARE: We have tried to take that into
2 consideration.

3 MR. ZUDANS: There is no reason for anybody to
4 believe that these pipes are any better than the LWR
5 pipes. Their walls are thinner. They are long and
6 complicated. They have lots of elbows because of the
7 tremendous thermal expansion problems they have there.
8 They are essentially like beer cans.

9 MR. CLARE: We probably are not the best ones
10 to discuss that. We do have a meeting set up for
11 November 17, 18.

12 MR. ZUDANS: Unfortunately, I will not be
13 here.

14 MR. CLARE: That is right. You are going to
15 go where the sun shines.

16 MR. CARBON: If you also could define specific
17 questions.

18 MR. ZUDANS: I have already defined that. I
19 think it is clear enough that they show what happens
20 with the flow rate and the other flow loops can
21 function, and they would also know how much the
22 temporary loss of flow is to the core and how it shuts
23 down. We find that the situation is not as bad as we
24 think.

25 MR. DICKSON: That is more than I thought you

1 asked for. I thought you asked for material we already
2 had, which is the elevations and what happens after a
3 leak and why we still are assured of having sufficient
4 inventory.

5 Now you are saying analyze a 30-second
6 transient and flows.

7 MR. ZUDANS: No. I understand you to imply
8 that you look at the guillotine -- the double-ended
9 guillotine break in the cold leg and you had the
10 associated flow rates and elevations to the system. If
11 you did not have them, you do not have the answer in the
12 PSAR.

13 MR. DICKSON: We do not. We did not look at
14 the cold leg pipe break with the transients involved
15 while the pumps are down.

16 MR. ZUDANS: I am not so much interested in
17 your heat removal aspect of transients. I am only
18 interested in whether or not you have capability to pump
19 sodium through the remaining loops.

20 MR. CLARE: From a volume --

21 MR. ZUDANS: That is right.

22 MR. CLARE: I think our analysis evaluates
23 that. It is essentially independent of flow rate, but
24 we will provide what we have.

25 MR. ZUDANS: You have only analyzed a limited

1 break size through the pipe.

2 MR. CLARE: From the standpoint of the
3 maintenance of the inventory, I think we can conclude by
4 looking at a few of the volume numbers and perhaps the
5 flow rate is not a terribly important parameter in that
6 evaluation. But let us get together what we have. We
7 understand your concern and will try to address it.

8 MR. CARBON: One more question there. You
9 said that you had not -- that it would be a race between
10 shutdown cooling and so on. What sort of temperatures
11 would you anticipate in a case like that?

12 MR. CLARE: I really do not have those
13 numbers, and to the best of my knowledge we have not
14 actually performed a calculation on that event for the
15 present core design. There were some numbers on the
16 docket many years ago for our earlier core design -- the
17 so-called homogeneous core design -- and other than the
18 fact that I believe we believe in some assemblies we
19 reach the boiling temperature of sodium, I cannot tell
20 you any more.

21 MR. CARBON: Any other thoughts before we
22 break for lunch?

23 (No response.)

24 MR. CARBON: Well, let's go break for lunch
25 and meet again about 2:20.

1 (Whereupon, at 1:23 o'clock p.m., the meeting
2 recessed, to reconvene at 2:20 o'clock p.m., the same
3 day.)

- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1 AFTERNOON SESSION

2 (2:20 p.m.)

3 MR. CARBON: Let's reconvene and proceed with
4 the NRC presentation.

5 Mr. Becker.

6 (Slide.)

7 MR. BECKER: I am Richard Becker, Dick Becker,
8 and I'm with the staff, the CRBR Program Office; and I
9 am the reviewer, in conjunction with some other
10 reviewers. I have the primary responsibility for the
11 accident analysis section.

12 I intend to cover very briefly today the
13 status of the review and also to touch on a little bit
14 of some of the rationale in our reviewing of the
15 accident and the accidents delineated for the design
16 basis analysis for Clinch River.

17 (Slide.)

18 We have helping us as consultants Brookhaven
19 National Laboratory, Los Alamos, and Idaho National
20 Engineering Laboratory working with us to help us
21 evaluate the accidents for Clinch River.

22 Basically, we have had as far as Chapter 15
23 goes, the accident analysis evaluation, we've had two
24 specific meetings with the applicant on that, on Chapter
25 15. I indicated several other chapters because there

1 are a number of chapters that hinge on Chapter 15. The
2 accident analyses are in Chapter 15, but a great deal of
3 detail associated with those accident analyses are in
4 other chapters. For example, Chapter 4 handles the
5 reactor core and the core internals, fuel and this type
6 of thing, the neutronics, what have you. Chapter 5 is
7 associated with the heat transport systems. And those
8 PSAR chapters all go together basically and are a strong
9 basis of support for Chapter 15.

10 I didn't indicate all of the meetings that
11 have been held as far as those chapters are concerned
12 because I think there has been some indication in the
13 discussions that have passed that there have been a
14 number of meetings associated with those.

15 There are some other chapters. There are
16 things associated with the piping integrity, a number of
17 meetings that have been held with the applicant. And I
18 just wanted to indicate basically that -- the status of
19 that interaction with the applicant.

20 (Slide.)

21 I didn't intend, since you have already had a
22 thoroughly extensive discussion of the applicant's
23 rationale as far as their selection of the design basis
24 accidents, I didn't intend to go into that since we're
25 in the process of review, and we are evaluating that,

1 and that will be included, of course, in our safety
2 evaluation report.

3 Is this microphone picking up well?

4 What I intended to do was give some idea
5 basically of how we are conducting the review, of what
6 kinds of things we're looking at, and to try to perhaps
7 bring up some of the questions that would result as to
8 how the review is being conducted and as to how we try
9 to evaluate whether the base -- the design base that is
10 presented to us is complete, whether it fits the
11 situation, this type of thing.

12 MR. CARBON: Excuse me. Are you trying to
13 review what design basis accidents are or the accidents
14 themselves?

15 MR. BECKER: I guess the answer to that is
16 both.

17 MR. CARBON: Then I guess you are saying you
18 have not yet decided where you will draw the line on
19 what are and what are not design basis accidents?

20 MR. BECKER: We have not, I would say, made a
21 final determination as to what that -- where that line,
22 if you can picture it, is, that's right.

23 MR. ZUDANS: That is not the question. If I
24 understood, the question is whether you have decided
25 which accidents are DBA accidents.

1 MR. BECKER: Oh, I think we have decided which
2 accidents of those that we now know are DBAs, yes. The
3 question I thought you meant was are there DBAs that
4 have not been -- have not been considered.

5 MR. CARBON: No. I was trying to ask this
6 latter question, the question have you decided what are
7 and what are not DBAs. And I guess you said you have.

8 MR. BECKER: I guess the answer to that was
9 yes, we have.

10 MR. CARBON: Do you agree fully with where the
11 project divides what they consider DBAs? Do you agree
12 fully? And what they don't do you agree fully?

13 MR. BECKER: I think at the state of our
14 review right now I would say we have found no reason to
15 disagree with what they have proposed as DBAs.

16 MR. CARBON: Do you have any reason to agree?

17 MR. BECKER: Well, we're considering -- we are
18 looking at the spectrum they presented to us, and we are
19 evaluating whether we agree that there are accidents
20 outside that spectrum. Of those accidents that have
21 been presented to us we have no disagreement with.

22 MR. CARBON: It seems to me, though, that
23 you're saying on the one hand that you have decided what
24 are DBAs and what are not, but then in the next sentence
25 it seems to me you are saying you have not yet decided

1 what are and what are not.

2 MR. BECKER: We have not yet made the decision
3 that the spectrum that we are evaluating is complete.

4 MR. ZUDANS: Could you also phrase it you have
5 not decided that the set of DBAs you have now
6 identified, this is complete?

7 MR. BECKER: I think that's correct.

8 MR. ZUDANS: There could be DBAs that you have
9 not yet analyzed that the applicant has proposed?

10 MR. BECKER: That's right.

11 MR. CARBON: But all of them that you are
12 aware of, that you've thought of, you're in agreement
13 with the project of which they say are and are not DBAs?

14 MR. BECKER: Yes.

15 MR. RAY: At which stage in your review will
16 you consider accidents beyond the DBA? Is that to come?

17 MR. BECKER: Well, I think that we considered
18 accidents beyond the DBA from the outset. I think the
19 evidence shows that we are looking at those things that
20 clearly can be identified as accidents beyond the DBA
21 and are including provisions to mitigate those accidents
22 in the design. Those you can clearly specify are beyond
23 the design basis. The core disassembly accidents, that
24 type of thing, are clearly identifiable as beyond DBA.

25 I think the question this morning about

1 station blackout being an accident or a situation which
2 is really outside the design basis accident is one of
3 those that is clearly identified on that basis. And I
4 think Bill Morris gave a very cogent answer as to why
5 that is -- because the multiplicity of failures that
6 have to occur conflicts basically with the definition of
7 almost all of the other spectrum of design basis
8 accidents.

9 MR. RAY: Is it possible that your review will
10 generate additional actions for which you would want
11 mitigation beyond the DBA?

12 MR. BECKER: I think you can always say that
13 possibility exists, yes. Well, I just sketched here
14 basically in looking at the accidents that have been
15 presented to us, stepping back and taking some idea as
16 to how you might consider the design basis accident, on
17 what basis you would identify those, you can categorize
18 them in several ways.

19 (Slide.)

20 You can categorize them by accident type, or
21 you can make a categorization by dose limit; and those
22 are not always necessarily the same, although they may
23 be falling into both categories.

24 We also look at the categorization of the
25 frequency of the accidents that are proposed into what

1 category they fall as far as whether they are expected
2 occurrences or they are likely faults or highly unlikely
3 faults.

4 We also evaluate the adequacy of the
5 engineered safety features proposed to mitigate or to
6 accommodate the design basis accidents: how well they
7 function, do they function under the right situations,
8 do they also adhere to all of the methodologies
9 associated the way a design basis accident is analyzed,
10 and how the engineered safety features respond to those
11 things.

12 Then finally, as I said just previously, we
13 evaluate the completeness of the spectrum.

14 MR. KASTENBERG: Do I read anything into the
15 word "limit" after dose? That's the only place you've
16 used it. Does it mean something special?

17 MR. BECKER: I don't think I would infer
18 anything special except the federal regulations
19 basically are guidelines, and I've interpreted that
20 basically as the limit essentially.

21 MR. KASTENBERG: But you wouldn't look at a
22 frequency limit at this point?

23 MR. BECKER: I would not look at a frequency
24 limit in that sense, no.

25 (Slide.)

1 We touched on this, and I want to give a
2 caveat to this. This is a conceptual slide. Do not
3 take it too literally.

4 Basically, I wanted to get some slide which
5 would give you some feel for the words that what we're
6 doing when we are looking at this, basically we are
7 scanning, if you will have it, the design basis
8 envelope. We can clearly identify those things that are
9 things which we know we want to have outside the design
10 basis, envelopes such as the CDAs, and the kinds of
11 things where if we're looking for accidents it should be
12 inside the design basis but might be missed.

13 We are really looking at what I call a buffer
14 zone. I called it that simply because I had no term
15 that I felt would be more descriptive for that
16 particular area. That would be the area I think for
17 accidents that have not been identified for the design
18 basis would lie.

19 It's conceivable we may be looking at an area
20 where we may not identify any accidents. But in essence
21 that's what we're doing when we look for completeness.
22 We're looking in that particular area.

23 I wanted to simply have a slide that would
24 give me something to focus the attention on that
25 particular aspect.

1 (Slide.)

2 There are several ways that you can go about
3 trying to assure yourself that the set of design basis
4 accidents are complete. There is no prescription as far
5 as I know or anyone else has been able to guide me, so
6 what you will have to do when you are trying to decide
7 whether or not you have things complete is to look at
8 things in at least two or as many ways as you possibly
9 can.

10 So when you are looking at the completeness of
11 the design basis envelope, there are several ways that
12 will give you some assistance at least that we believe
13 will be able to derive or arrive at any accidents which
14 have not been completely delineated by the set of
15 accidents that we have at hand or anything else that we
16 are currently considering.

17

18

19

20

21

22

23

24

25

1 One of the ways is to look at the mechanistic
2 sequence, to say this component fails, what happens in
3 that sequence, and that, I think, perhaps is maybe the
4 historic way to look at things. A way to verify that
5 sequence, the group exposed that way is complete, is to
6 look at it in a generic sense. I think there was some
7 discussion of that this morning, generically saying,
8 what categories of things do I have like overpower
9 events, what categories of things do I have that are
10 undercooling events, what category of things do I have
11 about radiation, radioactivity, fuel handling accidents,
12 these types of things, and cross-compare that particular
13 method.

14 There are some failure modes in effects
15 analysis which is another methodology that is possible
16 to show you some accident, coming up with some accident
17 perhaps that has not been thought of, has not been
18 evaluated, something of that nature. You can also look
19 at what other people have thought about, look at the
20 foreign experience, for example, evaluate what the
21 design basis spectrum for other reactors is.

22 I think that in some cases this is useful and
23 good. In other cases, it is very difficult to get a
24 good handle on it. I think one thing that strikes me is
25 the Russian experience, for example. It is difficult to

1 evaluate what the Russians think about their plants.

2 Finally, probabilistic risk assessment is
3 another method which can augment your thinking in other
4 areas. Perhaps reliability analysis is more correct to
5 say rather than PRA, but those are the kinds of things
6 that are available to you to test essentially the
7 completeness of the group of accidents that you have.

8 MR. KASTENBERG: Just a quick question. Some
9 time in the spring, the subcommittee had a presentation
10 on the PRA. The question came up as to whether the NRC
11 staff would be doing its own parallel PRA. Was that
12 ever resolved?

13 MR. BECKER: I would have to ask Bill Morris.

14 MR. MORRIS: Bill Morris, NRC staff. The
15 staff has engaged consultants to review the PRA being
16 performed by the applicant, and we believe that that is
17 the appropriate response.

18 MR. MARK: Mr. Becker, could you in two or
19 possibly three words explain to me the difference
20 between a FMEA and a PRA? F-M-E-A.

21 MR. RAY: Maybe it's a phoneta.

22 MR. BECKER: Actually, when I said a PRA is
23 the probabilistic risk assessment, which takes you
24 through the consequences, I actually, I think, should
25 have used reliability analysis, in which you are not

1 really concerned perhaps about the consequences as you
2 are about the probability associated with certain
3 sequences leading you to certain things you don't want.
4 The failure modes and effects analysis, to my
5 understanding, is looking at the detailed hardware and
6 evaluating where they might possibly fail and what
7 things they may lead to.

8 MR. MARK: That is great. In a PRA, do you
9 not also have to assess the probability and the kinds of
10 things that can happen and what the effects are?

11 MR. BECKER: I think the difference -- the
12 answer, I believe, is yes. I think the difference is in
13 level at which you look at these.

14 MR. MARK: Which is the more intense?

15 MR. BECKER: I think the failure modes and
16 effects analysis is the more -- the intensity, I am not
17 sure it differs between the two. I think the level of
18 detail differs, though, in the two. In one, you look at
19 more macroscopic, whereas the other, you look more in
20 detail at the finite pieces of given equipment.

21 MR. LIPINSKI: In your mechanistic sequence,
22 do you look at operator errors, or do you always assume
23 that if an operator can do something, he does it right?

24 MR. BECKER: Generally, it depends on whether
25 the action is required on a short-term basis or a

1 relatively long basis. The operator action in most of
2 the events that we look at is not required. It is an
3 automatic sequencing type of thing. For example, the
4 overpower, there is no operator action associated with
5 it. It's a plant protection system type of thing. The
6 undercooling accidents, most of those -- in fact, in
7 general, I think one of the accidents that was discussed
8 just before lunch, the overpower, there is a slow
9 overpower accident that basically is a malfunction of
10 the plant controller. We take no advantage of the fact
11 that the operator is there and could correct that.

12 MR. LIPINSKI: I was thinking more like
13 something at TMI 2. You have high pressure injection,
14 but an operator turns off high pressure injection when
15 he is not supposed to, and aggravating the condition. I
16 haven't looked at your sequence to give any detailed
17 thought to it, but the question is, if something is in
18 progress, can an operator intervene and make it worse?

19 MR. BECKER: I think -- well, I guess the
20 answer to that has to be, if the accident is a short
21 sequence accident, he has very little chance of
22 intervening. If it is a long sequence accident, yes,
23 the operator can intervene and could conceivably make
24 that accident worse. I think we look at it with the
25 operator having no involvement one way or the other

1 unless with a few -- there is one sequence of operation
2 that is not in the design basis accident, but there is
3 one sequence of operations in which the operator has to
4 act, but it is not in the design basis accident
5 envelope.

6 MR. LIPINSKI: That was my next question. If
7 there are some within the DBA envelope, and the operator
8 intervenes in the wrong direction, it is probably a low
9 probability event, but it could throw you into something
10 beyond the design basis accident.

11 MR. BECKER: Well, in short sequence
12 accidents, he does neither, as I said. In the longer
13 sequence accidents, it is assumed that the operator
14 basically does the correct thing.

15 MR. LIPINSKI: I thought that was one of the
16 lessons we learned from TMI 2.

17 MR. MORRIS: Excuse me. I think that you are
18 right, that subsequent to TMI, the staff was engaged in
19 a great deal more effort to assure that operators were
20 properly trained, and human factors were considered so
21 that this kind of incident will not occur, but to us,
22 that would be a failure of the operator training and the
23 operator's procedures for him to intervene in an
24 accident in an incorrect way. We believe it is unlikely
25 that that will occur now that these measures that have

1 been taken subsequent to TMI have been developed,
2 because those measures will be implemented in the CRBR.

3 So, we do not believe that this kind of
4 operator complication is necessarily a part of
5 establishing a design basis spectrum.

6 MR. LIPINSKI: I will give you a case in hand,
7 the design of the simulator. The operator was going
8 through a sequence using the written procedures. He
9 turned two pages at one time, so he went from the bottom
10 of one page to the top of two pages later, and continued
11 to execute the sequence, so that it was not a deliberate
12 error on his part in turning two pages at the same
13 time. He put them in the wrong part of the sequence.

14 MR. MORRIS: This was a training exercise? I
15 think that is the purpose of training exercises, to
16 ferret out these kinds of problems, to teach the
17 operator not to do that.

18 MR. LIPINSKI: Put that doesn't ensure that
19 that won't happen in the control room.

20 MR. MORRIS: No, we can't assure you that
21 there will be no operator errors. You would have to
22 have the human factors people in here to discuss it in
23 more depth, if you wish, but here we are talking about
24 something that is generic to LMFBR's and LWR's, and we
25 see no more inherent opportunity for the operator to

1 cause this kind of complication for this plant than for
2 an LWR, and we believe the operator training measures
3 that have been implemented will be sufficient to make
4 those kinds of complications very unlikely. We don't
5 think that they have to be introduced into the design
6 basis spectrum.

7 MR. LIPINSKI: They are unlikely, but if the
8 consequences are intolerable, it would be nice to know
9 about them in advance. It is generic to both reactors.

10 MR. MORRIS: I think as we approach the time
11 for the granting of the operating license for the plant,
12 that by that time there will be a contingent of trained
13 operators who have gone through all the permutations of
14 events that could occur and will be prepared to handle
15 these events. I think that is a thing that will occur
16 late in the review process.

17 MR. MARK: I agree with you that the extra
18 training, the extra care about the writing of procedures
19 and so forth are all fine, and they will reduce the
20 probability that an operator will out of ignorance do
21 the wrong thing, but all you can ever claim for this is
22 that you will reduce the probability, because as Walt
23 points out, the probability of turning two pages is a
24 little hard to assess and can never be said to have been
25 removed, and if somebody was eating caramels one day and

1 the pages stuck together, the likelihood that he might
2 turn two at once is increased.

3 MR. MORRIS: Again, we do recognize the
4 possibility that operator errors could complicate
5 accidents and lead to some severe consequences. This in
6 part is one of the reasons attention is being paid to
7 severe accidents at Clinch River. That is, we don't
8 believe these kinds of complications should be included
9 in the design basis, but we take further steps to assure
10 that if you should get into a severe accident situation
11 because of it, that the plant will accommodate these
12 kinds of things.

13 MR. MARK: You can and you must admit all the
14 time that you have not done enough, cannot possibly do
15 enough to exclude the possibilities of something
16 different happening. That is all.

17 MR. MORRIS: Yes, I agree with that.

18 MR. RAY: Mr. Becker, is the applicant
19 required to make analyses of failure modes and effects,
20 or does the staff do this?

21 MR. BECKER: That, I believe -- I would like
22 to ask Mr. Morris. That is a staff function, does the
23 failure modes and effects analysis?

24 MR. MORRIS: I think there are requirements on
25 the applicant to do failure modes and effects analysis.

1 Some of these have already been done, but others will be
2 spelled out in the SER. Particularly in Chapter 7,
3 there are some measures now included in the standard
4 review plan that require that it be demonstrated that
5 the failures of sensor lines or the failures of
6 electrical components, for instance, will not cause
7 events to occur that would be beyond those that are
8 examined in the design basis analysis in Chapter 15.
9 Those are requirements on the applicant, that he provide
10 those kinds of failure modes and effects analysis.

11 There is another failure modes and effects
12 analysis that the applicant has done or will be doing
13 that is part of the inherent program. I think I would
14 say that it is heavily weighted on the side of the
15 applicants to perform these analyses.

16 MR. RAY: In those cases, are those his
17 choices, and are they tuned to the mechanistic sequence,
18 for instance?

19 MR. MORRIS: I think we would examine them,
20 and if we found -- we felt that there should be
21 additional analysis done, we would expect and ask him to
22 do those.

23 MR. ZUDANS: I would like to add a little bit
24 to this. I understand the gist of the conversation, of
25 course, but it somehow strikes me as a little bit

1 difficult to have the situation where the design basis
2 accident otherwise would become beyond design basis just
3 because of some human error. I am just wondering
4 whether such things should not really be covered in the
5 margin of design basis events. Each design basis event
6 really is there to have the limits on a given component
7 on the system. That is what it is for. Otherwise, you
8 would not be in there.

9 If in that sequence there is some human action
10 required or number of actions, and if there is an
11 incorrect action, however improbable it might be, it
12 might make this event way beyond design basis. So I
13 would like to see those margins covering such
14 expressions.

15 MR. MORRIS: I am not sure I can completely
16 reply to this question. I know that the subject has
17 been addressed at length by the staff in a number of
18 different forums. I recall that after TMI and the TMI
19 hearings, there was a question raised, a contention, as
20 a matter of fact, raised regarding the necessity for
21 having interlocks on the switches to prevent an operator
22 from interfering with the safety coolant injection.

23 The staff, as I understand it, the staff has
24 consistently taken the position that it is preferred
25 that you do not design measures in to prevent the

1 operator from interfering in an accident, that what you
2 would lose then would be the capabilities for handling
3 many events that we have not yet been able to
4 anticipate, and that is something that would simply be
5 imprudent.

6 This whole issue is something I would have to
7 refer to some people from the Human Factors Division,
8 Instrumentation and Controls Branch, but that is my
9 interpretation of the policy that has been implemented
10 heretofore, and we acknowledge that if the operator gets
11 too excited, he can defeat safety functions, and once
12 having acknowledged that, it is hard to know just how
13 you would go about preventing him, once he has made that
14 decision. I don't know how you can design to prevent
15 that.

16 MR. ZUDANS: In these analyses that are being
17 done in the PRA and other ones, there are sequences set
18 up, and operator actions that are clearly identified,
19 and the consequences are also known, if they do it
20 wrong. That might mean that in some cases you tighten
21 up the specification or something else. So I am also
22 pretty sure that the PRA includes operator errors.

23 MR. CLARE: George Clare, Westinghouse.
24 Yes, indeed, our PRA will be looking at
25 operator action trees.

1 MR. ZUDANS: Not intentionally criminal
2 errors, but, you know --

3 MR. CLARE: Errors of omission and errors of
4 commission.

5 I would also like to echo a combination of the
6 comments that Dick Becker and Bill Morris made and just
7 point out that we have indeed attempted to provide
8 automatic initiation and control of essentially all, not
9 quite, but nearly all of our safety features on the
10 plant. By doing that, we achieve a couple of things.
11 We don't depend on the operator then to go do something,
12 and by putting him in a position where his hands are off
13 the control, standing back from the control panel and
14 standing there watching things happen, we also reduce
15 the chance that I think he would do something
16 inadvertently that he wasn't supposed to do, as well as
17 decreasing the chance he would do something -- he would
18 fail to do something.

19 I would emphasize what Bill said in his last
20 set of comments, that although in the evaluation of the
21 design basis accidents themselves there hasn't been a
22 tremendous emphasis on operator actions, in the review
23 of our instrumentation and control systems, the staff
24 has put us very hard to the task of demonstrating that
25 the automatic instrumentation and controls will be

1 resilient to operator errors.

2 Just as an example of that kind of thing,
3 let's take the auxiliary feedwater system. We get into
4 some event where auxiliary feedwater is required. The
5 operator goes over to the controls and turns off all the
6 auxiliary feedwater pumps, but just as soon as the water
7 level comes down to a point where we should be pumping
8 in more feedwater, those pumps will automatically start
9 up again. As long as the operator shuts them off, the
10 control system will turn them back on again, and he
11 cannot turn them off if the system is demanding
12 feedwater, no matter how hard he tries.

13 MR. ZUDANS: I am sure that is a good feature,
14 and you have looked at what stops the operator from
15 opening or closing the wrong valve.

16 MR. CLARE: Well, when you start working with
17 the operators out in the plant, you do find yourself in
18 a position, as Dr. Mark suggests, that there is only a
19 certain limit that you can provide for that kind of
20 situation. If the operator sets his mind to it, you
21 cannot completely prevent him from taking some improper
22 action. Perhaps the security discussion later this
23 afternoon will try to address some of those.

24 MR. CARBON: Maybe that is a good place --

25 MR. LIPINSKI: The discussion on aux feedwater

1 is good, but in TMI 2 they locked out the diesels. Is
2 your design going to prevent that?

3 MR. CLARE: I don't think I have the answer to
4 that question. Your comment isn't fully consistent with
5 my knowledge of the TMI event.

6 MR. LIPINSKI: At one point, those diesels
7 started. They stopped and they put them in the lockout
8 position so they wouldn't start automatically. That was
9 recovered late in the event, and somebody told them to
10 restart them, but they were sitting there for minutes in
11 the lockout position. Are you going to have a simulator
12 that is going to be an exact replica of your control
13 room?

14 MR. CLARE: Yes.

15 MR. CARBON: It looks like we are falling
16 behind schedule. Could we move on, Mr. Becker, and try
17 to get back on it?

18 MR. BECKER: I can go pretty quickly through
19 these others. I just had a couple of slides here to
20 perhaps kind of flesh out a little bit. There are two
21 kinds of approaches in looking at these things.

22 (Slide.)

23 MR. BECKER: One I define as a mechanistic
24 accident definition. Basically, that is the kind of
25 thing we are looking at the component failure. It also

1 includes historic accidents, things that have happened
2 like Fermi, the Fermi fuel melt and SL-1 and many other
3 things, for example, looking at all the potential
4 accidents. I indicated just a few items that, for
5 example, you look at the pump failure, seizure, loss of
6 electric power to the pump, these kinds of things. They
7 have become rather accepted ways to look at accident
8 scenarios.

9 (Slide.)

10 MR. BECKER: Then, just to kind of flesh out
11 the generic approach that I talked about, basically,
12 when you look at the reactivity, reactivity flow
13 interaction kinds of things, the sodium voiding, the
14 reactivity feedback associated with that, or
15 undercooling flow, both loss of system flow or local
16 flow, flow blockages, those kinds of things, and compare
17 those back with what you have, basically, the broader
18 categories of accidents, and cross-compare those with
19 the mechanistic sequence, and compare and see, do you
20 have those kinds of things that fill out your design
21 basis map.

22 (Slide.)

23 MR. BECKER: Then I said, one of the other
24 things we look at is the categorization of these events
25 as to what their frequencies are. This is one of the

1 things we evaluate, the frequency of the event, is it
2 consistent with the categorization of it. This is
3 simply the definition, basically. The incidence of
4 moderate frequency, the anticipated fault, the
5 infrequent incident or unlikely fault, or limiting
6 faults or extremely unlikely faults.

7 The applicant has defined an acceptance
8 criteria or a limiting criteria which we also are
9 evaluating, and if you will just keep this in mind, I
10 have got a slide which correlates with this, basically,
11 with the criteria for accepting the accidents which are
12 based on this categorization.

13 MR. MARK: This particular vu-graph, this
14 particular notion that is represented there really cries
15 out for numbers of the sort that Zenon Zudans was
16 talking about earlier. I quite admit and agree, we are
17 not prepared to put them on, but where are the break
18 points between those three different categories? What
19 do you mean by extremely unlikely? What do you mean by
20 unlikely? And what do you mean by anticipated? They
21 really cry out for a definition in terms of once per
22 reactor life or once per year or once per never, things
23 like that.

24 MR. BECKER: I think I agree with you. I
25 think this falls into the same category as -- It would

1 be nice, for example, to put a number on the design
2 basis. What is the design basis envelope? Everything
3 that is smaller than this is outside, and everything
4 that is --

5 MR. MARK: That is enough. It would be nice.
6 I don't think we are prepared to do it. I think at some
7 time we should anticipate and hope that it might be
8 done.

9 MR. BECKER: I was going to add just one
10 point. I think it has been said before, but it is
11 perhaps worth saying again. That is that the
12 uncertainty associated with trying to put those numbers
13 down is, I believe, the thing which keeps us from
14 relying heavily on those. The things that have very low
15 failure frequencies have large uncertainties to them.
16 They are very difficult numbers to measure and
17 establish. So it is really engineering judgment which
18 is the thing that establishes what those are, and that
19 is what we look at and review to see if we agree with
20 the articulated frequency, essentially, not looking at
21 the numbers.

22

23

24

25

1 Take some guidance from that perhaps from
2 numbers, but we do not rely on the absolute magnitude.

3 MR. KASTENBERG: Is it clear that frequency is
4 the only number you might attach to those? You might
5 consider dose or some pseudo-consequence to go along
6 with those rather than frequency itself that may have a
7 narrower uncertainty.

8 MR. BECKER: It is possible that you might
9 attach some other significance to it, except as far as
10 dose is concerned, while there has been no attempt to
11 delineate it in that fashion. But you are right. It is
12 possible that there might be other numbers.

13 MR. KASTENBERG: Or combinations of other
14 numbers.

15 MR. ZUDANS: I think that would be a
16 completely incorrect view of the issue, because we are
17 talking here in defining design basis events. Then we
18 are going to take those and define components so that
19 they do not get damaged, so we do not expect any
20 releases. So there is nothing to measure.

21 MR. KASTENBERG: That is why I said there
22 could be some other pseudo consequence such as a fuel
23 temperature, a clad temperature, a coolant temperature.

24 MR. ZUDANS: That is right, yes. There could
25 be some limits of that sort rather than probabilistic.

1 MR. BECKER: That is right. Categorization of
2 a criterion, an acceptance criterion. I think that is
3 right and that is what is proposed. There is no
4 question about that. I am not sure as far as dose is
5 concerned because I think you would be artificially
6 putting steps in-between.

7 (Slide.)

8 MR. BECKER: This is almost a redundant slide
9 to the applicant's this morning. They went through it
10 in much greater detail. One of the things -- there are
11 certain methodologies associated with what are implied
12 by design basis events. These things are generally
13 applied, and that is one of the things that we
14 evaluate.

15 The difficulty we have, I think, with looking
16 at events which have been covered, such as the station
17 blackout and mitigating features for events outside the
18 design basis, is how do you establish how you should
19 evaluate that particular event. Do you do it in the
20 conservative fashion of design basis? If you do it in
21 the conservative fashion of the design basis, you have
22 almost drawn it inside the design basis by fault, so the
23 systems tend to lose their distinction.

24 They tend to become confusing to the Staff, I
25 think, and they also become confusing to the public, so

1 that is why we have elected to clearly separate the
2 two.

3 Chapter 15, looking at the design basis
4 events, and appendix, looking at beyond the design
5 basis, and the criteria for those systems are discussed
6 in a separate fashion.

7 (Slide.)

8 MR. BECKER: Finally, recalling back that
9 slide on categorization, for most of the -- I think this
10 acceptance criteria basically covers all of the design
11 basis accidents and it is keyed to the categorization of
12 events. This is the acceptance criteria proposed by the
13 applicant. It is one which we are evaluating.
14 Basically, it is a step below the principal design
15 criteria. I think it can be said it is consistent with
16 the general design criteria and it is conservative in
17 the sense that it is being proposed, we believe.

18 MR. KASTENBERG: Does this relate back to the
19 question I raised this morning about the fuel
20 temperature where you have an extremely unlikely fault?
21 You have a dash in there.

22 MR. BECKER: That is right.

23 MR. KASTENBERG: So that is something you will
24 resolve at some point?

25 MR. BECKER: That is something we will

1 resolve, yes.

2 MR. ZUDANS: Is part of this DBA the view also
3 that touches upon emergency operator procedure
4 development?

5 MR. BECKER: We have nothing that -- no. In
6 fact, the answer to that is no. There are cases where
7 emergency procedures are definitely implied, for
8 example.

9 MR. ZUDANS: But they are not developed as yet
10 for this plant?

11 MR. BECKER: No. The station blackout, for
12 example, is an emergency procedure situation.

13 MR. ZUDANS: Well, has the applicant already
14 presented some emergency operating procedures for some
15 of these?

16 MR. BECKER: No. There have been no emergency
17 procedures. Their discussions require no emergency
18 procedures, nor have they presented any.

19 MR. ZUDANS: I guess this would be mostly for
20 beyond design basis events.

21 MR. BECKER: Mostly for beyond design basis
22 events, yes. I think there are certain things that are
23 indicated. Emergency procedures generally are indicated
24 for most design basis accidents, but they are not
25 necessarily required in order to make those accidents

1 acceptable, or the mitigation of those accidents
2 acceptable.

3 MR. ZUDANS: There is another question that I
4 am not quite clear on. There is a bunch of DBAs being
5 defined and you are reviewing them, and there are a
6 number of automatic actions that kind of channel that
7 particular event in its proper path, so to speak.

8 Are you looking at the tools used to identify
9 that this is indeed the kind of event that is being
10 mitigated by automatic actions, or is it possible that
11 automatic actions could respond in an erroneous way just
12 like the operator could do because this total symptom
13 package is not unique for a particular event?

14 MR. BECKER: The controls and instrumentation
15 are evaluated as well as all other aspects of the plant
16 in this sense, yes. I am not sure whether that directly
17 answers your question or not. The tools part of the
18 question --

19 MR. ZUDANS: We discussed just a minute ago
20 how operator actions are excluded from the DBAs because
21 it is assumed that automatic actions by the control
22 system or by the protection system would be handling and
23 guiding the event in its proper path.

24 MR. BECKER: That is correct.

25 MR. ZUDANS: What I am asking is is the

1 identification of a particular event so unique that the
2 automatic actions on the protection system will always
3 be correct? Could the protection system think it has
4 something and it does not really have that and it makes
5 an action that is not in error, it is based on
6 symptoms? It is the question of selection of symptoms
7 that certain actions are being initiated by.

8 Who looks at that? That is a design phase,
9 really.

10 MR. BECKER: It is a composite of looking at
11 the accident and also looking at the control and
12 instrumentation required to do those things, and that is
13 part of the review.

14 MR. ZUDANS: So this is in addition to human
15 error.

16 MR. BECKER: Well, if we have done our job
17 correctly, I think that the human error is minimized and
18 our review process basically says that the plant is
19 doing what the applicant says it is supposed to be
20 doing. We are basically validating and reviewing what
21 they have said it was to do, and basically when we come
22 out with our safety evaluation report we have said that
23 we will have essentially made that assurance.

24 I think maybe Bill Morris wants to give an
25 addition to that, but that is --

1 MR. ZUDANS: It is an unfair question, really,
2 because it digs into how the design is made.

3 MR. LIPINSKI: But if you do your failure
4 modes and effects analysis and feed that into a PRA, you
5 should be able to go up and down all these different
6 paths and get the probabilities down with the path to
7 show whether it is a reasonable path or whether it is
8 too much of a probability.

9 MR. BECKER: Yes. The distillation of all
10 these things should give you that assurance, that is
11 does what you say it is going to do and basically that
12 it does.

13 MR. CARBON: Carson?

14 MR. MARK: On that slide you say solidus, but
15 this is a design basis event and it is allowed -- the
16 fuel temperature --

17 MR. BECKER: This is melting of the clad.

18 MR. MARK: So the slide is not exactly
19 complete. Now what is the temperature at which the clad
20 melts the 304 stainless or whatever it is that they are
21 using?

22 MR. BECKER: 2,475.

23 MR. MARK: So you have a 2,475 margin in
24 there. It is kind of small compared to the error of the
25 temperature-measuring devices.

1 MR. BECKER: Well, that is a limit.

2 MR. MARK: Fine. Anyway, the stuff does not
3 melt?

4 MR. BECKER: That is the intent, that you do
5 not melt.

6 MR. KASTENBERG: I am just curious about one
7 thing, though, with respect to the solidus. I would
8 think an anticipated fault is something you might
9 anticipate occurring during the lifetime of the plant,
10 even though in the design basis concept you have certain
11 conservatisms.

12 MR. BECKER: That is correct.

13 MR. KASTENBERG: We know that for mixed oxide
14 fuel element you start to get sufficient fission gas
15 release well below melting -- that is, if you have a
16 transient. I guess -- did you consider that in your
17 review of accepting, say, on an anticipated fault that
18 you would allow the fuel to go up close to the solidus?
19 It would almost seem that that fuel loading may be shot
20 at that point, even though it is measured correctly.

21 MR. CARBON: I do not think they mean to imply
22 that the fuel will get to that very high temperature in
23 the anticipated fault case.

24 MR. KASTENBERG: They pose it as a limit. I
25 guess I am trying to understand how you interpret that.

1 MR. BECKER: The statement that I guess I gave
2 you on the slide is that this is the criteria proposed
3 by the applicant and is under evaluation. I think we
4 take into account those things. I cannot give you a
5 judgment right now whether that criteria is applicable.
6 That is the criteria that we are evaluating and it is
7 under evaluation.

8 MR. CARBON: Any other questions of Mr.
9 Becker?

10 (No response.)

11 MR. CARBON: If not, thank you very much.

12 The agenda now calls for a closed session on
13 plant safety and security, and rather than go into that,
14 it would seem to work out best logistically if we had
15 any discussion or if we had a discussion on the first
16 two topics -- design criteria and the rationale for
17 DBAs -- at this time, and then we will go into closed
18 session, with that essentially ending the open portion
19 of the meeting.

20 So let us discuss the presentation, our
21 questions, comments and so on on the design criteria.

22 As you are fully aware, the hope and intention
23 of the Staff is to bring a discussion of the topic to
24 the full Committee meeting next week. Will you be
25 seeking some sort of word from the full Committee or do

1 you simply want to present what you are doing?

2 MR. MORRIS: We would like an endorsement of
3 the principal design criteria, if possible.

4 MR. MARK: Max?

5 MR. CARBON: Yes, Carson.

6 MR. MARK: Anticipating next week, I think
7 that the Staff, if you will, might find it worthwhile to
8 explain more not in length but perhaps in greater
9 clarity and precision how your approach has been
10 determined -- the approach you have taken -- to the full
11 Committee to avoid or soften some of the questions which
12 kept emerging today.

13 Why don't you have this in there? Why don't
14 you have in there? And make it clearer. It seems to me
15 there was something that was not much said today that
16 probably is in your mind and certainly you would have to
17 understand it if it were, if you do not wish to
18 incorporate in this set of criteria things which would
19 open up doors in the LWR criteria for litigation or
20 heaven knows what.

21 That is, you do not have station blackout in
22 the LWR criteria. If you put them in here, then you are
23 going to have to expect that there will be the question
24 from someone -- why don't you have station blackout in
25 the LWR criteria. And there are a few other points like

1 that that you have carefully held back from, as I
2 picture it, in order not to open up a bigger can of
3 worms than you have already got affecting the rest of
4 the system.

5 MR. MORRIS: Yes. I said something along
6 these lines this morning. It is maybe not for the same
7 reason you said, it is just that we believe it would be
8 premature for us to make a judgment about what an
9 appropriate criterion for station blackout would be
10 while there is still an unresolve safety issue. We
11 would prefer to have that completed.

12 And there are similar other cases

13 MR. MARK: Yes, there are.

14 MR. MORRIS: And we would not want to move
15 into new territory.

16 MR. MARK: I believe it would be worthwhile
17 for you to point out a couple of those and say that is
18 why they are not changed, because of the fact that it is
19 either premature, they are generic to both sets of
20 reactors, and we cannot really live with the situation
21 when we put something down here that is not there, to be
22 there when it is not there already.

23 Things of that kind, I believe, could be
24 explained and would be helpful and smooth the
25 discussion, and I think that was the main point I wanted

1 to make. Single failure is probably another example of
2 that same broad sort.

3 While you said it this morning, it seems to me
4 it could be said with more emphasis. This is not CRBR
5 and if there are any further LMFBRs there will need to
6 be general design criteria for them which you think will
7 look at lot like this but will not necessarily be
8 identical.

9 MR. CARBON: I would like to add to that and
10 suggest that the kinds of things Carson is speaking of
11 are more the kinds of things that you explained rather
12 than Tom did, so I would urge that at least a
13 significant chunk of the time next week be devoted to
14 these broader points that Carson is raising -- the
15 philosophy, the background, your limitation and so on.
16 And then perhaps Tom could follow with some details, if
17 you wish, but this basic part comes first and I think
18 you are the individual who will probably have to
19 present.

20 MR. MARK: Unless Paul Check is still in
21 town.

22 MR. CARBON: Well, Paul is fine.

23 MR. MORRIS: We understand.

24 MR. CARBON: Other comments? Jerry? Bill?
25 Walt? Zenons?

1 (No response.)

2 MR. CARBON: I guess you have heard all our
3 comments all day, so I would not repeat specific ones.

4 I would comment that I have the agenda for
5 next week and this is scheduled for 2:30 to 4:30 on
6 Thursday afternoon -- 2:30 to 4:30 total.

7 MR. RAY: That is the fourth.

8 MR. CARBON: It is a fairly short time. Can
9 you -- you will need to summarize and hit things pretty
10 hard and precisely, I believe. Are there any other
11 comments?

12 If any of you three gentlemen have any
13 comments you care to write down as you travel home or
14 anything, I will welcome them.

15 MR. ZUDANS: I assume the transcript will be
16 available in time for the Staff to review before the
17 meeting next week. I think it is really difficult to
18 state it more concisely than we did during the
19 discussion. In fact, I do not even remember.

20 (Laughter.)

21 MR. CARBON: It will be interpreted
22 differently.

23 MR. ZUDANS: You will probably observe that as
24 the meeting proceeds and we get a better understanding
25 of what each party wants, it becomes a moving target as

1 to what we really want, to some extent. We must
2 recognize that the Staff has good reasons for what they
3 do and applicant has good reasons for what they do, and
4 we have good reasons for what we want, and they may not
5 be compatible.

6 MR. KASTENBERG: I just have one point of
7 information. Will we have a session which will explore
8 your appendix to the SER which covers mitigation beyond
9 the design basis before you actually issue the SER and
10 your acceptance criteria for the design basis accident?

11 MR. MORRIS: I believe we have on the
12 schedule the 18th or 19th core disruptive accident
13 energetics. That will not have criteria in it as such.
14 The past in other sessions earlier we did discuss this
15 criteria in a general form. I believe when the SER
16 comes out, it will have more specific details than what
17 you have seen in the past and I think we will just do
18 what you wish.

19 If you wish to have that at some future date,
20 another session to go into that in more detail, I think
21 we can have that. Ultimately, we may be able to provide
22 to you some preliminary portions of the SER that would
23 help you look at that and then subsequently have another
24 meeting to try to resolve that.

25 MR. CARBON: Certainly there are more topics

1 to be discussed down the road -- the CDA on the 19th, as
2 mentioned. We are planning more discussion and comment
3 on such things as sodium-concrete interactions and
4 challenges to containment. There is further discussion
5 coming, and maybe that is on the 18th, of the seismic
6 margins.

7 MR. MORRIS: If you mentioned a meeting
8 already planned for sodium-concrete interactions, that
9 is related to the criteria for beyond design basis
10 accidents.

11 MR. CARBON: I do not know of any meeting
12 specifically planned, but we will need discussion.

13 MR. MORRIS: If you need another discussion
14 of that, that is coincident. It is the same subject
15 essentially as criteria for beyond design basis
16 mitigating systems.

17 MR. CARBON: Let's go to the second topic,
18 then, the rationale for DBAs. Are you expecting any
19 sort of definitive action from us -- information?

20 MR. MORRIS: I might say one thing. I
21 believe we all recognize that even though we cannot
22 articulate it and cannot make that crisp a connection
23 between the principal design criteria and the DBAs that
24 there is some connection. We admit to you that it is a
25 difficult connection to make. We hope you will

1 understand that eventually we will have a set of
2 principal design criteria, specific criteria, and a set
3 of DBAs.

4 I just want to emphasize that this session on
5 DBAs I think has some bearing on your opinion about the
6 principal design criteria, although I hope you will
7 recognize that I believe, and I think others believe,
8 the principal design criteria perhaps are directed more
9 towards the general types of DBAs rather than towards
10 the specifics, and in that connection we do not expect a
11 specific statement from you in the near future, but
12 there is a relation.

13 MR. CARBON: Does anyone have any comments
14 they wish to make?

15 MR. ZUDANS: I would like to comment on what
16 you just said, Bill. I think we understand the
17 difficulty in identifying whether the chicken or egg
18 came before, but I think there is something that is
19 definitely before, and that is the three objectives or
20 three things that each nuclear power plant has to
21 satisfy, as stated by Mr. Clare.

22 You have reactivity control, residual heat
23 removal and mitigation of the consequences of release.
24 That is a general design criteria that everyone can
25 agree upon without any further comment. It is like

1 axioms in any particular mathematical theory, and if you
2 do those, many of your criteria respond directly to
3 these things. Many other criteria go and respond to and
4 identify the DBA.

5 So that is where kind of a mix comes into the
6 picture. Whether or not you can completely clean it up
7 is really difficult to say. I appreciate the tremendous
8 task, but that is the way it should be if it is possible
9 at all.

10 MR. CARBON: I would still make the comment
11 that I really do not agree until you add in the
12 criterion for preventing accidents, but I said that this
13 morning.

14 MR. ZUDANS: You are quite right, but many
15 accidents start out with initiators that have nothing to
16 do with your wishes. The weld breaks down, something
17 busts -- that is it. You cannot prevent that because
18 each component in the system has its own kind of a
19 failure probability. It has its own particular
20 reliability.

21 Now there is no question that that is the
22 ultimate objective. It is better to prevent than to
23 mitigate.

24 MR. CARBON: Well, we should not get into an
25 argument across the table.

1 MR. ZUDANS: I think we agree.

2 MR. CARBON: We seem to use different words,
3 so let's just stop.

4 Walt, do you have any comments?

5 MR. LIPINSKI: No, nothing further.

6 MR. CARBON: Bill, Jerry, Carson?

7 (No response.)

8 MR. CARBON: Well, I believe that ends our
9 discussion, then. Does either the project or the Staff
10 have anything else to bring up on these two subjects in
11 these two areas?

12 (No response.)

13 MR. CARBON: If not, then I believe we are
14 through with the first two-thirds of the meeting. We
15 will take a short break and go into closed session and
16 at the end of the closed session we will adjourn the
17 meeting. We will not take a transcript.

18 (Whereupon, at 3:30 o'clock p.m., the
19 Subcommittee recessed, to reconvene after a brief recess
20 in closed session.)

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/Subcommittee on Clinch River Breeder Reactor

Date of Proceeding: October 27, 1982


Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Jane N. Beach

Official Reporter (Typed)


Jane N. Beach

Official Reporter (Signature)

CRBR PRINCIPAL DESIGN
CRITERIA

10-27-82

TI

PURPOSE

10CFR50

The Principal Design Criteria establish the necessary design, fabrication, construction, testing, and performance requirements for structures, systems and components important to safety; that is, structures, systems, and components that provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.

HOW ACCOMPLISHED

THE INTENT OF THE CRITERIA IS TO EXPRESS THE BROAD REQUIREMENTS WHICH MUST BE MET TO ENSURE THAT THE SAFETY OF CRBR IS COMPARABLE TO LWRS AND THAT CORE DISRUPTIVE ACCIDENTS ARE OF SUFFICIENTLY LOW LIKELIHOOD THAT THEY CAN BE EXCLUDED FROM THE PLANT DESIGN BASIS. THIS IS ACCOMPLISHED BY:

- (A) ESTABLISHING REQUIREMENTS FOR THOSE STRUCTURES, SYSTEMS AND COMPONENTS (WHICH ARE COMPARABLE TO STRUCTURES, SYSTEMS, AND COMPONENTS IN LWRS) EQUIVALENT TO OR MORE CONSERVATIVE THAN THE CORRESPONDING REQUIREMENTS FOR LWRS.

- (B) ESTABLISHING REQUIREMENTS FOR THOSE STRUCTURES, SYSTEMS, AND COMPONENTS UNIQUE TO CRBR WHICH ARE CONSISTENT WITH THEIR IMPORTANCE TO SAFETY AND WHICH REFLECT AN EQUIVALENT OR MORE CONSERVATIVE SAFETY APPROACH THAN THAT GENERALLY APPLIED TO LWRS.

- (C) ESTABLISHING REQUIREMENTS ON THE CRBR DESIGN WHICH WILL MAKE THE LIKELIHOOD OF CORE DISRUPTIVE ACCIDENTS SUFFICIENTLY LOW THAT THEY CAN BE EXCLUDED FROM THE CRBR DESIGN BASIS.

CRBR - PRINCIPAL DESIGN CRITERIA -
APPROACH USED IN DEVELOPMENT

- 1) WHERE THERE WAS NO SUBSTANTIAL DIFFERENCE BETWEEN CRBR AND LWRs - THE GDC FROM 10 CFR 50, APPENDIX A, WAS ADOPTED IN ITS ENTIRETY.
- 2) WHERE THE INTENT OF A GDC APPLIED TO CRBR, THE GDC WAS ADOPTED TO THE MAXIMUM EXTENT PRACTICAL WITH MODIFICATIONS ONLY TO ADAPT TO CRBR SYSTEMS OR TERMINOLOGY.
- 3) WHERE SIGNIFICANT OR UNIQUE DIFFERENCES EXIST BETWEEN CRBR AND LWRs, ADDITIONAL CRITERIA WERE DEVELOPED TO ADDRESS THE SAFETY-RELATED CONCERNS OF THESE DIFFERENCES.
- 4) CONSIDERATION WAS GIVEN TO PDCs OF SEFOR AND FFTF, PREVIOUS LMFBR EXPERIENCE, AND ANS 54, IN JUDGING COMPLETENESS.
- 5) THE CRITERIA ADDRESS STRUCTURES, COMPONENTS, AND SYSTEMS ASSOCIATED ONLY WITH DESIGN BASIS EVENTS AND THOSE FEATURES WHICH REDUCE THE LIKELIHOOD OF CORE DISRUPTIVE ACCIDENTS SUFFICIENTLY THAT THEY CAN BE EXCLUDED FROM THE DESIGN BASIS.

FUNCTIONS OF CRITERIA

PROVIDE REQUIREMENTS ON THE DESIGN TO ENSURE:

- . CONTROL OF REACTIVITY AND THE FISSION PROCESS
- . PRESERVATION OF THE BARRIERS TO RADIOACTIVITY RELEASE
- . QUALITY OF DESIGN, FABRICATION AND TESTING
- . RELIABILITY
- . PROTECTION FROM FIRES
- . SUFFICIENT COOLANT INVENTORY
- . PROTECTION AGAINST NATURAL PHENOMENA
- . SUFFICIENT DECAY HEAT REMOVAL
- . PROVISIONS FOR TESTING AND INSPECTION
- . SYSTEM INTEGRITY
- . CONTROL OF THE RELEASE OF RADIOACTIVITY TO THE ENVIRONMENT
- . CONTROL OF PARAMETERS IMPORTANT TO SAFETY

SUMMARY OF CHANGES

1976 VERSION:

OF THE 55 CRITERIA IN 10 CFR 50, APPENDIX A

- 9 WERE OMITTED
- 10 UNIQUE ONES WERE ADDED FOR A TOTAL OF 56
- OF THE 46 APPENDIX A CRITERIA USED, 23 WERE MODIFIED
IN SOME WAY TO APPLY TO CRBR

PROPOSED VERSION

OF THE 55 CRITERIA IN 10 CFR 50, APPENDIX A

- 7 ARE OMITTED
- 12 UNIQUE ONES HAVE BEEN ADDED FOR A TOTAL OF 60
- OF THE 48 APPENDIX A CRITERIA USED, 27 HAVE BEEN MODIFIED
IN SOME WAY TO APPLY TO CRBR

CRBR CRITERIA IDENTICAL TO 10 CFR 50, APPENDIX A, CRITERIA

- #1 - QUALITY STANDARDS & RECORDS (1)
- #2 - DESIGN BASIS FOR PROTECTION AGAINST NATURAL PHENOMENA (2)
- #3 - FIRE PROTECTION (3)
- #6 - SHARING OF STRUCTURES, SYSTEMS, COMPONENTS (5)
- #9 - REACTOR INHERENT PROTECTION (11)
- #10 - SUPPRESSION OF REACTOR POWER OSCILLATIONS (12)
- #14 - CONTAINMENT DESIGN (16)
- #16 - INSPECTION & TESTING OF ELECTRICAL POWER SYSTEMS (18)
- #19 - PROTECTION SYSTEM RELIABILITY & TESTABILITY (21)
- #22 - SEPARATION OF PROTECTION & CONTROL SYSTEMS (24)
- #28 - QUALITY OF REACTOR COOLANT BOUNDARY (30)
- #43 - CAPABILITY FOR CONTAINMENT LEAKAGE RATE TESTING (52)
- #44 - PROVISIONS FOR CONTAINMENT TESTING & INSPECTION (53)
- #45 - PIPING SYSTEMS PENETRATING CONTAINMENT (54)
- #47 - PRIMARY CONTAINMENT ISOLATION (56)
- #50 - INSPECTION OF CONTAINMENT ATMOSPHERE. CLEANUP SYSTEM (42)

T2

CRBR CRITERIA IDENTICAL TO 10 CFR 50, APPENDIX A, CRITERIA (CONT'D.)

- #51 - TESTING OF CONTAINMENT ATMOSPHERE CLEANUP SYSTEM (43)
- #52 - CONTROL OF RELEASES OF RADIOACTIVE MATERIALS (60)
- #54 - PREVENTION OF CRITICALITY IN FUEL STORAGE & HANDLING (62)
- #55 - MONITORING FUEL & WASTE STORAGE (63)
- #58 - PROTECTION AGAINST ANTICIPATED OPERATIONAL OCCURRENCES (29)

CRBR CRITERIA SIMILAR TO 10 CFR 50, APPENDIX A, CRITERIA

- #5 - ENVIRONMENTAL & MISSILE DESIGN BASIS (4)
- *#8 - REACTOR DESIGN (10)
- #11 - INSTRUMENTATION & CONTROL (13)
- #12 - REACTOR COOLANT BOUNDARY (14)
- #13 - REACTOR COOLANT SYSTEM DESIGN (15)
- #15 - ELECTRICAL POWER SYSTEMS (17)
- #17 - CONTROL ROOM (19)
- #18 - PROTECTION SYSTEM FUNCTIONS (20)
- #20 - PROTECTION SYSTEM INDEPENDENCE (22)
- #21 - PROTECTION SYSTEM FAILURE MODES (23)
- #23 - PROTECTION SYSTEM REQUIREMENTS FOR REACTIVITY CONTROL MALFUNCTIONS (25)
- *#24 - REACTIVITY CONTROL SYSTEM REDUNDANCY (26)
- *#25 - REACTIVITY CONTROL SYSTEM CAPABILITY (27)
- #29 - FRACTURE PREVENTION OF REACTOR COOLANT BOUNDARY (31)
- #30 - INSPECTION OF REACTOR COOLANT BOUNDARY (32)
- *#35 - REACTOR RESIDUAL HEAT EXTRACTION SYSTEM (34)

CRBR CRITERIA SIMILAR TO 10 CFR 50, APPENDIX A, CRITERIA (CONT'D.)

- #38 - ADDITIONAL COOLING SYSTEMS (44)
- #39 - INSPECTION OF ADDITIONAL COOLING SYSTEMS (45)
- #40 - TESTING OF ADDITIONAL COOLING SYSTEMS (46)
- #41 - CONTAINMENT DESIGN BASIS (50)
- #42 - FRACTURE PREVENTION OF REACTOR CONTAINMENT BOUNDARY (51)
- #46 - REACTOR COOLANT BOUNDARY PENETRATING CONTAINMENT (55)
- #48 - CLOSED SYSTEMS PENETRATING CONTAINMENT (57)
- #49 - CONTAINMENT ATMOSPHERE CLEANUP (41)
- #53 - FUEL STORAGE & HANDLING & RADIOACTIVITY CONTROL (61)
- #56 - MONITORING RADIOACTIVITY RELEASE (64)
- #57 - REACTIVITY LIMITS (28)

* - INDICATES MAJOR CHANGE FROM APPENDIX A CRITERION.

UNIQUE CRBR CRITERIA

- #4 - PROTECTION AGAINST SODIUM & NaK REACTIONS
- #7 - SODIUM HEATING SYSTEMS
- #26 - HEAT TRANSPORT SYSTEM DESIGN
- #27 - ASSURANCE OF ADEQUATE COOLANT INVENTORY
- #31 - INTERMEDIATE COOLANT SYSTEM
- #32 - FRACTURE PREVENTION OF INTERMEDIATE COOLANT BOUNDARY
- #33 - INSPECTION & SURVEILLANCE OF INTERMEDIATE COOLANT BOUNDARY
- #34 - REACTOR & INTERMEDIATE COOLANT BOUNDARY & COVER GAS PURITY
- #36 - INSPECTION OF REACTOR RESIDUAL HEAT EXTRACTION SYSTEM
- #37 - TESTING OF REACTOR RESIDUAL HEAT EXTRACTION SYSTEM
- #59 - FUEL ROD FAILURE PROPAGATION
- #60 - FLOW BLOCKAGE

10 CFR 50 - APPENDIX A CRITERIA NOT USED BY CRBR

- #33 - REACTOR COOLANT MAKEUP
- #35 - EMERGENCY CORE COOLING
- #36 - INSPECTION OF EMERGENCY CORE COOLING SYSTEM
- #37 - TESTING OF EMERGENCY CORE COOLING SYSTEM
- #38 - CONTAINMENT HEAT REMOVAL
- #39 - INSPECTION OF CONTAINMENT HEAT REMOVAL SYSTEM
- #40 - TESTING OF CONTAINMENT HEAT REMOVAL SYSTEM

MAJOR CHANGES FROM 1976 VERSION

- #8 - REACTOR DESIGN - REQUIREMENT ADDED TO HAVE THE DESIGN PROVIDE MEANS TO PREVENT FUEL MANAGEMENT ERRORS.

- #24 - REACTIVITY CONTROL SYSTEM REDUNDANCY - REQUIREMENT CHANGED TO HAVE THE DESIGN PROVIDE TWO TOTALLY INDEPENDENT REACTIVITY CONTROL SYSTEMS, EACH CAPABLE OF TERMINATING ALL DESIGN BASIS EVENTS AND TO SPECIFY SHUTDOWN MARGIN REQUIREMENTS.

- #25 - REACTIVITY CONTROL SYSTEM CAPABILITY - REQUIREMENT CHANGED TO HAVE THE DESIGN PROVIDE TWO TOTALLY INDEPENDENT REACTIVITY CONTROL SYSTEMS, EACH CAPABLE OF TERMINATING ALL DESIGN BASIS EVENTS.

- #35 - REACTOR RESIDUAL HEAT EXTRACTION SYSTEM - REQUIREMENT CHANGED TO HAVE THE DESIGN INCLUDE INDEPENDENCE AND DIVERSITY, TO REQUIRE COOLANT COMPATABILITY WITH THE REACTOR COOLANT AND TO REQUIRE AT LEAST TWO FLOW PATHS REMAIN AVAILABLE FOLLOWING A SINGLE FAILURE.

MAJOR CHANGES FROM 1976 VERSION (CONT'D.)

- #57 - REACTIVITY LIMITS - NEW CRITERION ADDED - IT IS SIMILAR TO GDC #28.
- #58 - PROTECTION AGAINST ANTICIPATED OPERATIONAL OCCURRENCES - NEW CRITERION ADDED - IT IS IDENTICAL TO GDC #29.
- #59 - FUEL ROD FAILURE PROPAGATION - NEW CRITERION ADDED - IT REQUIRES THE DESIGN INCLUDE FEATURES TO LIMIT FUEL ROD FAILURE PROPAGATION.
- #60 - FLOW BLOCKAGE - NEW CRITERION ADDED - IT REQUIRES THE DESIGN INCLUDE FEATURES TO MINIMIZE THE POTENTIAL FOR FLOW BLOCKAGE.

CRITERION 8 - REACTOR DESIGN - THE REACTOR AND ASSOCIATED COOLANT, CONTROL, AND PROTECTION SYSTEMS SHALL BE DESIGNED WITH APPROPRIATE MARGIN TO ASSURE THAT SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS ARE NOT EXCEEDED DURING ANY CONDITION OF NORMAL OPERATION, INCLUDING THE EFFECTS OF ANTICIPATED OPERATIONAL OCCURRENCES. IN ADDITION, MEANS SHALL BE PROVIDED TO PREVENT FUEL MANAGEMENT ERRORS THAT COULD RESULT IN FUEL DAMAGE LIMITS BEING EXCEEDED.

CRITERION 24 - REACTIVITY CONTROL SYSTEM REDUNDANCY AND CAPABILITY - TWO INDEPENDENT REACTIVITY CONTROL SYSTEMS OF DIFFERENT DESIGN PRINCIPLES SHALL BE PROVIDED. EACH SYSTEM SHALL BE CAPABLE OF RELIABLY RESPONDING TO REACTIVITY CHANGES TO ASSURE THAT UNDER CONDITIONS OF NORMAL OPERATION, AND ANTICIPATED OPERATIONAL OCCURRENCES AND WITH APPROPRIATE MARGIN FOR MALFUNCTIONS SUCH AS A STUCK ROD, SPECIFIED ACCEPTABLE FUEL DESIGN LIMITS ARE NOT EXCEEDED. EACH SYSTEM SHALL HAVE SUFFICIENT WORTH, ASSUMING FAILURE OF ANY SINGLE ACTIVE COMPONENT, TO SHUT DOWN THE REACTOR FROM ANY OPERATING CONDITION TO ZERO POWER AND MAINTAIN SUBCRITICALITY AT THE HOT SHUTDOWN TEMPERATURE OF THE COOLANT, WITH ALLOWANCE FOR THE MAXIMUM REACTIVITY ASSOCIATED WITH ANY ANTICIPATED OPERATIONAL OCCURRENCE OR POSTULATED ACCIDENT. ONE OF THE SYSTEMS SHALL BE CAPABLE OF HOLDING THE REACTOR CORE SUBCRITICAL FOR ANY COOLANT TEMPERATURE ASSOCIATED WITH NORMAL OPERATION.

CRITERION 25 -REACTIVITY CONTROL SYSTEMS CAPABILITY - THE REACTIVITY CONTROL SYSTEMS SHALL BE DESIGNED TO HAVE AN INDEPENDENT CAPABILITY OF RELIABLY CONTROLLING REACTIVITY CHANGES TO ASSURE THAT UNDER POSTULATED ACCIDENT CONDITIONS AND WITH APPROPRIATE MARGIN FOR A STUCK ROD, THE CAPABILITY TO COOL THE CORE IS MAINTAINED.

CRITERION 35 - REACTOR RESIDUAL HEAT EXTRACTION SYSTEM - A REACTOR RESIDUAL HEAT EXTRACTION SYSTEM SHALL BE PROVIDED TO TRANSFER RESIDUAL HEAT FROM THE REACTOR COOLANT SYSTEM TO ULTIMATE HEAT SINKS UNDER ALL PLANT SHUTDOWN CONDITIONS FOLLOWING NORMAL OPERATION, ANTICIPATED OPERATIONAL OCCURRENCES AND POSTULATED ACCIDENT CONDITIONS. A PASSIVE BOUNDARY SHALL NORMALLY SEPARATE REACTOR COOLANT FROM THE WORKING FLUIDS OF THE REACTOR RESIDUAL HEAT EXTRACTION SYSTEM. ANY FLUID IN THE RESIDUAL HEAT EXTRACTION SYSTEM THAT IS SEPARATED FROM THE REACTOR COOLANT BY A SINGLE PASSIVE BARRIER SHALL NOT BE CHEMICALLY REACTIVE WITH THE REACTOR COOLANT.

SUITABLE REDUNCANCY, INDEPENDENCE AND DIVERSITY IN SYSTEMS, COMPONENTS AND FEATURES, AND SUITABLE INTERCONNECTIONS, LEAK DETECTION, AND ISOLATION CAPABILITIES SHALL BE PROVIDED TO ASSURE THAT FOR ONSITE ELECTRICAL POWER SYSTEM OPERATION (ASSUMING OFFSITE POWER IS NOT AVAILABLE) AND FOR OFFSITE ELECTRICAL POWER SYSTEM OPERATION (ASSUMING ONSITE POWER IS NOT AVAILABLE) THE SYSTEM SAFETY FUNCTION CAN BE ACCOMPLISHED, ASSUMING A SINGLE FAILURE, WITH AT LEAST TWO FLOW PATHS REMAINING AVAILABLE FOR RESIDUAL HEAT REMOVAL.*

*THIS REQUIREMENT IS NOT INTENDED TO PRECLUDE TWO-LOOP OPERATION PROVIDED THE SYSTEM SAFETY FUNCTIONS CAN BE APPROPRIATELY MET.

CRITERION 57 - REACTIVITY LIMITS - THE REACTIVITY CONTROL SYSTEMS SHALL BE DESIGNED WITH APPROPRIATE LIMITS ON THE POTENTIAL AMOUNT AND RATE OF REACTIVITY INCREASE TO ASSURE THAT THE EFFECTS OF POSTULATED REACTIVITY ACCIDENTS CAN NEITHER (1) RESULT IN DAMAGE TO THE REACTOR COOLANT BOUNDARY GREATER THAN LIMITED LOCAL YIELDING NOR (2) SUFFICIENTLY DISTURB THE CORE, ITS SUPPORT STRUCTURES OR OTHER REACTOR VESSEL INTERNALS TO IMPAIR SIGNIFICANTLY THE CAPABILITY TO COOL THE CORE. THESE POSTULATED REACTIVITY ACCIDENTS SHALL INCLUDE CONSIDERATION OF EVENTS SUCH AS ROD EJECTION (UNLESS PREVENTED BY POSITIVE MEANS), ROD RUNOUT, STEAMLINERUPTURE, CHANGES IN REACTOR COOLANT TEMPERATURE AND PRESSURE, COLD SODIUM ADDITION.

CRITERION 58 - PROTECTION AGAINST ANTICIPATED OPERATIONAL OCCURRENCES - THE PROTECTION AND REACTIVITY CONTROL SYSTEMS SHALL BE DESIGNED TO ASSURE AN EXTREMELY HIGH PROBABILITY OF ACCOMPLISHING THEIR SAFETY FUNCTIONS IN THE EVENT OF ANTICIPATED OPERATIONAL OCCURRENCES.

CRITERION 59 - FUEL ROD FAILURE PROPAGATION - FEATURES SHALL BE PROVIDED TO LIMIT PROPAGATION OF STOCHASTIC FUEL ROD FAILURES. THESE FEATURES MAY BE INHERENT IN THE DESIGN OF THE FUEL AND BLANKET ASSEMBLIES TO ELIMINATE OR MITIGATE PROPAGATION OR MAY INCLUDE MONITORING SYSTEMS TO DETECT PIN FAILURES IN TIME TO PERMIT APPROPRIATE MEASURES TO BE TAKEN. THE FEATURES PROVIDED SHALL BE SUFFICIENT TO LIMIT PROPAGATION OF EACH FAILURE TO THE ASSEMBLY IN WHICH IT IS LOCATED.

CRITERION 60 - FLOW BLOCKAGE - THE REACTOR INTERNALS AND CORE ASSEMBLIES SHALL BE DESIGNED TO MINIMIZE THE POTENTIAL FOR FLOW BLOCKAGE OR FLOW RESTRICTION TO ONE OR MORE CORE ASSEMBLIES, WHILE IN THE REACTOR CORE, BY LOOSE PARTS OR BY CORE ASSEMBLY LOADING ERRORS SUFFICIENT TO CAUSE FUEL DAMAGE LIMITS TO BE EXCEEDED.

DISPOSITION OF COMMENTS RAISED BY ACRS-CRBR SUBCOMMITTEE

AT 3/30 - 3/31/82 MEETING ON PDCs

- 1) WHY DON'T PDCs DEFINE DESIGN BASIS ACCIDENTS (DBAs)?
 - PDCs DEFINE DESIGN REQUIREMENTS ON SYSTEMS, COMPONENTS, AND STRUCTURES. DBAs ARE USED TO TEST THE CAPABILITY OF THE PLANT SYSTEMS, COMPONENTS, AND STRUCTURES. DEVELOPMENT AND REVIEW OF DBAs IS DISCUSSED IN THE INTRODUCTION TO SER SECTION 3.1.

- 2) WHY DON'T PDCs ADDRESS CDAs AND ENERGETICS?
 - PDCs ADDRESS DESIGN REQUIREMENTS FOR SYSTEMS, COMPONENTS, AND STRUCTURES NECESSARY FOR MITIGATING DBAs AND REDUCING THE LIKELIHOOD OF EVENTS BEYOND THE DESIGN BASIS SUCH THAT THEY CAN BE EXCLUDED FROM THE DESIGN BASIS SPECTRUM. CDAs AND ENERGETICS (INCLUDING CRITERIA) ARE TO BE ADDRESSED IN A SEPARATE APPENDIX TO THE SER.

DISPOSITION OF COMMENTS RAISED BY ACRS-CRBR SUBCOMMITTEE (CONT'D.)

- 3) WHY DON'T PDCs SPECIFY A MARGIN OF SAFETY FOR THE PLANT FOR THE SSE?
 - EVENTS BEYOND THE SSE ARE CONSIDERED AS BEYOND THE DESIGN BASIS. THE MARGIN AVAILABLE AT THE SSE WILL, HOWEVER, BE EVALUATED AND WILL BE THE SUBJECT OF A FUTURE MEETING.

- 4) WHY DON'T PDCs SPECIFY NATURAL CIRCULATION AS A REQUIREMENT?
 - THE CONCERN IS DECAY HEAT REMOVAL AND THE CRITERIA ADDRESS THIS. THE PLANT IS BEING ANALYZED FOR NATURAL CIRCULATION AND IT IS EXPECTED THAT THIS CAPABILITY WILL BE DEMONSTRATED.

- 5) WHY DON'T THE PDCs ADDRESS SABOTAGE?
 - SABOTAGE IS ADDRESSED IN 10 CFR 73.

DISPOSITION OF COMMENTS RAISED BY ACRS-CRBR SUBCOMMITTEE (CONT'D.)

6) WHY DON'T THE PDCs ADDRESS CONTAINMENT RETENTION TIME?

- THEY DO IN A GENERAL SENSE IN PDC #14.

7) WHY DON'T THE PDCs ADDRESS STATION BLACKOUT?

- STATION BLACKOUT IS A SPECIFIC EVENT FOR WHICH THE PLANT WILL BE ANALYZED ALTHOUGH IT IS NOT IN THE DESIGN BASIS CATEGORY. PDCs DO NOT ADDRESS DBAs BUT RATHER DESIGN REQUIREMENTS ON SYSTEMS, COMPONENTS, AND STRUCTURES.

8) ADD DEFINITION OF "POSTULATED ACCIDENTS" AND "FUEL DAMAGE LIMITS."

- DONE.

RESPONSE TO D. OKRENT COMMENTS OF JULY 1, 1982

- 1) CRITERION 2 APPEARS TO BE INADEQUATE IN THAT IT REFERS ONLY TO HISTORIC NATURAL PHENOMENA AS A BASIS FOR JUDGMENT.
 - CRITERION 2 SPECIFIES THAT SUFFICIENT MARGIN SHOULD BE INCLUDED TO ACCOUNT FOR THE UNCERTAINTIES OF THE DATA. THIS ALLOWS A SITE SPECIFIC DETERMINATION.

- 2) CRITERION 5 REFERS TO "POSTULATED ACCIDENTS." IT IS NOT CLEAR WHETHER THIS WILL LIMIT THE ENVIRONMENTAL QUALIFICATION TO DESIGN BASIS ACCIDENTS AND LEAVE IMPORTANT FUNCTIONS VULNERABLE TO OTHER CIRCUMSTANCES.
 - ALL EQUIPMENT, WHETHER REQUIRED FOR DBAs OR FOR EVENTS BEYOND THE DESIGN BASIS WILL BE QUALIFIED TO ITS APPROPRIATE ENVIRONMENT. CRITERION 5 ADDRESSES THIS FOR EQUIPMENT ASSOCIATED WITH DBAs. A SEPARATE APPENDIX TO THE SER WILL ADDRESS THIS FOR EQUIPMENT ASSOCIATED WITH EVENTS BEYOND DBAs.

RESPONSE TO D. OKRENT COMMENTS OF JULY 1, 1982 (CONT'D.)

- 3) CRITERION 7 USES THE TERM "SINGLE FAILURE." WHY IS SINGLE FAILURE OK?
- APPLICATION OF THE SINGLE FAILURE CRITERION IS CONSIDERED ACCEPTABLE IF FAILURE OF THE SYSTEM OR COMPONENT TO WHICH IT IS APPLIED WILL NOT DIRECTLY AFFECT THE ABILITY OF THE PLANT TO SHUTDOWN OR REMOVE DECAY HEAT. TO PROVIDE ADDITIONAL MARGIN IN THE PLANT SHUTDOWN AND DECAY HEAT REMOVAL AREAS REQUIREMENTS FOR DIVERSITY, REDUNDANCY, AND INDEPENDENCE ARE APPLIED SUCH THAT ADDITIONAL FAILURES CAN BE ACCOMMODATED (SEE PDC 20, 24, 35).
- 4) CRITERION 11 DOES NOT GIVE ANY GUIDANCE ON RELIABILITY REQUIREMENTS FOR INSTRUMENTATION AND CONTROL.
- STATEMENTS ON RELIABILITY ARE USED ONLY IN CONJUNCTION WITH SYSTEMS THAT PERFORM AN ACTIVE SAFETY FUNCTION. CRITERION 11 ADDRESSES SYSTEMS THAT MONITOR AND CONTROL BUT DO NOT PROVIDE THE PLANT WITH AUTOMATIC PROTECTION. HOWEVER, RELIABILITY OF THESE SYSTEMS WILL NOT BE IGNORED BUT RATHER WILL BE CONSIDERED FOR INCLUSION IN THE APPLICANT'S RELIABILITY PROGRAM.

RESPONSE TO D. OKRENT COMMENTS OF JULY 1, 1982 (Cont'd.)

5) CRITERION 15 USES THE TERM "SINGLE FAILURE" FOR ONSITE POWER SUPPLIES, WITHOUT JUSTIFICATION IN TERMS OF RELIABILITY OF COMMON CAUSE FAILURES.

- IF COMMON CAUSE FAILURES AFFECTING SAFETY ARE IDENTIFIED, THE DESIGN WILL BE CHANGED TO ELIMINATE THEM. FOR THOSE SYSTEMS ASSOCIATED WITH SHUTTING DOWN THE PLANT AND REMOVING DECAY HEAT, REQUIREMENTS ON DIVERSITY AND INDEPENDENCE HAVE BEEN ADDED TO HELP ELIMINATE THE POSSIBILITY OF ANY UNKNOWN COMMON CAUSE FAILURES FROM VOIDING THE FUNCTION OF THESE SYSTEMS.

6) CRITERION 17 IS OBSCURE AS TO WHETHER IT DEALS WITH A FIRE IN THE CONTROL ROOM.

- CRITERION 17 IS INTENDED TO COVER A FIRE IN THE CONTROL ROOM.

RESPONSE TO D. OKRENT COMMENTS OF JULY 1, 1982 (CONT'D.)

7) CRITERION 22 AGAIN USES THE TERM SINGLE FAILURE WITHOUT CONSIDERATION OF POSSIBLE COMMON CAUSE EVENTS.

- SEE #5 ABOVE.

8) CRITERION 26 AGAIN USES "SINGLE FAILURE."

- SEE #5 ABOVE.

**CLINCH RIVER BREEDER
REACTOR PLANT**



BRIEFING FOR

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
WORKING GROUP**

DESIGN BASIS ACCIDENTS

OCTOBER 27, 1982

BRIEFING ON
CRBRP DESIGN BASIS ACCIDENTS
FOR THE
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS) WORKING GROUP


WASHINGTON, D.C.

OCTOBER 27, 1982

AGENDA

- OVERALL APPROACH G. H. CLARE
- REACTOR ACCIDENTS P. W. DICKSON
- PLANT ACCIDENTS G. H. CLARE

**CRBRP DESIGN
BASIS ACCIDENTS**



BRIEFING FOR

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
WORKING GROUP**

OVERALL APPROACH

PRESENTED BY:

**GEORGE H. CLARE
LICENSING MANAGER, CRBRP PROJECT
WESTINGHOUSE-OR
ADVANCED REACTORS DIVISION**

OCTOBER 27, 1982

**THE PURPOSE OF DESIGN BASIS
ACCIDENTS IS TO PROVIDE "DESIGN
BASES" FOR THE PLANT
SAFETY FEATURES**

- SAFETY FUNCTIONS
- CONTROLLING PARAMETERS

REFERENCE 10 CFR 50.2(U)

DESIGN BASIS ACCIDENTS ARE CONSERVATIVELY DEFINED USING JUDGEMENT TO INTEGRATE THE AVAILABLE INFORMATION

- SODIUM REACTOR PLANT EXPERIENCE
 - DOMESTIC
 - FOREIGN
- SODIUM TEST FACILITY EXPERIENCE
 - DOMESTIC
 - FOREIGN
- LIGHT WATER REACTOR PLANT EXPERIENCE
 - DOMESTIC
- LICENSING REGULATIONS, GUIDELINES AND PRECEDENTS
 - 10 CFR 50
 - REGULATORY GUIDES
 - STANDARD FORMAT AND CONTENT (LMFBR EDITION)
 - STANDARD REVIEW PLAN
 - LWR LICENSING EXPERIENCE
 - FFTF "SAFETY REVIEW"

THERE ARE THREE IMPORTANT ASPECTS OF EACH DESIGN BASIS ACCIDENT

- ACCIDENT INITIATOR
- ADDITIONAL EQUIPMENT FAILURES
- CONSERVATIVE ANALYSIS ASSUMPTIONS

ACCIDENT INITIATORS ARE CHOSEN CONSERVATIVELY BY INTEGRATING AVAILABLE INFORMATION

- SODIUM REACTOR PLANT EXPERIENCE
- SODIUM TEST FACILITY EXPERIENCE
- LIGHT WATER REACTOR PLANT EXPERIENCE
- CRBRP GENERAL CHARACTERISTICS AND DESIGN DETAILS
- LICENSING REGULATIONS, GUIDELINES AND PRECEDENTS

**EXAMPLES: CONTROL ROD WITHDRAWAL, STEAM
GENERATOR LEAK**

ADDITIONAL EQUIPMENT FAILURES ARE SPECIFIED CONSERVATIVELY BY INTEGRATING AVAILABLE INFORMATION

- LICENSING REGULATIONS, GUIDELINES AND PRECEDENTS
 - LOSS OF OFFSITE POWER OR ONSITE POWER
 - SINGLE ACTIVE FAILURE
 - NON-SAFETY RELATED EQUIPMENT FAILS TO FUNCTION
- SPECIAL LMFBR CONSIDERATIONS
 - REACTOR SHUTDOWN SYSTEM
- CRBRP DESIGN DETAILS

**CONSERVATISMS USED IN THE EVALUATION
OF DBA CONSEQUENCES ARE SPECIFIED TO
ENVELOPE UNCERTAINTIES IN DESIGN
PARAMETERS AND ACCIDENT
PHENOMENOLOGY**

EXAMPLE:

- PUMP HEAD
- PRESSURE DROPS
- HEAT TRANSFER CHARACTERISTICS
- SODIUM BURNING CHEMISTRY

T7

SAFETY FUNCTIONS FALL INTO THREE TRADITIONAL CATEGORIES

- REACTOR SHUTDOWN
 - PRIMARY REACTOR SHUTDOWN SYSTEM
 - SECONDARY REACTOR SHUTDOWN SYSTEM
- SHUTDOWN HEAT REMOVAL **RELATED:**
 - MAIN HEAT TRANSPORT LOOPS
 - STEAM GENERATOR AUXILIARY HEAT REMOVAL SYSTEM
 - DIRECT HEAT REMOVAL SERVICE
 - SUPPORTING SYSTEMS
 - CATCH PANS
 - AEROSOL MITIGATION
 - SWR PRESSURE RELIEF
 - SPENT FUEL COOLING
- MITIGATION OF RADIONUCLIDE RELEASES ... **RELATED:**
 - CONTAINMENT INCLUDING ISOLATION SYSTEM
 - CONFINEMENT; RCB AND RSB
 - CELL LINERS
 - CONTROL ROOM HABITABILITY

**CRBRP DESIGN BASIS
ACCIDENTS**

BRIEFING FOR

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
WORKING GROUP**

**CRBRP PSAR
REACTOR ACCIDENTS**

PRESENTED BY:

**DR. PAUL W. DICKSON
TECHNICAL DIRECTOR, CRBRP PROJECT
WESTINGHOUSE-OR
ADVANCED REACTORS DIVISION**

OCTOBER 27, 1982



BOUNDING CORE UNDERCOOLING EVENT INITIATOR

- **LOSS OF OFFSITE POWER**

**BOUNDING CORE UNDERCOOLING EVENT
ADDITIONAL EQUIPMENT
FAILURES ASSUMED**

- ALL THREE DIESEL GENERATORS FAIL TO START
- TWO OUT OF THREE LOGIC TO TRIP EITHER SHUTDOWN SYSTEM
- ONLY ONE SHUTDOWN SYSTEM OPERATES
- ONE ROD IN THAT SYSTEM FAILS TO INSERT

BOUNDING CORE UNDERCOOLING EVENT ASSUMPTIONS

- MINIMUM PUMP HEAD INITIALLY
- MAXIMUM CORE AND SYSTEM PRESSURE DROPS INITIALLY
- PUMPS STOP WITH MAXIMUM ROTOR BACKPRESSURE DROP
- WORST CASE DOPPLER COEFFICIENT INCLUDING UNCERTAINTIES
- MINIMUM CONTROL ROD SHUTDOWN WORTH (ONE STUCK ROD)
- 3σ HOT CHANNEL SPOT FACTORS
- HIGHEST POWER AND TEMPERATURE HOT RODS AT WORST TIME IN LIFE
- WORST END OF UNCERTAINTY RANGE USED FOR PROPERTIES (e.g., FUEL C_p) AND FUEL/CLAD GAP CONDUCTANCE FOR BOTH POWER AND TEMPERATURE CALCULATIONS
- MAXIMUM DECAY HEAT LOADS INCLUDING 3σ UNCERTAINTIES AND TIME IN LIFE EFFECTS
- NO CREDIT TAKEN FOR INTER- AND INTRA-ASSEMBLY FLOW AND HEAT REDISTRIBUTION
- NEGATIVE REACTIVITY FEEDBACKS NEGLECTED (e.g., CORE RADIAL EXPANSION, BOWING, AXIAL EXPANSION OF FUEL AND CLADDING)
- CONSERVATIVE 0.2 SECOND DELAY USED FOR PPS LOGIC, SCRAM BREAKER AND THE CONTROL ROD UNLATCH TIME DELAYS
- ALL ABOVE ASSUMPTIONS ASSUMED TO OCCUR SIMULTANEOUSLY

● ● ● WORST REACTIVITY INSERTION EVENTS

- ROD RUN OUT
- SSE

ROD RUN OUT INITIATOR

- CONTROLLER FAILURE

**ROD RUN OUT
ADDITIONAL EQUIPMENT
FAILURES ASSUMED**

- FAILURE OF HIGH FLUX BLOCKING CIRCUIT
- FAILURE OF FLUX/FLOW MISMATCH BLOCKING CIRCUIT
- FAILURE OF ROD BANK POSITION LIMITER CIRCUIT
- FAILURE OF SINGLE ROD OUT-OF-ALIGNMENT BLOCKING CIRCUIT
- TWO OUT OF THREE LOGIC TO TRIP EITHER SHUTDOWN SYSTEM
- ONLY ONE SHUTDOWN SYSTEM OPERATES
- ONE ROD IN THAT SYSTEM FAILS TO INSERT

ROD RUN OUT

MAJOR ASSUMPTIONS USED IN TRANSIENT HOT ROD ANALYSIS


- ROD BANK OPERATING AT CORE MIDPLANE (HIGHEST DIFFERENTIAL WORTH)
- MAXIMUM ROD WORTH ASSUMED FOR RUN OUT ROD
- CONSERVATIVE PLANT THDV INITIAL CONDITIONS (e.g., 750° REACTOR INLET)
- WORST CASE DOPPLER COEFFICIENT INCLUDING UNCERTAINTIES
- MINIMUM CONTROL ROD SHUTDOWN WORTH (ONE STUCK ROD)
- 3σ HOT CHANNEL SPOT FACTORS
- HIGHEST POWER AND TEMPERATURE HOT RODS AT WORST TIME IN LIFE

ROD RUN OUT
MAJOR ASSUMPTIONS USED IN
TRANSIENT HOT ROD ANALYSIS (CONT.)

- WORST END OF UNCERTAINTY RANGE USED FOR PROPERTIES (e.g., FUEL C_p) AND FUEL/CLAD GAP CONDUCTANCE FOR BOTH POWER AND TEMPERATURE CALCULATIONS
- MAXIMUM DECAY HEAT LOADS INCLUDING 3σ UNCERTAINTIES AND TIME IN LIFE EFFECTS
- NO CREDIT TAKEN FOR INTER- AND INTRA-ASSEMBLY FLOW AND HEAT REDISTRIBUTION
- NEGATIVE REACTIVITY FEEDBACKS NEGLECTED (e.g., CORE RADIAL EXPANSION, BOWING, AXIAL EXPANSION OF FUEL AND CLADDING)
- CONSERVATIVE 0.2 SECOND DELAY USED FOR PPS LOGIC, SCRAM BREAKER AND THE CONTROL ROD UNLATCH TIME DELAYS
- ALL ABOVE ASSUMPTIONS ASSUMED TO OCCUR SIMULTANEOUSLY


SSE REACTIVITY INSERTION

CRBRP CORE SUPPORT STRUCTURE




5-78-PO1380-11-1

CRBRP CONCEPTUAL CORE RESTRAINT DESIGN



CONCEPTUAL DIAGRAM FOR THE LIMITED FREE BOW RADIAL CORE RESTRAINT FOR THE CRBRP



ASSUMPTIONS USED FOR SSE ANALYSES

- POWER LOST TO PUMPS
- STEP REACTIVITY INSERTION DUE TO CORE COMPACTION EFFECTS
- DELAY IN CONTROL SYSTEM SCRAM SPEED DUE TO SEISMIC INDUCED FORCES ON DRIVELINE/GUIDE STRUCTURE

ADDITIONAL EQUIPMENT FAILURES ASSUMED

- TWO OUT OF THREE LOGIC TO TRIP
EITHER SHUTDOWN SYSTEM
- ONLY ONE SHUTDOWN SYSTEM
OPERATES
- ONE ROD IN THAT SYSTEM FAILS TO
INSERT

MAJOR ASSUMPTIONS USED IN TRANSIENT HOT ROD ANALYSIS

- CONSERVATIVE PLANT THDV INITIAL CONDITIONS (e.g., 750° REACTOR INLET)
- WORST CASE DOPPLER COEFFICIENT INCLUDING UNCERTAINTIES
- MINIMUM CONTROL ROD SHUTDOWN WORTH (ONE STUCK ROD)
- 3σ HOT CHANNEL SPOT FACTORS
- HIGHEST POWER AND TEMPERATURE HOT RODS AT WORST TIME IN LIFE
- WORST END OF UNCERTAINTY RANGE USED FOR PROPERTIES (e.g., FUEL C_p) AND FUEL/CLAD GAP CONDUCTANCE FOR BOTH POWER AND TEMPERATURE CALCULATIONS
- MAXIMUM DECAY HEAT LOADS INCLUDING 3σ UNCERTAINTIES AND TIME IN LIFE EFFECTS
- NO CREDIT TAKEN FOR INTER- AND INTRA-ASSEMBLY FLOW AND HEAT REDISTRIBUTION
- NEGATIVE REACTIVITY FEEDBACKS NEGLECTED (e.g., CORE RADIAL EXPANSION, BOWING, AXIAL EXPANSION OF FUEL AND CLADDING)
- CONSERVATIVE 0.2 SECOND DELAY USED FOR PPS LOGIC, SCRAM BREAKER AND THE CONTROL ROD UNLATCH TIME DELAYS
- ALL ABOVE ASSUMPTIONS ASSUMED TO OCCUR SIMULTANEOUSLY

CONCLUSIONS

- PSAR UNDERCOOLING AND OVERPOWER TRANSIENTS HAVE BEEN EVALUATED ON AN EXTREMELY CONSERVATIVE BASIS AND ALL EVENTS MEET THE ACCEPTANCE GUIDELINES OF TABLE 15.1.2-2

**CRBRP DESIGN
BASIS ACCIDENTS**

BRIEFING FOR

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)
WORKING GROUP**

PLANT ACCIDENTS

PRESENTED BY:

**GEORGE H. CLARE
LICENSING MANAGER, CRBRP PROJECT
WESTINGHOUSE-OR
ADVANCED REACTORS DIVISION**

OCTOBER 27, 1982



CONTAINMENT DESIGN BASIS ACCIDENT INITIATOR

- COVERED IN DETAIL ON MAY 24, 1982.
 - SIGNIFICANT RADIOACTIVE INVENTORIES:
REACTOR FUEL, COLD TRAPS, COVER GAS, AND
COOLANT.
 - COOLANT IN AIR-FILLED CELL (MAINTENANCE) IS
THE BOUNDING SOURCE
 - LWR PRACTICE
 - PRIMARY SODIUM STORAGE TANK (PSST) CAN
HOLD THE LARGEST INVENTORY
 - SIGNIFICANT SODIUM FIRES HAVE NOT OCCURRED
- INITIATOR: LEAK IN THE PSST DURING MAINTENANCE**

T8

CONTAINMENT DESIGN BASIS ACCIDENT ADDITIONAL "EQUIPMENT" FAILURES

- VIOLATION OF PROCEDURES REQUIRING LOW INVENTORY PRIOR TO DEINERTING
- VIOLATION OF HEALTH PHYSICS GUIDELINES; LARGE SODIUM VOLUME IS A MAJOR GAMMA SOURCE, ENTRY IN CELL WOULD GIVE HIGH DOSES
- FAILURE TO MANUALLY EXTINGUISH FIRE
- FAILURE OF ONE SET OF CIS RADIATION MONITORS

OR

FAILURE OF ONE TRAIN OF CIS LOGIC OR VALVES

- LWR PRACTICE

- FAILURE OF ONE OF THREE DIVERSE CIS RADIATION MONITORS

- LWR PRACTICE

CONTAINMENT DESIGN BASIS ACCIDENT ANALYSIS CONSERVATISMS

- MAXIMUM SODIUM INVENTORY; INSTANTANEOUS SPILL
- MAXIMUM REACTION ENERGY (100% Na_2O FORMATION)
- 100% OF O_2 IN RCB CONSUMED
- DIRECT GAS EXCHANGE BETWEEN CELL AND RCB ATMOSPHERE - NOT CONSIDERING EQUIPMENT
- END OF LIFE SODIUM CONTAMINATION; CONSTANT 1% FAILED FUEL
- NO PLUGGING OF CONTAINMENT LEAKAGE PATHS
- NO AEROSOL FALLOUT OUTSIDE CONTAINMENT
- 95% METEOROLOGY

SODIUM WATER REACTION (STEAM GENERATOR LEAK) INITIATOR

- COVERED IN DETAIL ON JUNE 25, 1982
- STEAM GENERATOR LEAKS HAVE BEEN POSTULATED IN LWRS
- STEAM GENERATOR LEAKS HAVE OCCURRED
- NO RAPIDLY DEVELOPING SWRs HAVE OCCURRED
- NO GUILLOTINE TUBE FAILURES HAVE OCCURRED
- EXPERIMENTS HAVE DEMONSTRATED SLOW PROPAGATION;
BOUNDING ANALYSIS SHOWS PROPAGATION NO FASTER
THAN ONE SECOND
- FOREIGN LMFBRs ASSUME ONE TO THREE TUBE FAILURES

INITIATOR:

- **PRECURSOR**
- **EQUIVALENT D.E.G. FAILURE**
- **TWO ADDITIONAL D.E.G. FAILURES AT ONE SECOND
INTERVALS**

**SODIUM WATER REACTION
(STEAM GENERATOR LEAK)**

ADDITIONAL "EQUIPMENT" FAILURES

- LEAK DETECTION AND MANUAL TERMINATION DO NOT OCCUR
- PRESSURE RELIEF FAILURE
- PRE-EXISTING "UNDETECTABLE" IHX LEAK (ENVELOPED BY PIPE LEAK EVENT)
- LOSS OF OFFSITE POWER JUST PRIOR TO SWR (ADVERSE CONDITIONS AT INITIATION)

**SODIUM WATER REACTION
(STEAM GENERATOR LEAK)
ANALYSIS CONSERVATISMS**

- PRECURSER FAILS TO BURST RUPTURE ON EXPANSION TANK
- TUBE FAILURES ARE INSTANTANEOUS
- WATER INJECTION PER RELAP4 (BWR PRECEDENT)
- WORST FAILURE LOCATIONS
- CONSERVATIVE RUPTURE DISK MODEL BASED ON TEST DATA
- CONSERVATIVE REACTION MODEL BASED ON TEST DATA
- ENERGY ABSORPTION IN STRUCTURES NEGLECTED

ACRS CRBR SUBCOMMITTEE MEETING
OCTOBER 27, 1982

DBA ACCIDENT ANALYSIS
STATUS AND RATIONALE

RICHARD BECKER
NRC/CRBRPO

ACCIDENT ANALYSIS STATUS

CONSULTANTS

BROOKHAVEN NATIONAL LABORATORY
LOS ALAMOS NATIONAL LABORATORY
IDAHO NATIONAL ENGINEERING LABORATORY

MEETINGS

CHAPTER 15

FEBRUARY 28, 1982

APRIL 5, 1982

CHAPTER 4

CHAPTER 5

CHAPTER 3

CRBR
DESIGN BASIS ACCIDENT
REVIEW

- CATEGORIZATION BY ACCIDENT TYPE
- CATEGORIZATION BY DOSE LIMIT
- CATEGORIZATION BY FREQUENCY
- ADEQUACY OF ENGINEERED SAFETY FEATURES
- COMPLETENESS

CRBR

ACCIDENT COMPLETENESS REVIEW

. DESIGN BASIS ACCIDENT ENVELOPE

. BUFFER ZONE

. BEYOND THE DESIGN BASIS ACCIDENT

REVIEW

COMPLETENESS METHODOLOGIES

- . MECHANISTIC SEQUENCE
- . GENERIC TYPE
- . FAILURE MODES & EFFECTS ANALYSIS (FMEA)
- . FOREIGN EXPERIENCE
- . PRA

MECHANISTIC
ACCIDENT DEFINITION

- . HISTORIC ACCIDENTS
- . COMPONENT FAILURE SCENARIO
- PUMP FAILURES
- FLOW BLOCKAGE
- FEED WATER/VALVE FAILURES

GENERIC
ACCIDENT DEFINITION

- . OVERPOWER
 - REACTIVITY
 - REACTIVITY FLOW INTERACTION
- . UNDERCOOLING
 - FLOW
 - . SYSTEM
 - . LOCAL
- . FIRES
- . FUEL HANDLING & RADIOACTIVE STORAGE
- . MISCELLANEOUS

CATEGORIZATION

NORMAL OPERATION

INCIDENTS OF MODERATE FREQUENCY

INFREQUENT INCIDENTS

LIMITING FAULTS

ANTICIPATED FAULT

UNLIKELY FAULT

EXTREMELY UNLIKELY FAULT

DESIGN BASIS ANALYSIS

SINGLE FAILURE CRITERION

CONSERVATIVE ANALYSIS

UNCERTAINTIES

MOST CONSERVATIVE CONDITION

INSTRUMENT UNCERTAINTIES, ERROR & RESPONSE

DESIGN BASIS EVENTS
ACCEPTANCE CRITERIA

<u>EVENT</u> <u>CLASSIFICATION</u>	<u>FUEL</u> <u>TEMPERATURE</u>	<u>CLADDING</u> <u>TEMPERATURE (°F)</u>	<u>COOLANT</u> <u>TEMPERATURE (°F)</u>	<u>DOSE</u> <u>GUIDELINES</u>
ANTICIPATED FAULT	SOLIDUS	1500	---	10 CFR 20
UNLIKELY FAULT	SOLIDUS	1600	---	10 CFR 20
EXTREMELY UNLIKELY FAULT	---	2475 (SOLIDUS)	SATURATION	1/10 of 10 CFR 100