NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	LICENSEE CODE (2)	G A E I H 2
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1
	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 3 6 6
	EVENT DATE (8)	0 9 1 8 8 1
	REPORT DATE (9)	1 0 1 4 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On 9-18-82; personnel were selecting rods to increase power from 875 MWt
03 on Unit 2. During this, the rod out permissive light went out; however,
04 ROD Block alarms were not received. Rod Block Monitor "B" was subsequent-
05 ly determined to be inoperable; Rod Block Monitor "A" remained operable.
06 The unit was placed in a 24 hour LCO in accordance with Tech. Specs.
07 3.1.4.3 Action a. The health and safety of the public were not affected
08 by this non-repetitive event.

Line	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
09	IE	E	A	INSTRU	X	Z

LER/RO REPORT NUMBER (17)	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	82	—	105	/	03	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
A	Z	Z	Z	0000	N	N	N	G080

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The problem with "B" RBM was found to be a blown power fuse. The fuse
11 was replaced. Voltages to the RBM were checked and no problems were
12 found. Proper operation was verified by selecting rods and observing
13 correct control board light indications. The LCO was cleared within the
14 required time limit.

Line	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
15	F	036	NA	A	Operator Observation

Line	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
17	000	Z	NA

PERSONNEL INJURIES

Line	NUMBER (40)	DESCRIPTION (41)
18	000	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	TYPE (42)	DESCRIPTION
19	Z	NA

PUBLICITY

Line	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
20	N		

8210290209 821014
PDR ADOCK 05000366
S PDR

NAME OF PREPARER S. B. Tipps PHONE: (912) 367-7851