

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N 5 | S | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 5  
7 8 | 9 | 14 | 15 | 25 | 26 | 57 | 58  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T  
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 7 | 2 | 7 | 0 | 3 | 2 | 6 | 8 | 2 | 8 | 0 | 4 | 1 | 3 | 8 | 2 | 9  
7 8 | 60 | 61 | 68 | 69 | 74 | 75 | 80  
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
0 2 | A gaseous release from the Waste Gas System was initiated at 2250 hours,  
0 3 | March 26, 1982. The Control Room Operator failed to align the Containment/Plant  
0 4 | Vent Monitors 1R11A, 1R12A and 1R12B to the plant vent as required by Operating  
0 5 | Instruction O.I.II-12.3.3.  
0 6 |  
0 7 |  
0 8 |

0 9 | SYSTEM CODE | M | B | 11 | CAUSE CODE | A | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | E | 15 | VALVE SUBCODE | Z | 16 |  
7 8 | 9 | 10 | 11 | 12 | 13 | 18 | 19 | 20 |  
17 | LER RO REPORT NUMBER | 8 | 2 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 1 | 6 | 24 | 26 | OCCURRENCE CODE | / | 27 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 |  
ACTION TAKEN | H | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | Y | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | T | 3 | 0 | 0 | 26 |  
33 | 34 | 35 | 36 | 37 | 40 | 41 | 42 | 43 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
1 0 | The failure of the operator to properly perform the operating instruction resulted  
1 1 | in the incorrect vent monitor alignment. LCO 2.3.4.c was met at 0048 hours,  
1 2 | March 27, 1982, with the termination of the gaseous release. ETS release rate limits  
1 3 | were not exceeded, and there was no adverse impact on the environment. The operator  
1 4 | involved was counseled by the Senior Shift Supervisor concerning LCO 2.3.4.c and  
7 8 9 the importance of adherence to approved procedures. 80

1 5 | FACILITY STATUS | G | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32  
7 8 9 | 10 | 12 | 13 | 44 | 45 | 46 | 80

1 6 | ACTIVITY CONTENT | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36  
7 8 9 | 10 | 11 | 44 | 45 | 80

1 7 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | Z | 38 | DESCRIPTION | N/A | 39  
7 8 9 | 11 | 12 | 13 | 80

1 8 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41  
7 8 9 | 11 | 12 | 80

1 9 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | DESCRIPTION | N/A | 43 | 8210290218 821006  
7 8 9 | 10 | 11 | 12 | 80 PDR ADOCK 05000272 S PDR

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | N/A | 45 | NRC USE ONLY  
7 8 9 | 10 | 68 | 69 | 80

NAME OF PREPARER R. Frahm PHONE 609/935-6000 Fxt 3078