

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1750 Chestnut Street Tower II

October 14, 1982

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

82 OCT 18 AID: 11

USNRC REGION II  
ATLANTA, GEORGIA


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET  
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-296/82037 - REVISION 1

The enclosed report is a supplement to my letter to you dated September 7, 1982 concerning the calibration valve for the suppression chamber high-level switches being found open during routine surveillance testing. This report is submitted in accordance with Browns Ferry unit 3 Technical Specification 6.7.2.a(6).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

RECEIVED

1022

8210290231 821014  
PDR ADOCK 05000296  
S PDR