(7.77)	LICENSEE EVENT REPORT
	CONTRO! BLOCK:
	$ \begin{array}{ c c c c c } \hline N & C & B & E & P & 2 \\ \hline 9 & \text{LICENSEE CODE} & 14 \\ \hline 15 & \text{LICENSE NUMBER} \\ \hline 15 & \text{LICENSE NUMBER} \\ \hline 25 & 26 \\ \hline 26 & \text{LICENSE TYPE} \\ \hline 30 & 57 \\ \hline 26 & \text{LICENSE TYPE} \\ \hline 30 & 57 \\ \hline 57 $
CON'T	REPORT LG 0 5 0 - 0 3 2 4 0 0 9 2 9 8 2 8 1 0 2 1 8 2 9 SOURCE 60 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80 9
0 2	While performing the calibration and functional test of CAC suppression pool/drywell
03	[temperature monitoring instrumentation, PT-56.3PC, it was discovered that suppression]
04	chamber water temperature recorder 2-CAC-TR-778, located on the remote shutdown panel,
0 5	was showing expected indications of temperatures, but was intermittently recording
06	them on the chart recorder. Similar reportable events involving this instrument have
0 7	occurred before, the most recent reported in LER 1-82-58. This event did not affect
08	the health and safety of the public. T.S. 3.3.5.2, 6.9.1.9b
09 78	SYSTEM CODE C
	$\begin{array}{c c c c c c c c c c c c c c c c c c c $
10	The observed intermittent temperature recording occurred because the recorder print
11	actuation solenoid was out of adjustment. The solenoid was adjusted for proper
12	operation and the recorder, Model No. 551, was returned to service. Plant Engineering
1 3	is evaluating other recorders to replace the presently utilized recorder for this
14 7 8	particular application on both units.
1 5	FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DISCOVERY DESCRIPTION (32) 9 10 0
	ACTIVITY CONTENT DELEASE OF RELEASE AMOUNT OF ACTIVITY 35 UCATION OF RELEASE 36 LOCATION OF RELEASE 36 NA 44 PERSONNEL EXPOSURES 44 80
17	NUMBER TYPE DESCRIPTION (39) 0 0 0 (37) Z (38) NA
7 8	9 PERSONNEL INJURIES NUMBER DESCRIPTION (1) 80
1 8 7 8	↓ 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
19	LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION (43) 9 10 NA 80
20	PUBLICITY ISSUED DESCRIPTION 45 B210290246 B21021 S PDR ADOCK 05000324 PDR DR B210290246 B21021 NRC USE ONLY 68 69 80 5
	NAME OF PREPARER M. J. Pastva, Jr. PHONE 919-457-9521