



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 25, 1982

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

USNRC REGION II
ATLANTA, GEORGIA
82 OCT 26 A 9: 44

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Low Pressure Core Spray System
Failure Due to Valve
Operator Motor Failure
Reference: LER 82-089/03 L-0
AECM-82/505

On September 25, 1982, the Low Pressure Core Spray System failed Surveillance Test 06-OP-1E21-M-0001 due to the failure of the LPCS minimum flow valve (E21-F011). This event is being reported pursuant to T.S.3.5.1. Attached is LER 82-089/03 L-0.

Yours truly,

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8210290311 821025
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22