## MCGUIRE NUCLEAR STATION

## MONTHLY OPERATING STATUS REPORT

## October 1990

1. Personnel Exposure -

For the month of October, 1 individual(s) exceeded 10 percent of their allowable annual radiation dose limit

 The total station liquid release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gasecus release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

9012190160 901214 PDR ADOCK 05000369 R PDR

## UNIT SHUTDOWNS AND POWER REDUCTIONS DOCKET NO. 50-369

N O	DATE	(1) T Y P E	DURATION HOURS	(2) REASON	(3) MET- HOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
14	90-10-13	F	34.07	A	3		IA	INSTRU	REACTOR TRIP DUE TO SOLID STATE PROTECTION SYSTEM SWITCH FAILURE DURING SYSTEM TEST
53-P	90-10-14	S		В			IE	INSTRU	HOLDING LOAD INCREASE FOR NUCLEAR INSTRUMENTATION CALIBRATION
54-P	90-10-14	F	1. A.	В			HG	ZZZZZZ	HOLD FOR FEEDWATER CHEMISTRY
55-P	90-10-15	S		В			IE	INSTRU	HOLDING LOAD INCREASE FOR NUCLEAR INSTRUMENTATION CALIBRATION
56-P	90-10-15	F		A			HA	TURBIN	DECREASING LOAD TO TAKE UNIT OFFLINE DUE TO LOW PRESSURE TURBINE VIBRATION
15	90-10-15	F	385.17	A	1		HA	TURBIN	UNIT SHUTDOWN DUE TO HIGH VIBRATION ON LOW PRESSURE TURBINE
L) F For S Sch	eduled A B C D E F G	-Reft -Regt -Oper -Admi -Oper	n: ipment Fail ntenance or ueling ulatory Res rator Train inistrative rator Error er (Explain	tric ing (Ex	tion & Lice	ense Exami	natio	3-Automa	(4) Exhibit G - Instruction for Preparation of Data Entry Sheets For Licens Event Report (LER) File (NUREG-0161) (5) Exhibit I - Same Source