



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 13, 1990

Docket
File

Docket No. 50-219

Mr. E. E. Fitzpatrick
Vice President and Director
Oyster Creek Nuclear Generating Station
P.O. Box 388
Forked River, New Jersey 08731

Dear Mr. Fitzpatrick:

SUBJECT: GPU NUCLEAR CORPORATION PROPOSAL TO REPLACE INTERNAL DYE
PENETRANT EXAMINATION OF THE FEEDWATER NOZZLES AND CONTROL
ROD DRIVE RETURN NOZZLE WITH EXTERNAL ULTRASONIC
EXAMINATIONS FOR OYSTER CREEK NUCLEAR GENERATING STATION
(TAC NO. 75845)

The NRC staff has completed its review of GPU Nuclear Corporation's (licensee/
GPUN) submittals dated January 18, 1990 and July 12, 1990. The licensee's
submittals proposed during 13R refueling outage to replace internal dye
penetrant (PT) examination of the Feedwater (FW) Nozzles, and Control Rod Drive
Return (CRDR) Nozzle with external ultrasonic (UT) examinations for Oyster
Creek Nuclear Generating Station (OCGNS). Additional information was provided
during a review meeting on September 19, 1990, between the staff, and its
contractor, Battelle, Pacific Northwest Laboratories, licensee, and Universal
Testing Laboratories (UTL) (licensee's contractor) on the operation of the
equipment to be used for the UT examination of the subject nozzles.

Based on the information and instruction provided by the licensee and licensee's
contractor the staff finds the proposed FW and CRDR nozzle inspection acceptable
for the 13R refueling outage provided:

1. Any surface indication detected by the phased array system and not proven
to be geometric in nature will require that a liquid penetrant examination
be performed that meets the requirements of Section XI.
2. The phased array system should demonstrate the capability to detect
thermal fatigue cracks that are 0.172 inch in depth. The demonstration
need not be a blind demonstration, as an example if data is available
from other test (such as PISC II or past inservice inspection
examinations) could be used to illustrate crack detection capability.

170011

9012190167 901213
PDR ADOCK 05000219
P PDR

DF01
DF03

The staff's conclusions and recommendations are presented in the enclosed Safety Evaluation and NRC contractor's report on its review of the UTL Phased-Array UT inspection system.

Attached is a SALP related to the task. This action completes work to be performed by the Materials and Chemical Engineering Branch under TAC No. 75845.

Sincerely,

151

Alexander W. Dromerick, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - 1/11
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc w/enclosures:
See next page

Distribution:

- Docket File
- NRC & Local PDRs
- PD I-4 File
- SVarga
- EGreenman
- SNorris
- ADromerick
- OGC
- EJordan
- TMcLellan
- ACRS (10)
- CWHehl

OFC	:PDI-4:LA	:PDI-4:PI	:PDI-4:D	:	:
NAME	:SNorris	:ADromerick:cn	:JFStolz	:	:
DATE	: 12/13/90	: 12/13/90	: 12/13/90	:	:

Mr. E. E. Fitzpatrick
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear
Generating Station

cc:

Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

I. H. Jolles, Executive Vice President
GPU Service Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Kent Tosch, Chief
New Jersey Department of Environmental
Protection
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625

BWR Licensing Manager
GPU Nuclear Corporation
1 Upper Pond Road
Parsippany, New Jersey 07054

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Licensing Manager
Oyster Creek Nuclear Generating Station
Mail Stop: Site Emergency Bldg.
P. O. Box 388
Forked River, New Jersey 08731