

DEC 12 1990

Docket No. 50-285

Mr. W. Gary Gates
Division Manager - Nuclear Operations
Omaha Public Power District
444 South 16th Street Mall
Mail Stop 8E, EP4
Omaha, Nebraska 68102-2247

Dear Mr. Gates:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 136 TO FACILITY
OPERATING LICENSE NO. DPR-40 (TAC NO. 77089)

The Commission has issued the enclosed Amendment No. 136 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated June 28, 1990, as supplemented August 2 and November 15, 1990.

The amendment makes changes to the Fort Calhoun Technical Specifications to restrict the containment spray system use as a backup for shutdown cooling.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

(S)

Wayne C. Walker, Project Manager
Project Directorate IV-1
Division of Reactor Projects III, IV, and V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 136 to DPR-40
2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

<u>Docket File</u>	NRC/Local PDR	PD4-1 Reading	W. Walker(2)
M. Virgilio	T. Quay	L. Berry	ACRS(10) (MSP315)
OGC(MS15B18)	D. Hagan(MS3206)	G. Hill(4)	
Wanda Jones(MS7103)	J. Calvo(MS11F22)	PD4-1 Plant File	
GPA/PA(MS2G5)	ARM/LFMB(MS4503)	L. Constable,RIV	

OFC	: PD4-1/LA	: PD4-1/PM	: OGC <i>S. Utter</i>	: PD4-1/D	:	:	:
NAME	: L. Berry <i>LB</i>	: W. Walker <i>W. Walker</i>	: S. Utter <i>S. Utter</i>	: T. Quay <i>T. Quay</i>	:	:	:
DATE	: 12/6/90	: 12/6/90	: 12/7/90	: 12/11/90	:	:	:

OFFICIAL RECORD COPY

Document Name: FC AMEND/77089

170021

9012190174 901212
PDR ADOCK 05000285
P PDR

DFD1
12/13



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

December 12, 1990

Docket No. 50-285

Mr. W. Gary Gates
Division Manager - Nuclear Operations
Omaha Public Power District
444 South 16th Street Mall
Mail Stop 8E/EP4
Omaha, Nebraska 68102-2247

Dear Mr. Gates:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 136 TO FACILITY
OPERATING LICENSE NO. DPR-40 (TAC NO. 77089)

The Commission has issued the enclosed Amendment No. 136 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated June 28, 1990, as supplemented August 2 and November 15, 1990.

The amendment makes changes to the Fort Calhoun Technical Specifications to restrict the containment spray system use as a backup for shutdown cooling.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Wayne C Walker

Wayne C. Walker, Project Manager
Project Directorate IV-1
Division of Reactor Projects III, IV, and V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 136 to DPR-40
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. W. Gary Gates
Omaha Public Power District

Fort Calhoun Station, Unit No. 1

cc:

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW
Washington, D.C. 20036

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68008

Mr. Raymond P. Mullikin, Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Harold Borchert, Director
Division of Radiological Health
Nebraska Department of Health
301 Centennial Mall, South
Post Office Box 95007
Lincoln, Nebraska 68509

Mr. T. L. Patterson, Manager
Fort Calhoun Station
Post Office Box 399
Fort Calhoun, Nebraska 68023