



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 25, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Five Penetration Room Fire  
Door Alarms Inoperable  
(Special Report)  
Reference: LER 82-090/99 X-0  
AECM-82/503

82 OCT 26 A 9 43  
USNRC REGION II  
ATLANTA, GEORGIA

During shutdown, while performing Surveillance Procedure  
06-OP-SP64-M-0043 (Fire Door Alarm Checks), five Penetration Room Fire Door  
Alarms were found inoperable. An LCO was entered in accordance with  
T.S.3.7.7. Attached is LER 82-090/99 X-0.

Yours truly,

JPM:sap  
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8210290348 821025  
PDR ADOCK 05000416  
S PDR

OFFICIAL COPY

IE 22