



**Entergy
Operations**

Entergy Operations, Inc.

217 Bienville St.
New Orleans, LA 70112
Tel: 504-585-2805
Tel: 504-739-6774

Raymond F. Burski

Manager
Safety & Regulatory Affairs

W3P90-1559

A4.05

QA

December 14, 1990

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
NRC Inspection Report 90-16
Additional Information

Gentlemen:

By letter dated October 18, 1990 (W3P90-1514) Waterford 3 submitted corrective action for deviations identified in NRC Inspection Report 90-16. In response to NRC questions concerning W3P90-1514, Waterford 3 and the NRC conducted a telephone conversation November 13, 1990 to discuss the response to those questions. This letter serves to document the results of that conversation and the action that was agreed to during the discussion.

In addition to the corrective action stated in W3P90-1514, the following interim corrective action will also be implemented:

- Temporary labeling of RG 1.97 instruments on the Control Panels will be completed by January 15, 1991 with the exception of recorders for Condensate Storage Pool Level, Pressurizer Level, Reactor Coolant System Hot and Cold Leg Temperatures and Steam Generator Wide Range Level. The evaluation of the 1983 submittal for RG 1.97 Instrumentation, which is expected to be completed by December 31, 1990, indicates that Design Changes will be required to bring these recorders into compliance with RG 1.97 requirements. Upon completion of the design changes, the above recorders will be appropriately labeled.
- Licensed shift operators will be given on-shift training with regard to the temporary labeling. The shift training will be completed by February 28, 1991.


9012190203 901214
PDR ADOCK 05000382
PDR

*TR01
1/0*

W3P90-1559
NRC Inspection Report 90-16
Additional Information
December 14, 1990
Page 2

If you have any questions concerning these responses, please contact
L.W. Laughlin at (504) 739-6331.

Very truly yours,



RFB/BGM/emb

cc: Messrs. R.D. Martin, NRC Region IV
D.L. Wigginton, NRC-NRR
E.L. Blake
R.B. McGehee
NRC Resident Inspectors Office