

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-338VIRGINIA ELECTRIC AND POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE


The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 42 to Facility Operating License No. NPF-4 issued to the Virginia Electric and Power Company (the licensee) for operation of the North Anna Power Station, Unit No. 1 (the facility) located in Louisa County, Virginia. The amendment is effective as of its date of issuance.

The amendment revises the NA-1 Technical Specifications by increasing the average reactor coolant system temperature from 580.3°F to 582.8°F. The 2.5°F increase is enveloped within the already approved and docketed FSAR accident and transient analyses for the currently licensed thermal power level of 2785 Megawatts.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.

DESIGNATED ORIGINAL

Certified By




- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated June 8, 1982; (2) Amendment No. 42 to Facility Operating License No. NPF-4; and (3) the Commission's related Safety Evaluation. These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Board of Supervisors Office, Louisa County Courthouse, Louisa, Virginia 23093 and at the Alderman Library, Manuscripts Department, University of Virginia, Charlottesville, Virginia 22901. A copy of items (2) and (3) may be obtained upon request to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland this 4th day of October, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing