

October 25, 1982

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-82-41

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by NRC staff on this date.

FACILITY: Omaha Public Power District
Fort Calhoun Station
Docket: 50-285

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: LEAKING STEAM GENERATOR HANDHOLE

The licensee performed a shutdown and cooldown on Friday, October 22, 1982, to perform repairs to a leaking secondary side handhole on steam generator A. Other minor repairs are being performed during this outage, and the licensee expects to return to service by Wednesday evening, October 27, 1982.

No press releases are planned by the licensee or RIV.

NRC Region IV (Dallas) was informed of this situation by the licensee at 2 p.m. on October 25, 1982

CONTACT: W. D. Johnson, 728-8155

DISTRIBUTION:

H. ST. 2:30p MNBB 2:24p Phillips 2:22p E/W 2:16p Willste 2:18p MAIL:
Chmn Palladino EDO NRR IE NMSS DOT: Trans Only
Comm. Gilinsky PA OIA RES
Comm. Ahearne MPA AEOD
Comm. Roberts ELD
Comm. Asselstine
SECY Air Rights INPO } *mailed*
ACRS SP NSAC NSAC
CA
PDR Regions: *mailed*

Licensee: _____
(Reactor Licensees)

RPB-C *[initials]* RPB2 *[initials]* DRRP&EP *[initials]* PAO *[initials]* RA-RIV *[initials]*
WJohnson:gb WCSeidle JEGagliardo CEWisner JTCollins
10/25/82 10/25/82 10/25/82 10/25/82 10/25/82

1E34