



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 163  
License No. DPR-59


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Power Authority of the State of New York (the licensee) dated March 9, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 163, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate 1-1  
Division of Reactor Projects - 1/11  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: July 30, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 163

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Page

217

Insert Page

217

JAFNPP

3.9 (cont'd)

3. From and after the time that one of the Emergency Diesel Generator Systems is made or found to be inoperable, continued reactor operation is permissible for a period not to exceed 7 days provided that the two incoming power sources are available and that the remaining Diesel Generator System is operable. At the end of the 7-day period, the reactor shall be placed in a cold condition within 24 hours, unless the affected diesel generator system is made operable sooner.
4. When both Emergency Diesel Generator Systems are made or found to be inoperable, a reactor shutdown shall be initiated within two hours and the reactor placed in a cold condition within 24 hours after initiation of shutdown.

4.9 (cont'd)

3. The emergency diesel generator system instrumentation shall be checked during the monthly generator test.
4. Once each operating cycle, the conditions under which the Emergency Diesel Generator System is required will be simulated to demonstrate that the pair of diesel generators will start, accelerate, force parallel, and accept the emergency loads in the prescribed sequence.
5. Once within one hour and at least once per twenty-four hours thereafter while the reactor is being operated in accordance with Specifications 3.9.B.1, 3.9.B.2, or 3.9.B.3 the availability of the operable Emergency Diesel Generators shall be demonstrated by manual starting and force paralleling where applicable.