



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TL LULL

TENNESSEE VALLEY AUTHORITY  
DOCKET NO. 50-328  
SEQUOYAH NUCLEAR PLANT, UNIT 2  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 136  
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 21, 1990, as supplemented by the letter dated November 13, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 136, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Heddon, Director  
Project Directorate 11-4  
Division of Reactor Projects - 1/11  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 10, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 136

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3/4 6-19  
3/4 6-20

INSERT

3/4 6-19  
3/4 6-20

TABLE 3.6-2

CONTAINMENT ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
A. PHASE "A" ISOLATION		
1. FCV-1-7	SG Blow Dn	10*
2. FCV-1-14	SG Blow Dn	10*
3. FCV-1-25	SG Blow Dn	10*
4. FCV-1-32	SG Blow Dn	10*
5. FCV-1-181	SG Blow Dn	15*
6. FCV-1-182	SG Blow Dn	15*
7. FCV-1-183	SG Blow Dn	15*
8. FCV-1-184	SG Blow Dn	15*
9. FCV-26-240	Fire Protection Isol.	20
10. FCV-26-243	Fire Protection Isol.	20
11. FCV-30-134	Cntmt Bldg Press Trans Sense Line	4*
12. FCV-30-135	Cntmt Bldg Press Trans Sense Line	4*
13. FCV-31C-222	CW-Inst Room Clrs	10*
14. FCV-31C-223	CW-Inst Room Clrs	10*
15. FCV-31C-224	CW-Inst Room Clrs	10*
16. FCV-31C-225	CW-Inst Room Clrs	10*
17. FCV-31C-229	CW-Inst Room Clrs	10*
18. FCV-31C-230	CW-Inst Room Clrs	10*
19. FCV-31C-231	CW-Inst Room Clrs	10*
20. FCV-31C-232	CW-Inst Room Clrs	10*
21. FSV-43-2	Sample Przr Steam Space	10*
22. FCV-43-3	Sample Przr Steam Space	10*
23. FSV-43-11	Sample Przr Liquid	10*
24. FCV-43-12	Sample Przr Liquid	10*
25. FSV-43-22	Sample RC Outlet Hdrs	10*
26. FCV-43-23	Sample RC Outlet Hdrs	10*
27. FSV-43-34	Accum Sample	5*
28. FCV-43-35	Accum Sample	5*
29. FSV-43-55	SG Blow Dn Sample Line	10*
30. FSV-43-58	SG Blow Dn Sample Line	10*

TABLE 3.6-2 (Continued)

CONTAINMENT ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
A. PHASE "A" ISOLATION		
31. FSV-43-61	SG Blow Dn Sample Line	10*
32. FSV-43-64	SG Blow Dn Sample Line	10*
33. FSV-43-75	Boron Analyzer	5*
34. FCV-43-77	Coron Analyzer	5*
35. FCV-61-96	Gylcol Inlet to Floor Cooler	30*
36. FCV-61-97	Gylcol Inlet to Floor Cooler	30*
37. FCV-61-110	Gylcol Outlet to Floor Cooler	30*
38. FCV-61-122	Gylcol Outlet to Floor Cooler	30*
39. FCV-61-191	Ice Condenser - Gylcol In	30*
40. FCV-61-192	Ice Condenser - Gylcol In	30*
41. FCV-61-193	Ice Condenser - Gylcol Out	30*
42. FCV-61-194	Ice Condenser - Gylcol Out	30*
43. FCV-62-61	RCP Seals	10
44. FCV-62-63	RCP Seals	10
45. FCV-62-72	Letdown Line	10*#
46. FCV-62-73	Letdown Line	10*#
47. FCV-62-74	Letdown Line	10*#
48. FCV-62-77	Letdown Line	20
49. FCV-63-23	Accum to Hold Up Tank	10*
50. FCV-63-64	WDS N <sub>2</sub> to Accum	10*
51. FCV-63-71	Accum to Hold Up Tank	10*
52. FCV-63-84	Accum to Hold Up Tank	10*
53. FCV-68-305	WDS N <sub>2</sub> to PRT	10*
54. FCV-68-307	PRT to Gas Analyzer	10*
55. FCV-68-308	PRT to Gas Analyzer	10*
56. FCV-70-85	CCS from Excess Lt Dn Hx	10*
57. FCV-70-143	CCS to Excess Lt Dn Hx	60*
58. FCV-77-9	RCDT Pump Disch	10*
59. FCV-77-10	RCDT Pump Disch	10*
60. FCV-77-18	RCDT and PRT to V H	10*