Corrected Page for
October 1990 Report

9012200150 901214
PDR ADOCK 05000338
R PDR

OPERATING DATA REPORT

DOCKET NO.: 50-339
DATE: November 4, 90
COMPLETED BY: T. Phillips
PHONE: (703) 894-2774

OPERATING STATUS

1. Unit Name:.....North Anna 2
2. Reporting Period:.....October 1990
3. Licensed Thermal Power (MWt):..... 2893
4. Nameplate Rating (Gross MWe):..... 947
5. Design Electrical Rating (Net MWe):..... 907
6. Maximum Dependable Capacity (Gross MWe):.. 957
7. Maximum Dependable Capacity (Net MWe):.... 909

8. If changes occur in Capacity Ratings (Items No. 3 thru 7) since last report, give reasons: N/A

9. Power level to which restricted, if any (Net MWe): N/A
10. Reasons for restrictions, if any: N/A

	This Month	Y-t-D	Cumulative
11. Hours in Reporting Period.....	745.0	7,296.0	86,616.0
12. Number of Hours Reactor was Critical.....	0.0	5,570.3	69,692.4
13. Reactor Reserve Shutdown Hours.....	43.0	79.9	5,934.8
14. Hours Generator On-Line.....	0.0	5,570.2	68,822.1
15. Unit Reserve Shutdown Hours.....	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH).....	0.0	15,267,117.4	183,413,464.4
17. Gross Electrical Energy Generated (MWH).....	0.0	5,027,524.0	60,033,041.0
18. Net Electrical Energy Generated (MWH).....	0.0	4,769,708.0	57,608,540.0
19. Unit Service Factor.....	0.0%	76.3%	79.5%
20. Unit Availability Factor.....	0.0%	76.3%	79.5%
21. Unit Capacity Factor (using MDC Net).....	0.0%	71.8%	74.0%
22. Unit Capacity Factor (using DER Net).....	0.0%	72.1%	73.3%
23. Forced Outage Rate.....	0.0%	0.4%	6.5%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
*75 day Refueling/10 year ISI Outage started 8/22/90

25. If Shutdown at end of Report Period, estimated time of Startup: 11/5/90
26. Units in Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		