

December 12, 1990

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-RII-90-77

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Crystal River 3
Docket No. 50-302

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 X Not Applicable

SUBJECT: SHUTDOWN LONGER THAN 48 HOURS

Crystal River 3 began a planned eight-day maintenance outage this morning. The licensee took the unit off line at 3:21 a.m. and commenced a shutdown to Mode 5. The purpose of the outage is to replace a leaking reactor coolant system safety valve and to repair packing leaks on a pressurizer spray line isolation valve and a spray control valve. RCS leakage was well within TS limits.

The NRC received initial notification of this event from the licensee to the Senior Resident Inspector at approximately 3:00 p.m. (EST) on December 11, 1990.

This information is current as of 9:00 a.m. on December 12, 1990.

CONTACT: - R. Schin at 841-5561

DISTRIBUTION:

One White	M'land Nat'l	Regions	MAIL TO:	DCS (Original IE 34)
Flint North	Bank Bldg	Region I		DOT (Transportation Only)
Chairman Carr	IRM	Region II	FAX TO:	INPO 1125
Comm. Rogers	OIG	Region III		LICENSEE (Corporate) 1126
Comm. Curtiss	AEOD	Region IV		RII Resident 1127
Comm. Remick	NRC Ops Ctr	Region V		
OGC				
OCA				
GPA/SLITP/PA	Nicholson Lane	Phillips Bldg		
EDO	RES	ACRS		
NRR				
NMSS	L Street	EWV		
OE	PDR	ASLAP		

5520: 12/12/90 @ 10:50 a.m. TO REGIONS AND HQ *****

9012210032 901212
PDR 1&E
PNO-11-90-077 PDR

011
IC-34