LICENSEE EVENT REPORT

	LICENSEE EVENT REPORT
	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	N Y R E G 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T 0 1 7 8	REPORT LG 0 5 0 0 0 2 4 4 7 0 9 2 3 8 2 8 1 0 2 3 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 During performance of Periodic Test PT-3, Containment Spray Pumps and NaOH
0 3	Additive System, check valve 862B failed to promptly close. This valve was
0 4	declared inoperable which is a Limiting Condition for Operation based on
0 5	Tech. Spec. 3.3.2.2.c.
0 6	
0 7	
0 8	9 80
0 9 7 8	SYSTEM CODE CODE SUBCODE SUBCO
110	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The vendor for this valve, Alloyco, was called to the site to assist in the
11	repair of this valve. Repairs consisted of machining the seat and disc
1 2	assembly of this valve to assure proper closure. Subsequent testing following
1 3	repairs indicated acceptable performance and the valve was returned to operable
1 4	status.
7 8	ACRES CONTRACTOR CONTR
1 6	PERSONNEL EXPOSURES
1 7	PERSONNEL INJURIES (1)
1 8	0 0 0 40 NA
1 9	Z 42 NA
2 0	PUBLICITY 8211010241 821022 NRC USE ONLY SSUED DESCRIPTION (45) PDR ADDICK 05000244 PDR S PDR
	NAME OF PREPARER James C. Bodine PHONE: 315-524-4446 Ext. 241