

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 N Y I P S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

REPORT SOURCE L 6 0 5 0 0 0 2 4 7 7 0 9 1 5 8 2 8 1 0 1 4 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 During normal operation, Reactor Containment Fan Cooler Unit #22 was removed from

3 service. Leakage from a previously reported service water leak had increased

4 resulting in an additional burden on the liquid waste disposal system. The

5 redundant fan cooler units were available and two Containment Spray Pumps

6 were verified as operable in accordance with Tech. Spec. 3.3.B.2.a. There were

7 no safety implications and the health and safety of the public were unaffected.

8 Similar Events: LER 82-33, LER 82-37.

7 SYSTEM CODE S B 11 CAUSE CODE E 12 CAUSE SUBCODE D 13 COMPONENT CODE H T E X C H 14 COMP. SUBCODE C 15 VALVE SUBCODE Z 16

17 LER NO REPORT NUMBER 8 2 21 22 SEQUENTIAL REPORT NO. 0 4 0 23 24 25 26 OCCURRENCE CODE 0 3 27 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32

ACTION TAKEN X 18 FUTURE ACTION B 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 7 8 D 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 The Fan Cooler Unit was removed from service to reduce the liquid waste disposal

1 system burden. The plant was brought to the cold shutdown condition within the

2 Tech. Spec. permitted time period. During the present refueling/maintenance

3 outage the cooler coil will be inspected. A follow-up report will be submitted

4 upon determining cause and corrective actions.

5 FACILITY STATUS E 28 % POWER 0 9 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Removed from service 32

6 ACTIVITY RELEASED Z 33 CONTENT OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE 38 DESCRIPTION NA 39

8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

0 ISSUED N 44 DESCRIPTION NA 45

8211010260 821014  
PDR ADOCK 05000247  
S PDR

NRC USE ONLY

NAME OF PREPARER Gary Hinrichs PHONE (914) 526-5475