DISTRIBUTION

Docket Nos.: 50-327, 50-328

NRC PDR

L PDR LB #4 r/f TERA/NSIC

EAdensam MDuncan CStahle

OCT 2 1 1982

Docket Nos.: 50-327

and 50-328

Mr. H. G. Parris Manager of Power Tennessee Valley Authority 500A Chestnut Street, Tower II Chattanooga, Tennessee 37401

Dear Mr. Parris:

Subject: Request to Uncover ERCW Lines at Sequoyah

Your letter of May 5, 1982, stated that there is a need to remove two feet of the ten foot layer of backfill over the essential raw cooling water (ERCW) lines during a five day installation period for new sewage treatment lines. We understand that this work is now to be carried out during the current outage.

We conclude that the probability of damage to the ERCW lines during this period as a result of tornadoes is sufficiently low to eliminate the need for additional protection for the ERCW lines during this period.

Sincerely,

Elinor G. Adensam, Chief Licensing Branch No. 4 Division of Licensing

cc: See next page

8211010505 82102 PDR ADOCK 05000327

OFFICE	DL:LB#4	DL:LB#4	DL:LB#4	 	
SURNAME)	C Stable:eb	MDuncan	EAdensam	 	
DATE	10/10 /82	10/20 /82	10/2/182	 	

Mr. H. G. Parris Manager of Power Tennessee Valley Authority 500A Chestnut Street, Tower II Chattanooga, Tennessee 37401

cc: Herbert S. Sanger, Jr., Esq.
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33
Knoxville, Tennessee 37902

Mr. H. N. Culver Tennessee Valley Authority 400 Commerce Avenue, 249A HBB Knoxville, Tennessee 37902

Mr. Bob Faas Westinghouse Electric Corp. P.O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. Jerry Wills Tennessee Valley Authority 400 Chestnut Street, Tower II Chattanooga, Tennessee 37401

Mr. Donald L. Williams, Jr. Tennessee Valley Authority 400 West Summit Hill Drive, W10B85 Knoxville, Tennessee 37902

Resident Inspector/Sequoyah NPS c/o U.S. Nuclear Regulatory Commission 2600 Igou Ferry Road Soddy Daisy, Tennessee 37379

James P. O'Reilly, Regional Administrator U.S. Nuclear Regulatory Commission, Region II 101 Marietta Street, Suite 3100 Atlanta, Georgia 30303