

APPENDIX A
NOTICE OF VIOLATION

Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Docket Nos. 50-317, 50-318
License Nos. DPR-53, DPR-69

As a result of the inspection conducted at the Calvert Cliffs Nuclear Power Plant on November 26-29, 1990, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), the following violation was identified.

10 CFR 20.203(c)(5) states in part that for a high radiation area "...any licensee, or applicant for a license, may apply to the Commission for approval of methods...for controlling access to high radiation areas...". Technical Specification 6.12.1.a for each unit states in part that "...a high radiation area...shall be barricaded and conspicuously posted as a High Radiation Area and entrance thereto shall be controlled by issuance of a Special or Radiation Work Permit and any individual or group of individuals permitted to enter such areas shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area...".

Contrary to the above, on January 17, 1990, two contractor personnel entered a posted High Radiation Area without a dose rate meter as required by Special Work Permit to meet the conditions of Technical Specification 6.12.1.a. On February 6, 1990, a plant operator also entered a posted High Radiation Area without a dose rate meter, as did two other contractor personnel on June 13, 1990.

This is a Severity Level IV Violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Baltimore Gas and Electric Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

"OFFICIAL RECORD COPY"

9012260021 901218
PDR ADOCK 05000317
Q PDR