December 14, 1990

Docket No. 50-416

Mr. William T. Cottle Vice President, Operations GGNS Entergy Operations, Inc. Post Office Box 7-5 Port Gibson, Mississippi 39150 DISTRIBUTION
Docket File
PD4-1 RF
PD4-1 PF
TQuay
LBerry
LKintner

BBoger(MS13E4) EJordan(MNBB3701) ACRS(10)(MSP-315) MVirgilio(MS13E4) PHarrell,RGNIV OGC(MS15B18) NRC & Local PDR

Dear Mr. Cottle:

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NO. 77146)

By letter dated May 7, 1990, you applied for an amendment to the Grand Gulf Nuclear Station, Unit 1, Operating License No. NPF-29. The proposed amendment would change the Technical Specifications (TS) Section 3/4.7.2, "Control Room Emergency Filtration System," by identifying six air-operated isolation valves in the system as those required by TS 4.7.2.d.2 to close within 4 seconds. The present TS implies that all valves in the system must be verified to close within 4 seconds, including two fresh air inlet valves which are motor-operated and designed to close in about 75 seconds. The basis for this implication was Updated Final Safety Analysis Report (UFSAR), Table 18.1-2, "Control Room Isolation Damper Characteristics," hich erroneously listed all eight valves as having a maximum closing time of 4 seconds.

Your letter dated December 7, 1990, withdrew the amendment request because UFSAR Table 18.1-2 was corrected by deleting the two motor-operated valves from the table and adequate clarification regarding the safety function and surveillance testing of these two valves had been provided in meetings with the NRC staff on October 23 and November 6, 1990. Staff summaries of the meetings were issued on November 28 and November 30, 1990, respectively. The UFSAR change was submitted by licensee's letter dated December 1, 1990.

Your proposed amendment is considered withdrawn.

Sincerely,

ORIGINAL SIGNED BY

Lester L. Kintner, Senior Project Manager Project Directorate IV-1 Division of Reactor Projects III, IV, and V Office of Nuclear Reactor Regulation

cc: See next page

			1			
FC PRA	1 200	- · Add	:P04-1/01			
IAME : LBer	ry	: LKyhlemer: 1h. J	TOURY			
ATE : 12/	W90	: 1/14/90 //	12/14/90		:	
Comment C	FFICIAL RECO	ORD COPY	Document Na	me: GG AMEND/77	7146	

9012260178 901214 PDR ADOCK 05000416 Je01

Docket No. 50-416

Mr. William T. Cottle Vice President, Operations GGNS Entergy Operations, Inc. Post Office Box 756 Port Gibson, Mississippi 39150 DISTRIBUTION
Docket File
PD4-1 RF
PD4-1 PF
TQuay
LBerry
LKintner

DISTRIBUTION
BBoger(MS13E4)
EJordan(MNBB3701)
ACRS(10)(MSP-315)
MVirgilio(MS13E4)
PHarrell,RGNIV
OGC(MS15B18)
NRC & Local PDR

Dear Mr. Cottle:

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NO. 77146)

By letter dated May 7, 1990, you applied for an amendment to the Grand Gulf Nuclear Station, Unit 1, Operating License No. NPF-29. The proposed amendment would change the Technical Specifications (TS) Section 3/4.7.2, "Control Room Emergency Filtration System," by intifying six air-operated isolation valves in the system as those required by TS 4.7.2.d.2 to close within 4 seconds. The present TS implies that all valves in the system must be verified to close within 4 seconds, including two fresh air inlet valves which are motor-operated and designed to close in about 75 seconds. The basis for this implication was Updated Final Safety Analysis Report (UFSAR), Table 18.1-2, "Control Room Isolation Damper Characteristics," which erroneously listed all eight valves as having a maximum closing time of 4 seconds.

Your letter dated December 7, 1990, withdrew the amendment request because UFSAR Table 18.1-2 was corrected by deleting the two motor-operated valves from the table and adequate clarification regarding the safety function and surveillance testing of these two valves had been provided in meetings with the NRC staff on October 23 and November 6, 1990. Staff summaries of the meetings were issued on November 28 and November 30, 1990, respectively. The UFSAG change was submitted by licensee's letter dated December 1, 1990.

Your proposed amendment is considered withdrawn.

Sincerely,

ORIGINAL SIGNED BY:

Lester L. Kintner, Senior Project Manager Project Directorate IV-1 Division of Reactor Projects III, IV, and V Office of Nuclear Reactor Regulation

CC: See next page

FC PD4-1/(A) :PD4-1/PM :PD4-1/PM : PD4-1/PM : P



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

December 14, 1990

Docket No. 50-416

Mr. William T. Cottle Vice President, Operations GGNS Entergy Operations, Inc. Post Office Box 756 Port Cibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - WITHDRAWAL OF AN AMENDMENT

REQUEST (TAC NO. 77146)

By letter dated May 7, 1990, you applied for an amendment to the Grand Gulf Nuclear Station, Unit 1, Operating License No. NPF-29. The proposed amendment would change the Technical Specifications (TS) Section 3/4.7.2, "Control Room Emergency Filtration System," by identifying six air-operated isolation valves in the system as those required by TS 4.7.2.d.2 to close within 4 secunds. The present TS implies that all valves in the system must be verified to close within 4 seconds, including two fresh air inlet valves which are motor-operated and designed to close in about 75 seconds. The basis for this implication was Updated Final Safety Analysis Report (UFSAR), Table 18.1-2, "Control Room Isolation Damper Characteristics," which erroneously listed all eight valves as having a maximum closing time of 4 seconds.

Your letter dated December 7, 1990, withdrew the amendment quest because UFSAR Table 18.1-2 was corrected by deleting the two motor-operated valves from the table and adequate clarification regarding the safety function and surveillance testing of these two valves had been provided in meetings with the NRC staff on October 23 and November 6, 1990. Staff summaries of the meetings were issued on November 28 and November 30, 1990, respectively. The UFSAR change was submitted by licensee's letter dated December 1, 1990.

Your proposed amendment is considered withdrawn.

Sincerely,

ester L. Kintner, Senior Project Manager

Project Directorate IV-1

Division of Reactor Projects III, IV, and V

Office of Nuclear Reactor Regulation

cc: See next page

Mr. W. T. Cottle Entergy Operations, Inc.

cc:

Mr. Ted H. Cloninger Vice President, Engineering Entergy Operations Inc. P. O. Box 31995 Jackson, Mississippi 39286-1995

Robert B. McGehee Wise, Carter, Child & Caraway P. O. Box 651 Jackson, Mississippi 39205

Nicholas S. Reynolds, Esquire Winston & Strawn 1400 L Street, N.W. - 12th Floor Washington, D.C. 20005-3502

Mr. Jim T. LeGros Manager of Quality Assurance Entergy Operations, Inc. P. O. Box 31995 Jackson, Mississippi 39286-1995

Mr. Jack McMillan, Director Division of Solid Waste Management Mississippi Department of Natural Resources P. O. Box 10385 Jackson, Mississippi 39209

Mr. Michael J. Meisner Director, Nuclear Licensing Entergy Operations, Inc. P. O. Box 756 Port Gibson, Mississippi 39150

Mr. C. B. Hogg, Project Manager Bechtel Power Corporation P. O. Box 2166 Houston, Texas 77252-2166

Mr. H. O. Christensen Senior Resident Inspector U.S. Nuclear Regulatory Commission Mr. Donald C. Hintz, Executive Vice Route 2, Box 399 Port Gibson, Mississippi 39150

Grand Gulf Nuclear Station

Mr. C. R. Hutchinson GGNS General Manager Entergy Operations, Inc. P. O. Box 756 Port Gibson, Mississippi 39150

The Honorable William J. Guste, Jr. Attorney General Department of Justice State of Louisiana P. O. Box 94005 Baton Rouge, Louisiana 70804-9005

Alton B. Cobb, M.D. State Health Officer State Board of Health P. O. Box 1700 Jackson, Mississippi 39205

Office of the Governor State of Mississippi Jackson, Mississippi 39201

President, Claiborne County Board of Supervisors Port Gibson, Mississippi 39150

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta St., Suite 2900 Atlanta, Georgia 30°23

Mike Morie, Attorney General Frank Spencer, Asst. Attorney General State of Mississippi Post Office Box 22947 Jackson, Mississippi 39225

Mr. Gerald W. Muench Vice President, Operations Support Entergy Operations, Inc. P. O. Lox 31995 Jackson, Mississippi 39286-1995

President & Chief Operating Officer Entergy Operations, Inc. P. O. Box 31995 Jackson, Mississippi 39286-1995