

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 M D C C N 2 2 0 0 - 1 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

1 REPORT SOURCE L 6 0 5 0 0 0 3 1 8 7 0 4 1 1 4 8 1 8 0 5 0 4 8 1 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 At 1025, during the performance of modification work, a drain line was  
3 accidentally broken from the emergency discharge of 22 ECCS pump room  
4 cooler. This necessitated the shutdown of 21 Saltwater Header (T. S.  
5 3.7.5.1), to effect repairs. #21 Saltwater Header was returned to ser-  
6 vice at 1930. The redundant Saltwater Header remained operable during  
7 this event. This is not a repetitive occurrence.

9 SYSTEM CODE W A 11 CAUSE CODE A 12 CAUSE SUBCODE F 13 COMPONENT CODE P I P E X X 14 COMP. SUBCODE A 15 VALVE SUBCODE Z 16

17 LER/RO REPORT NUMBER 8 1 18 EVENT YEAR 8 1 19 SEQUENTIAL REPORT NO. 0 1 7 20 OCCURRENCE CODE 0 3 21 REPORT TYPE L 22 REVISION NO. 0

23 ACTION TAKEN B 24 FUTURE ACTION Z 25 EFFECT ON PLANT Z 26 SHUTDOWN METHOD Z 27 HOURS 0 0 0 0 28 ATTACHMENT SUBMITTED N 29 NPRD-4 FORM SUB. N 30 PRIME COMP. SUPPLIER A 31 COMPONENT MANUFACTURER X 9 9 9 32

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 A dropped tool broke the plastic nipple. Scaffolding was not equipped  
1 with required toe boards. All scaffolding has been checked to ensure  
2 the boards are installed. Applicable personnel were cautioned to be  
3 more careful when working around operating equipment and of the require-  
4 ment for toe boards on scaffolding.

5 FACILITY STATUS G 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

6 ACTIVITY RELEASED Z 33 CONTENT OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NAME OF PREPARER J. S. Lagiewski/M. E. Roberson PHONE: (301) 269-4747/4807

8211020132 810504  
PDR ADOCK 05000318  
S PDR

GPO 817-928