

December 13, 1990

Docket No. 50-264

Dr. Charles W. Kocher
Reactor Manager
H&E.S/I.H
1602 Building
Dow Chemical Company
Midland, Michigan 48674

Dear Dr. Kocher:

SUBJECT: ISSUANCE OF AMENDMENT NO. 6 TO FACILITY OPERATING LICENSE
NO. R-108 - DOW CHEMICAL COMPANY

The Commission has issued the enclosed Amendment No. 6 to Facility Operating License No. R-108 for the Dow Chemical Company. The amendment consists of changes to the Technical Specifications in response to your submittal dated October 15, 1990 and supplemented on November 20, 1990.

The amendment allows the installation of a microprocessor based instrumentation and control system. The Technical Specifications are amended to reflect the new instrumentation and control system, and an administrative change to the date when the annual report is to be issued.

A copy of the related Safety Evaluation supporting Amendment No. 6 is enclosed.

Sincerely,

Original signed by:
Marvin M. Mendonca, Senior Project Manager
Non-Power Reactors, Decommissioning and
Environmental Projects Directorate
Division of Advanced Reactors
and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 6
2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

✓ Docket file	EJordan	NRC & Local PDRs	GH11 (4)
NRDE r/f	WJones	WTravers	JCalvo
EHylton	ACRS (10)	MMendonca	GPA/PA
OGC	OC/LFMB	DHagan	Plant file
Region V	AAdams	SNewberry	

[AMEND 6 DOE]

NRDE:LA
EHylton
11/28/90

NRDE:PM *MM*
MMendonca/sr
11/28/90

OGC *OGC* SICB *SICB* NRDE:D *NRDE:D*
~~11/17/90~~ SNewberry *SNewberry* Weiss *Weiss*
 12/7/90 *12/7/90* 11/13/90 12/13/90

9012260269 901213
PDR ADOCK 05000264
P PDR

198025

JFO
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

December 13, 1990

Docket No. 50-264

Dr. Charles W. Kocher
Reactor Manager
H&E.S/I.H
1602 Building
Dow Chemical Company
Midland, Michigan 48674

Dear Dr. Kocher:

SUBJECT: ISSUANCE OF AMENDMENT NO. 6 TO FACILITY OPERATING LICENSE
NO. R-108 - DOW CHEMICAL COMPANY

The Commission has issued the enclosed Amendment No. 6 to Facility Operating License No. R-108 for the Dow Chemical Company. The amendment consists of changes to the Technical Specifications in response to your submittal dated October 15, 1990 and supplemented on November 19, 1990.

The amendment allows the installation of a microprocessor based instrumentation and control system. The Technical Specifications are amended to reflect the new instrumentation and control system, and an administrative change to the date when the annual report is to be issued.

A copy of the related Safety Evaluation supporting Amendment No. 6 is enclosed.

Sincerely,

A handwritten signature in cursive script, appearing to read "Marvin M. Mendonca".

Marvin M. Mendonca, Senior Project Manager
Non-Power Reactors, Decommissioning and
Environmental Projects Directorate
Division of Advanced Reactors
and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 6
2. Safety Evaluation

cc w/enclosures:
See next page

Dow Chemical Company

Docket No. 50-264

cc:

Office of the Mayor
202 Ashman
Midland, Michigan 48640

Dr. J. M. Macki, Chairman
Reactor Operations Committee
Dow Chemical Company
1602 Building
Midland, Michigan 48640

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913