

Appendix

NOTICE OF VIOLATION

The Detroit Edison Company

Docket No. 50-314⁴

As a result of the inspection conducted on September 13-15, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

Paragraph 1.5.4 of the Fermi QA Manual states that testing activities will comply with the requirements of 10 CFR 50, Appendix B, Criterion XI "Test Control," which requires written test procedures which include acceptance limits contained in applicable design documents.

Contrary to the above, Preoperational Test Procedure PRET.C4100-001, Revision 3 was approved for use and did not contain acceptance limits for overpressure relief valve setpoints or the current level at which the explosive valve activation logic loss of continuity alarm should operate.

This is a Severity Level V violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Oct 15, 1982
Dated

W. S. Little
W. S. Little, Chief
Engineering Programs Branch