

## OPERATING DATA REPORT

DOCKET NO. 50-286  
 DATE 9/1/82  
 COMPLETED BY L. Auterino  
 TELEPHONE (914) 739-8200

### OPERATING STATUS

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: August, 1982
3. Licensed Thermal Power (MWr): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 926
7. Maximum Dependable Capacity (Net MWe): 891
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reasons For Restrictions, If Any: \_\_\_\_\_

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	5,831.0	52,632.0
12. Number Of Hours Reactor Was Critical	0	1,984.6	34,090.8
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	0	1,969.6	32,913.1
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	0	5,060,030	86,143,401
17. Gross Electrical Energy Generated (MWH)	0	1,502,170	26,298,300
18. Net Electrical Energy Generated (MWH)	0	1,436,036	25,183,443
19. Unit Service Factor	0	33.8	62.5
20. Unit Availability Factor	0	33.8	62.5
21. Unit Capacity Factor (Using MDC Net)	0	27.6	53.7
22. Unit Capacity Factor (Using DER Net)	0	25.5	49.6
23. Unit Forced Outage Rate	0	2.3	14.3

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling outage in progress

8211020207 820909  
 PDR ADDCK 05000286  
 R PDR

Upon completion of scheduled maintenance EST. Date (Jan. 83)

25. If Shut Down At End Of Report period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast                      Achieved

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-286

UNIT Indian Point  
No. 3

DATE 9/1/82

COMPLETED BY L. Auterino

TELEPHONE (914) 739-8200

MONTH August, 1982

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

**INSTRUCTIONS**

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

MONTHLY I & C CATEGORY I REPORT

August 1982  
 \_\_\_\_\_  
 Month

W.R. No.	DATE	EQUIPMENT	MALFUNCTION	CORRECTIVE ACTION
IC-1-1766-2	8/5/82	31 Diesel Generator Day Tank Level Indicator	Erroneous Readings	Replaced indicator

## MONTHLY MAINTENANCE REPORT

August, 1982

Month

M.R. #	DATE	EQUIPMENT	MALFUNCTION	CORRECTIVE ACTION
-2990	8/12/82	MS-55 Main steam valve on No. 32 steam generator.	Leaks passed seat	Cleaned seating surfaces
-2996	8/12/82	FCV-1176A, Service water valve from the Diesel Generators	Valve failed open .	Clean and tighten wiring terminals on valve operator

**UNIT SHUTDOWNS AND POWER REDUCTIONS**

DOCKET NO. 50-286  
 UNIT NAME Indian Point No. 3  
 DATE 9/1/82  
 COMPLETED BY L. Auterino  
 TELEPHONE (914) 739-8200

REPORT MONTH August, 1982

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
04	820325	S	744	B&C	N/A		N/A	N/A	Unit in a scheduled cycle III-IV refueling and maintenance outage.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

<sup>5</sup>  
 Exhibit - Same Source

## OPERATING EXPERIENCE

Indian Point Unit 3 remained shutdown for the entire reporting period.

During the period of July 30 to August 5, a containment integrated leak rate test (ILRT) was performed.

Preparations for steam generator sleeving and secondary side girth weld repairs are in progress.