VIRGINIA ELECTRIC AND POWER COMPANY

NORTH ANNA POWER STATION

MONTHLY OPERATING REPORT

MONTH August YEAR 1982

APPROVED:

STATION MANAGER

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. _50-338

UNIT _NA-1

DATE 09-01-82

COMPLETED BY G. Schmitendorf

TELEPHONE703-894-5151X2502

MONTH	August		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u> </u>	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

OPERATING DATA REPORT

DOCKET NO. 50-338

DATE 09-01-82

COMPLETED BY G. D. Schmitendorf (703) 894-5151 X2502

OPERATING STATUS

			Notes	
1.	Unit Name: North Anna 1			
2.	Reporting Period: August 1982			
3.	Licensed Thermal Power (MWt):	2775		
4.	Nameplate Rating (Gross MWe):	947		
5.	Design Electrical Rating (Net MWe):	907		
6.	Maximum Dependable Capacity (Gross MWe):	918		
7.	Maximum Dependable Capacity (Net MWe):	865		
8.	If Changes Occur in Capacity Ratings (It		u 7) Since Last R	eport, Give Reasons
	NA			
	Power Level To Which Restricted, If Any	(Net MWe):	N/A	
10.	Reasons For Restrictions, If Any:		N/A	
		This Month	Yrto-Date	Cumulative
11.	Hours In Reporting Period	744	5,831	37,152
12.		0	3,129.9	26,958.2
13.	Reactor Reserve Shutdown Hours	0	21.5	256.4
14.	Hours Generator On-Line	0	3,022.9	26,375.9
15.	Unit Reserve Shutdown Hours	0	0	0
16.	Gross Thermal Energy Generated (MWH)	0	7,941,328	68,255,580
17.	Gross Electrical Energy Generated (MWH)	0	2,537,888	21,783,410
18.	Net Electrical Energy Generated (MWH)	0	2,396,973	20,519,889
19.	Unit Service Factor	0	51.8	71.0
20.	Unit Availability Factor	0	51.8	71.0
21.		0	47.5	63.9
22.		0	45.3	60.9
23.		0	7.3	5.1
24.	Shutdowns Scheduled Over Next 6 Months	(Type, Date, a	and Duration of E	ach):
_				
25. 26.	185, 181 1 181, 181, 182, 183, 183, 183, 183, 183, 183, 183, 183			10-21-82
			Forecast	Achieved
	INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION			

UNIT SHUTDOWNS AND POWER REDUCTIONS

August

Licensee

Event

DOCKET NO.

50-338

UNIT NAME DATE

North Anna 1

COMPLETED BY

09-01-82 G. D. Schmitendorf

TELEPHONE

(703) 894-5151 X2502

Type Duration Reason 2 No. Date (Hours)

Method of Shutting Down Reactor Report #

REPORT MONTH

System Code 4 Component Code 5

Cause & Corrective Action to Prevent Recurrence

82-10

S 744 The scheduled refueling outage continues

F: Forced S: Scheduled Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3

Method:

1-Manual

2-Manual Scram. 3-Automatic Scram

4-Continuations

5-Load Reduction

9-Other

Exhibit F - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File

(NUREG-0161)

5

Exhibit H - Same Source

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-339

UNIT NA-2

DATE 09-01-82

COMPLETED BY G. Schmitendorf

TELEPHONE703-894-5151X2502

MONTH	August		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	92.5
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	93.7
15	0	31	206.6
16	0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

OPERATING DATA REPORT

DOCKET NO. 50-339

DATE 09-01-82

COMPLETED BY G. D. Schmitendorf
TELEFHONE (703) 894-5151 X2502

OPERATING STATUS

			Notes	
1.	Unit Name: North Anna 2			
2.	Reporting Period August 1982			
3.	Licensed Thermal Power (MWt):	2775		
4.	Nameplate Rating (Gross MWe):	947		
5.	Design Electrical Rating (Net MWe):	907		
6.	Maximum Dependable Capacity (Gross MWe):			
7.	Maximum Dependable Capacity (Net MWe):	890		
8.	If Changes Occur in Capacity Ratings (It		7) Since Last Re	eport. Give Reasons
			.,	port, orre neadon.
	NA			
9.	Power Level To Which Restricted, If Any	(Net MWe):	N/A	
10.	Reasons For Restrictions, If Any:	(Mee Me).	N/A	
-				
		This Month	Yrto-Date	Cumulative
11.	Hours In Reporting Period	744	5,831	15,023
12.	Number of Hours Reactor Was Critical	49.9	2,192.6	9,607.4
13.	Reactor Reserve Shutdown Hours	185.1	358.8	1,992
14.	Hours Generator On-Line	46.8	2,108.5	9,567.9
15.	Unit Reserve Shutdown Hours	0	0	0
16.	Gross Thermal Energy Generated (MWH)	40,396	5,112,986	23,895,827
17.	Gross Electrical Energy Generated (MWH)	11,230	1,687,590	8,002,822
18.	Net Electrical Energy Generated (MWH)	9,413	1,595,412	7,597,828
19.	Unit Service Factor	6.3	36.2	63.7
20.	Unit Availability Factor	6.3	36.2	63.7
21.	Unit Capacity Factor (Using MDC Net)	1.4	30.7	56.8
22.	Unit Capacity Factor (Using DER Net)	1.4	30.2	55.8
23.	Unit Forced Outage Rate	93.7	40.0	24.2
24.	Shutdowns Scheduled Over Next 6 Months			
25. 26.		stimated Date	of Startup:	
	the rest states (Filer to commercia		orecast	Achieved
	INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION	-		

UNIT SHUTDOWNS AND POWER REDUCTIONS

UNIT NAME North Anna 2 09-01-82 DATE G. D. Schmitendorf COMPLETED BY August REPORT MONTH (703) 894-5151 X2502 TELEPHONE Type Duration Reason 2 Method of Licensee Cause & Corrective System Component Code 4 Code 5 Shutting Bevent Down Reactor Report # (Hours) Action to Prevent Recurrence Continued from Previous Month Repair work necessary following 82-13 820708 F 512.1 thermal sleeves inspection in progress. "B" Phase Main Transformer 82-14 820822 F 185.1 NA NA NA Failure.

DOCKET NO.

50-339

d: Exhibit F - Instructions
**
al for Preparation of Data
ual Scram. Entry Sheets for Licensee
omatic Scram Event Report (LER) File
tinuations (NUREG-0161)
d Reduction
er s
Exhibit H - Same Source
1

	Pa	ge <u>1</u>	of _1_
UNIT SHUTDOWN	AND POWER	REDUCTION	NS
EXPLANATION SH	EET DO	CKET NO.	50-338
REPORT MONTH	August	_UNIT N	AME NA-2
YEAR	1982	DATE	09-01-82

COMPLETED BY G. D. Schmitendorf

82-14 (A) (3) At 1931 on August 22, 1982 with the unit at approximately 30% power the unit was stable and maintaining a power level below 30% for secondary chemistry to come within allowable specification for power escalation. A "B" Main Transformer Differential Trip Alarm was received. This was immediately followed by a turbine trip and a reactor trip. Initial investigation indicated that an internal explosion had occurred on "B" Main Transformer. The unit was taken to Mode 3 and stabilized there. The reason for the transformer failure is still under investigation. The transformer was replaced with a spare and the unit returned to power one week after the unit trip.