	LICENSEE EVENT REPORT
	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5.
CON'T 0 1 7 6	SOURCE LEG 0 5 0 0 0 3 1 1 0 0 8 8 2 8 1 0 2 0 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 On October 8, 1982, while performing a containment surveillance, an operator dis-
0 3	covered a small service water leak of approximately 0.5 GPM on No. 21 Containment Fan
04	Coil Unit (CFCU). The unit was declared inoperable, the CFCU was immediately
0 5	isolated, and prompt notification of the NRC was performed. Since No. 22 CFCU was
0 6	out of service for planned maintenance, Action Statement 3.6.2.3.b was entered. Both
0 7	containment spray systems were operable. The occurrence constituted abnormal degra-
0 8	dation of the containment in accordance with Technical Specification 6.9.1.8.c
7 8	SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
10	The leakage was due to erosion of the cooling coils by silt in the service water. The
111	leak was repaired utilizing Belzona metal filler, the unit was satisfactorily
112	tested, and the action statement was terminated. A new design cooler will be
1 3	installed during the next refueling.
1 4	(82-113, 82-112, 82-111, 82-109, 82-101)
1 5	STATUS POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 0 8 1 29 NA A 31 Operator Observation
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35 Z 33 Z 34 NA PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35 NA BO BO
1 7 7 8	NUMBER TYPE DESCRIPTION (39) 9
1 8	NUMBER DESCRIPTION (41) d o o 0 NA 9 11 12 8211020238 821020 80
1 9	TYPE DESCRIPTION S PDR ADOCK 05000311 B NA S PDR ADOCK 05000311
20	PUBLICITY SSUED DESCRIPTION 45 NRC USE ONLY NRC USE ONLY
7 8	R. Frahm 609/935-6000 Ext 3070
	NAME OF PREPARER PHONE: