

# CP&L

Carolina Power & Light Company

Brunswick Nuclear Project  
P. O. Box 10429  
Southport, N.C. 28461-0429  
December 20, 1990

FILE: B09-13510C  
SERIAL: BSEP/90-0827

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555


BRUNSWICK STEAM ELECTRIC PLANT UNIT 1  
DOCKET NO. 50-325  
LICENSE NO. DPR-71  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND  
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-90-004)

Gentlemen:

During the Unit 1 Refuel 7 and Maintenance Outage, a Unit 1 fire barrier LCO was initiated on November 14, 1990, for Fire Barrier Penetration Seal No. R1-2-049 in the unit Reactor Building and fire watches were appropriately stationed. Fire Seal NO. R1-2-049 [pipe cap] approximate location is on the 30-foot elevation west wall. The subject LCO was initiated to facilitate IGSCC GE inspection equipment, cable and leads, being run into the unit Reactor Building.

Due to the scope of the involved work, the seven day time frame of the LCO was exceeded on November 21, 1990. Until completion of this ISI work and subsequent return of the fire barrier penetration to service and cancellation of the LCO, an hourly fire watch patrol, as required by Technical Specifications, will remain in effect.

Very truly yours,



J. L. Harness, General Manager  
Brunswick Nuclear Project

9012270313 901230  
PDR ADOCK 05000325  
S FDR

TEC 2  
10

BSEP/90-0782

-2-

WRT/

Enclosure

cc: Mr. S. D. Ebnetter  
Mr. N. B. Le  
BSEP NRC Resident Office